

Table 21 Vacuum – design and diversified flows

Department	Design flow for each terminal unit (L/min)	Diversified flow Q (L/min)
In-patient accommodation:		
Ward unit	40	$Q = 40$
Multiple ward units	40	$Q_d = 40 + [(n - 1)40/4]$
Accident & emergency:		
Resuscitation room, per trolley space	40	$Q = 40 + [(n - 1)40/4]$
Major treatment/plaster room, per trolley space	40	$Q = 40 + [(n - 1)40/4]$
Post-anaesthesia recovery, per trolley space	40	$Q = 40 + [(n - 1)40/4]$
Treatment room/cubicle	40	$Q = 40 + [(n - 1)40/8]$
Operating:		
Anaesthetic rooms	40	No additional flow included
Operating rooms:		
Anaesthetist	40	$Q = 40$
Surgeon	40	$Q = 40$
Operating suites	40	$Q_s = 80 + [(nS - 1)80/2]$
Post-anaesthesia recovery	40	$Q = 40 + [(n - 1)40/4]$
Maternity:		
LDRP rooms:		
Mother	40	$Q = 40 + [(n - 1)40]/4$
Baby	40	No additional flow included
Operating suites:		
Anaesthetist	40	$Q = 40$
Obstetrician	40	$Q = 40$
Operating suites		$Q_s = 80 + [(nS - 1)80/2]$
Post-anaesthesia recovery	40	$Q = 40 + [(n - 1)40/4]$
In-patient accommodation:		
Ward unit comprising single, multi-bed and treatment room	40	$Q = 40$
Multi-ward units	40	$Q = 40 + [(n - 1)40/2]$
Nursery, per cot space	40	No additional to be included
SCBU	40	$Q = 40 + [(n - 1)40/4]$
Radiology/diagnostic departments:		
All anaesthetic and procedures rooms	40	$Q = 40 + [(n - 1)40/8]$
Critical care areas	40	$Q = 40 + [(n - 1)40/4]$
High-dependency units	40	$Q = 40 + [(n - 1)40/4]$
Renal	40	$Q_d = 40 + [(n - 1)40/4]$
Adult mental illness accommodation:		
ECT room	40	$Q = 40 + [(n - 1)40/4]$
Post-anaesthesia, per bed space	40	$Q = 40 + [(n - 1)40/4]$
Adult acute day care accommodation:		
Treatment rooms	40	$Q = 40 + [(n - 1)40/4]$
Post-anaesthesia recovery per bed space	40	$Q = 40 + [(n - 1)40/8]$
Day patient accommodation (as “In-patient accommodation”)		As “In-patient accommodation”
Oral surgery/orthodontic:		
Consulting rooms, type 1	40	Dental vacuum only
Consulting rooms, types 2 & 3	40	Dental vacuum only
Recovery room, per bed space	40	$Q = 40 + [(n - 1)40/8]$
Out-patient:		
Treatment rooms	40	$Q = 40 + [(n - 1)40/8]$
Equipment service rooms, sterile services etc	40	Residual capacity will be adequate without an additional allowance