



BID BULLETIN NO. 3
10 JULY 2024

Public Bidding No. VMC-2024-034
**SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF INVERTER AIR-
CONDITIONING UNITS OF DIFFERENT AREAS IN HOSPITAL AND MOTOR POOL**

Issued pursuant to Sec. 22.5 of the IRR of RA 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by the prospective bidders during the **Pre-Bid** Conference held on July 04, 2024, likewise, respond to bidder's written queries received within the prescriptive period for filing.

POSTED IN BIDDING DOCUMENTS		AMENDMENT	
Section VI. Schedule of Requirements			
TERMS OF REFERENCE			
ANNEX A			
• NO POSTED SPECIFICATIONS FOR:			
A. Air-Conditioning Unit, Window Type, 2.0HP, Inverter Type		A. Air-Conditioning Unit, Window Type, 2.0HP, Inverter Type	
		FEATURES	SPECIFICATION
		Fan Coil Application Type	Window Type
		Cooling Capacity (minimum)	17640 KJ/h
		Energy Efficient Ratio (minimum)	11.5 – 12.0 KJ / W-hr
		DOE Certification at least 3-4 Star	
		Features	Unit
		Power Supply	V
		Phase	Ø
		System Power Input, max	2800 W
		Sound Pressure Level (indoor), max	52 – 57
		Compressor Type	Scroll/Rotary
		Refrigerant	R410 / R32
		Controls	Wireless remote control with built-in timer, temperature control
		Air Filter	Washable
B. Air-Conditioning Unit, Window Type, 1.5HP, Inverter Type		B. Air-Conditioning Unit, Window Type, 1.5HP, Inverter Type	
		FEATURES	SPECIFICATION
		Fan Coil Application Type	Window Type
		Cooling Capacity (minimum)	12160 KJ/h
		Energy Efficient Ratio (minimum)	11.0 – 12.0 kJ / W-hr
		DOE Certification at least 3-4 Star	
		Features	Unit
		Power Supply	V
		Phase	Ø
		System Power Input, max	1390 W
		Sound Pressure Level (indoor), max	52 – 57

"PHIC Accredited Healthcare Provider"

"Valenzuela Medical Center...Where your health matters most"



Republic of the Philippines
Department of Health
Metro Manila Center for Health Development
VALENZUELA MEDICAL CENTER




	Compressor Type		Scroll/Rotary
	Refrigerant		R410 / R32
	Controls		Wireless remote control with built-in timer, temperature control
	Air Filter		Washable
ADDITIONAL REQUIREMENT OF VMC (FINANCIAL COMPONENT)			
PRICE SCHEDULE FOR GOODS OFFERED FROM WITHIN THE PHILLIPINES OR ABROAD	<ul style="list-style-type: none">➤ Price offer must be listed in line item with total amount as basis for LOT BID➤ Indicate the brand and country of origin per line item		

All other provisions of the bidding documents not affected by revisions included in this Bid Bulletin shall remain in effect. Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

Prepared by:


LESTER JOHN JAKE R. DIVINO, LPT
BAC Secretariat

Noted by:


SHIRLENE V. VIANZON
Chairperson, BAC

"PHIC Accredited Healthcare Provider"

"Valenzuela Medical Center...Where your health matters most"

• Padrigal St., Karuhatan, Valenzuela City 1441 • Trunk Line: 294-67-11 loc. 134; • Fax: 291-42-59
• URL: <http://vmc.doh.gov.ph> • Email: valgen_hosp@yahoo.com