



Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number

12549566

Procuring Entity

VALENZUELA MEDICAL CENTER

Title

SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF TWO (2) INVERTER AIRCONDITIONING UNITS

Area of Delivery

Metro Manila

Solicitation Number:	VMC-2025-267	Status	Pending
Trade Agreement:	Implementing Rules and Regulations		
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Associated Components	1
Classification:	Goods	Bid Supplements	0
Category:	Airconditioning and Airconditioning Systems	Document Request List	0
Approved Budget for the Contract:	PHP 200,833.34	Date Published	04/11/2025
Delivery Period:	30 Day/s	Last Updated / Time	03/11/2025 16:32 PM
Client Agency:		Closing Date / Time	07/11/2025 10:00 AM
Contact Person:	LESTER JOHN JAKE R DIVINO BAC SECRETARIAT Padrigal St., Karuhatan, Valenzuela City Metro Manila Philippines 63-2-2920604 vmc.bac2025@gmail.com		

Description
STOCK/ PROPERTY NO. UNIT ITEM DESCRIPTION QTY. UNIT COST TOTAL COST
lot Supply, Delivery, Installation, Testing and Commissioning of Inverter Airconditioning Unit 1
unit Air-Conditioning Unit, Window Type 2.0HP, Inverter Type (Chief Allied Office - Annex Building) 1 63,166.67
63,166.67
Specifications:
Fan Coil Application Type: Window Type
Cooling Capacity (minimum): 18,750 KJ/h
Energy Efficient Ratio (minimum) DOE Certification at least 3-4 Star: 11.5 - 12.3 KJ/W-hr
Power Supply: 220-240V, 60Hz (will work with Philippine Electrical System)
Phase: Single Phase
System Power Input, max: 1,524 W
Sound Pressure Level (indoor), max: 45-48 db(A)
Compressor Type: Scroll/Rotary
Refrigerant: R410A/R32
Controls: Wireless remote control with built-in timer, temperature control
Air Filter: Washable
unit Air-Conditioning Unit, (Floor Mounted) Split Type 3.0TR, Inverter Type (Chief Nurse Office - Annex Building) 1 137,666.67
137,666.67
Specifications:
Fan Coil Application Type: Cabinet Type
Cooling Capacity (minimum): 37,000 - 38,201 kJ/h
Energy Efficient Ratio (minimum) DOE Certification at least 3-4 Star: 9.5 - 12.0 kJ / W-hr
Power Supply: 220 - 240, 60Hz (will work with Philippine electrical system)
Phase: Single
System Power Input, max: 3,200 - 3,900 W
Sound Pressure Level (indoor), max: 45 - 65 db(A)
Compressor Type: Scroll/Rotary
Refrigerant: R410 / R32
Controls: Wireless remote control with built-in timer, temperature control
Air Filter: Washable
Condense air discharge: Horizontal (floor air discharge)

ACCU Fan type: Propeller
ACCU Fan Motor: Total enclosed
Service valves: Suction & liquid lines
Safety controls: High & low-pressure controls

NOTES:

- Piping, Electrical and Accessories
- a.) Refrigerant piping preferably TYPE-L, hard drawn seamless copper using the standard pipe size recommended by the manufacturer
 - b.) All piping shall be leak tested with pressure of at least 1.5 times the designated working pressure;
 - c.) Copper elbow - long radius, wrap refrigerant pipes with polyethylene tape;
 - d.) Provide NEMA Type, UL listed bolt-on circuit breakers for FCU/ACCU;
 - e.) Use PVC or liquid tight flexible conduit for electrical pipes, use PVC or liquid tight-fitting connections and stranded THWN/THHN wires feeder lines
 - f.) Use color blue, schedule 40 PVC pipe for drain lines using the appropriate size recommended by the manufacturer, but not less than 1 inch in diameter;
 - g.) Re-use / Rehab condensate drain lines, and replace if necessary.

Materials (Copper piping installation and insulations, welding job and other incidental material/s)

- "a.) To supply and install the manufacturer's refrigerant piping system including necessary insulation, hangers and supports. "
- "b.) The winning supplier shall provide 1 (one) water drain pump for each air-conditioning unit procured, ensuring a corresponding pump for each unit and a warranty of six (6) months."
- c.) The winning supplier shall provide PVC Cladding for copper piping of split type inverter airconditioning unit (Cabinet Type)

Maintenance and Support

- "a.) During the warranty period, the winning bidder shall provide highly technical personnel to service all the air-conditioning units; including its compressor, components/peripherals whenever hardware and/or any related problem occur;"
- b.) The winning supplier will conduct a (1) one-year free cleaning service on a quarterly basis for air-conditioning units to be installed
- c.) Winning supplier must have a local service center;
- d.) On call support should be available every working day;
- e.) On hardware repair, testing shall be done on-site to know the extent of the problem;
- f.) The winning bidder must shoulder all expenses of the technician/s who will be providing the technical services on-site during the warranty period.

Scope of Works:

- 1. Mobilization of Manpower, Complete tools and Equipment
- 2. Installation of New Airconditioning unit 2.0HP Window Type, Inverter
- 3. Testing and Commissioning of 2 Units, Window and Cabinet Type
- 4. Turnover to the authorized personnel of Valenzuela Medical Center
- 5. Final Acceptance: Submission of completion report and warranty certificate
- 6. The winning supplier must affix the EER sticker during the installation of new airconditioning units
- 7. The BPS/DTI Philippine Standard (PS) mark license of import commodity clearance (ICC) mark affixed
- 8. The winning supplier must affix the EER sticker during the installation of new air-conditioning units.
- 9. Manufacturers of the unit to be delivered should be existing in the Philippines for at least ten (10) years.
- 10. If the units are malfunctioning or inoperable, the Supplier shall provide maintenance service within seventy-two (72) hours after receipt of notification at no cost to VMC.
- "11. The winning supplier shall provide 1 (one) water drain pump for each air-conditioning unit procured, ensuring a corresponding pump for each unit and a warranty of six (6) months."

Warranty Period: Should be five (5) years on compressor and one (1) year on parts and labor with free cleaning service on a quarterly basis.

Delivery Period: 30 Calendar Days upon receive of PO and payment

***** nothing follows *****

TOTAL 200,833.34

A copy of your legal requirements (Certificate of Registration from BIR, SEC/DTI, Business/Mayor's Permit with Official Receipt, Platinum Philgeps Certificate, Tax Clearance, and Notarized Hard copy of Omnibus Sworn Statement) are also required to be submitted along with your quotation/proposal.

Other Information

Quotations may be submitted manually at the office of the BAC Secretariat, BAC Office, Valenzuela Medical Center, Padrigal St., Karuhatan, Valenzuela City., through facsimile (telefax no. 2944625) or email to vmc.bac2025@gmail.com. For any clarification, you may call Mr. Lester John Jake R. Divino at telephone no. 294-46-25 or via email at vmc.bac2025@gmail.com.

Created by LESTER JOHN JAKE R DIVINO

Date Created 03/11/2025

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.