



Republic of the Philippines  
Department of Health  
Metro Manila Center for Health Development  
**VALENZUELA MEDICAL CENTER**



**BIDS AND AWARDS COMMITTEE**

February 25, 2025

**NOTICE OF AWARD**

1 LOT COMPLETE SUPPLY OF LABOR, TOOLS, AND EQUIPMENT FOR THE REWINDING OF FIRE PUMP OF VMC,  
MOTORPOOL BUILDING  
BAC RESO NO. 2025-072 dated February 18, 2025

**MR. ROBERT EMMANUEL B. AMOJILAR**

Sales Engineer

**THE SENTINEL AUTOMATION AND SECURITY SOLUTIONS INC.**

1089 KAREN AVENUE HEN. T. DE LEON 1442

CITY OF VALENZUELA NCR, THIRD DISTRICT PHILIPPINES

Phone No.: 09985512617/09985512618

Email: [sales.sentinel@outlook.ph](mailto:sales.sentinel@outlook.ph)/[engineering@thesentinelautomation.com](mailto:engineering@thesentinelautomation.com)/  
[sales@thesentinelautomation.com](mailto:sales@thesentinelautomation.com)

Dear Mr. Amojilar:

Please be notified that the result of the Negotiated Procurement through *Small Value Procurement* for the  
**1 LOT COMPLETE SUPPLY OF LABOR, TOOLS, AND EQUIPMENT FOR THE REWINDING OF FIRE PUMP OF**  
**VMC, MOTORPOOL BUILDING** under PR No. 25-02-166, is hereby awarded to you as the lowest quotation  
with a contract amount equivalent to **ONE HUNDRED FIFTY THOUSAND EIGHTY PESOS (₱ 150,080.00);**

Item No.	QTY	UNIT	ITEM / DESCRIPTION	UNIT COST	TOTAL AMOUNT
			Complete Supply of Labor, Tools and Equipment for the Rewinding of Fire Pump of Valenzuela Medical Center - MOTORPOOL BUILDING		
1	1	LOT	REWINDING OF FIRE PUMP MOTOR	150,080.00	150,080.00
			Specifications:		
			Pump Model: XA65/16-S30		
			Capacity: 30HP, 500GPM, 60psi		
			Voltage: 380/220V		
			Current: 34.7/59.9Ampere		
			Frequency: 60Hz, 3Phase		
			Weight: 135Kg		
			Speed: 3500RPM		
			Scope of Works:		
			1. Coordination with end-user prior to pull out the motor.		
			2. Dismantling of the unit.		
			3. Conduct Initial Static Instrumentation Test:		
			- Insulation Resistance Test		
			- Winding Resistance Test		

"PHIC Accredited Healthcare Provider"  
"Valenzuela Medical Center...Where your health matters most"



Address: Padrigal St., Karuhatan, Valenzuela City, 1441  
Telephone Nos: 8294-6711 to 17  
Director's Office Direct Line: 8291-4259  
Email Address: [valgen\\_hosp@yahoo.com](mailto:valgen_hosp@yahoo.com)  
Website: <https://vmc.doh.gov.ph/>




Republic of the Philippines  
Department of Health  
Metro Manila Center for Health Development  
**VALENZUELA MEDICAL CENTER**




		4. Removal of burnt-out windings and note original winding data and size of wires.		
		5. Evaluate and note the cause of burnt-out winding.		
		6. Evaluate mechanical problem arise during the course of implementation.		
		7. Cleaning of slots.		
		8. Check and conduct hot core test to check the hot spots.		
		9. Apply Red varnish to the stator core.		
		10. Insertion of new winding according to its original winding data.		
		11. Oven bake to cure moisture and monitor insulation before varnishing.		
		12. Oven bake to cure varnished.		
		13. Clean and scrape out exist varnished.		
		14. Replacement of bearing.		
		15. Assemble the unit.		
		16. Conduct final static instrumentation Test:		
		- Insulation Resistance Test		
		- Winding Resistance Test		
		18. Prepare reports prior to delivery.		
		19. Coordination with the end-user for the delivery schedule.		
		20. Deliver the unit.		
		21. Installation of the Existing Fire Pump		
		22. Conduct Testing and Commissioning		
		23. Turnover to the authorized personnel		
		24. Final Acceptance: Submission of completion report		
		Delivery: 30 working days upon receive of JO		
		Warranty: Three (3) months on supplies and labor		
		Duration of Work: One (1) week		
		***** nothing follows *****		
			<b>TOTAL:</b>	<b>150,080.00</b>

The Valenzuela Medical Center reserves the right to withdraw / terminate this Notice of Award in view of non-delivery on the time specified, delivery of items of poor quality / substandard and any other violation of the terms and conditions provided in the Notice of Award.

Approved by:

 **MAR 03 2025**  
**EDILBERTO V. CAVANEYRO, MD, MHA, FPCS, FPSGS**  
OIC - Medical Center Chief II

Conformed:



Authorized Representative  
**THE SENTINEL AUTOMATION AND SECURITY SOLUTIONS INC.**  
Company

Date: \_\_\_\_\_

/J.D.

"PHHC Accredited Healthcare Provider"  
"Valenzuela Medical Center...Where your health matters most"



Address: Padrigal St., Karuhatan, Valenzuela City, 1441  
Telephone Nos: 8294-6711 to 17  
Director's Office Direct Line: 8291-4259  
Email Address: valgen\_hosp@yahoo.com  
Website: <https://vmc.doh.gov.ph/>