



Republic of the Philippines
Department of Health
Metro Manila Center for Health Development
VALENZUELA MEDICAL CENTER



BIDS AND AWARDS COMMITTEE

February 07, 2025

NOTICE OF AWARD

COMPLETE SUPPLY, LABOR, TOOLS AND EQUIPMENT FOR
FIRE DETECTION AND ALARM SYSTEM OF VMC - IDS BUILDING
BAC RESO NO. 2025-049 dated January 28, 2025

MR. ROBERT AMOJILAR

Sales Engineer

THE SENTINEL AUTOMATION AND SECURITY SOLUTIONS INC.

1089 KAREN AVENUE HEN. T. DE LEON 1442

CITY OF VALENZUELA NCR, THIRD DISTRICT PHILIPPINES

Phone No.: 09985512617/09985512618

Email: sales.sentinel@outlook.ph/engineering@thesentinelautomation.com/
sales@thesentinelautomation.com

Dear Mr. Amojilar:

Please be notified that the result of the Negotiated Procurement through *Small Value Procurement* for the **COMPLETE SUPPLY, LABOR, TOOLS AND EQUIPMENT FOR FIRE DETECTION AND ALARM SYSTEM OF VMC - IDS BUILDING** under PR No. 25-01-051, is hereby awarded to you as the lowest quotation with a contract amount equivalent to **ONE HUNDRED TWENTY-EIGHT THOUSAND EIGHT HUNDRED PESOS ONLY (P128,800.00)**;

Item No.	QTY	UNIT	ITEM / DESCRIPTION	UNIT COST	TOTAL AMOUNT
			Complete Supply, Labor, Tools and Equipment of Smoke Detector for Fire Detection and Alarm System of Valenzuela Medical Center - IDS BUILDING		
1	25	PC	SMOKE DETECTOR	5,152.00	128,800.00
			Specifications: Voltage Range: 12-30V DC Standby Current: 35µA Alarm Current @24V DC 470Ω: 30mA Ambient Temperature: -10°C ~ +55°C Material: Fire Proof Plastic Dimensions: 102mmØ x 49mmØ Weight: range to 150-157 grams Color: White Scope of Works: 1. Mobilization of Manpower, Tools and Equipment 2. Dismantling of Non-Compatible Smoke Detector 3. Installation of New Smoke Detector 4. Testing and Commissioning		

"PHIC Accredited Healthcare Provider"
"Valenzuela Medical Center...Where your health matters most"



Address: Padrigal St., Karuhatan, Valenzuela City, 1441
Telephone Nos: 8294-6711 to 17
Director's Office Direct Line: 8291-4259
Email Address: valgen_hosp@yahoo.com
Website: https://vmc.doh.gov.ph/

