



**Republic of the Philippines  
Department of Health  
Metro Manila Center for Health Development  
VALENZUELA MEDICAL CENTER**



**REQUEST FOR QUOTATION**

**PR NO. 25-10-1562**

November 05, 2025

The Valenzuela Medical Center (VMC) through its **Bids and Awards Committee (BAC)** intends to procure the **"QUARTERLY PREVENTIVE MAINTENANCE SERVICE OF FIRE DETECTION AND ALARM SYSTEM OF VMC-IDS & MOTORPOOL BUILDING FOR CY 2026"** for the **ENGINEERING AND FACILITIES MANAGEMENT SECTION** in accordance with Section 34.1 (Small Value Procurement) of the Implementing Rules and regulations of the Republic Act No. 12009.

Please send your **price offer** for the items listed below duly signed by you or your authorized representative not later than November 10, 2025 10:00am. The BAC reserves the right to accept, reject & waive defects in the canvass.

ITEM NO.	QTY	UOM	ITEM DESCRIPTION	UNIT COST	TOTAL COST
			<b>Early Procurement Activities for CY 2026</b>		
1.	4	Quarterly	<b>Quarterly Preventive Maintenance Service of Fire Detection and Alarm System of VMC - IDS &amp; MOTORPOOL BUILDING</b>	<b>46,766.67</b>	<b>187,066.68</b>
			<b>Scope of Works:</b>		
			A. The service provider shall furnish all tools, labor and supervision necessary for the Preventive Maintenance of Fire Detection and Alarm System (FDAS) at VALENZUELA MEDICAL CENTER - IDS & MOTORPOOL BUILDING All works shall include but not limited to the following:		
			1. Check connectivity of wiring/system, functionality tests of all devices		
			2. Initiating Devices: Inspection and Cleaning of Smoke Detectors, Heat Detectors, Supervisory Devices, Waterflow Devices, Manual Pull Station		
			3. Check-up and cleaning of Fire Alarm Bell. & Push Button/Horn/Strobe Light. Wipe out, Chemical contact cleaner, Air blower, Vacuum Cleaning		
			4. Check-up and cleaning Fire Alarm Control Panel		
			5. Inspection of Fuse Terminals and Primary Power Supply		
			6. Inspection of Panel trouble signal LED's and Lamps		
			7. Inspection of battery (Swelling or Loose Connection)		
			8. Test battery-load voltage.		
			9. Test and inspection of panel functionality, LED's, Fuses and other components.		
			10. Tightening screw connection and terminal lugs.		
			11. Testing and commissioning.		

*"PHIC Accredited Healthcare Provider"*

*"Valenzuela Medical Center...Where your health matters most"*



Address: Padrigal St., Karuhatan, Valenzuela City, 1441  
Telephone Nos: 8294-6711 to 17  
Director's Office Direct Line: 8291-4259  
Email Address: valgen\_hosp@yahoo.com  
Website: <https://vmc.doh.gov.ph/>