



Philippine Government Electronic Procurement System

Central Portal for
Philippine Government
Procurement Opportunities

Help

Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 11996599
Procuring Entity VALENZUELA MEDICAL CENTER
Title 4 UNIT AIRCONDITIONING UNIT, WINDOW TYPE 2.5HP @ 80,760.00
Area of Delivery Metro Manila

Solicitation Number:	VMC-2025-142	Status	Active
Trade Agreement:	Implementing Rules and Regulations		
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Associated Components	1
Classification:	Goods	Bid Supplements	0
Category:	Airconditioning and Airconditioning Systems		
Approved Budget for the Contract:	PHP 323,040.00	Document Request List	1
Delivery Period:	30 Day/s		
Client Agency:		Date Published	29/04/2025
Contact Person:	LESTER JOHN JAKE R DIVINO BAC SECRETARIAT Padrigal St., Karuhatan, Valenzuela City Metro Manila Philippines 63-2-2920604 vmc_bac@yahoo.com	Last Updated / Time	28/04/2025 17:03 PM
		Closing Date / Time	02/05/2025 10:00 AM

Description

UNIT ITEM DESCRIPTION QTY. UNIT COST TOTAL COST

Supply, Delivery, Installation, Testing and Commissioning of Inverter Airconditioning Unit of Valenzuela Medical Center - 4th Floor Surgery Ward -

- unit Air-Conditioning Unit, Window Type 2.5HP, Inverter Type -

Specifications: -

Fan Coil Application Type: Window Type -

Cooling Capacity (minimum): 23,400 - 24,120 KJ/h -

Energy Efficient Ratio (minimum) DOE Certification at least 3 - 4 Star: 11.2 - 12.0 KJ/W-hr -

Power Supply: 220-240V, 60 Hz (will work with Philippine Electrical System) -

Phase: Single Phase -

System Power Input, max: 2,010 - 2,160 W -

Sound Pressure Level (indoor): max: 52 - 57 db(A) -

Compressor Type: Scroll/Rotary -

Refrigerant: R410A/R32 -

Controls: Wireless remote control with built-in timer, temperature control -

Air-Filter: Washable -

-

Scope of Work: -

1. Mobilization of Manpower, Complete Tools and Equipment -

2. Installation of New Airconditioning unit 2.5HP Window Type, Inverter -

3. Testing and Commissioning of 4 Units procured -

4. Turnover to the authorized personnel of Valenzuela Medical Center -

5. Final Acceptance: submission of completion report and warranty certificate -

6. The winning supplier must affix the EER sticker during the installation of new air-conditioning units -

7. The BPS/DTI Philippine Standard (PS) mark license of import commodity clearance (ICC) mark affixed -
8. Manufacturers of the unit to be delivered should be existing in the Philippines for at least ten (10) years. -
9.If the units are malfunctioning or inoperable, the Supplier shall provide maintenance service within seventy-two (72) hours after receipt of notification at no cost to VMC -
Warranty Period: Shoudn be five (5) years on compressor and one (1) year on parts and labor with free cleaning service on a quarterly basis. -
Delivery Period: 30 Calendar Days upon receive of PO and payment -

A copy of your UPDATED legal requirements (Certificate of Registration from BIR, SEC/DTI, Business/Mayor's Permit with Official Receipt, PhilGEPS Certificate, Tax Clearance, Audited FS with 2023 ITR or latest, and Omnibus Sworn Statement) is also required to be submitted along with your quotation/proposal

Other Information
Quotations may be submitted manually at the office of the BAC Secretariat, BAC Office, Valenzuela Medical Center, Padrigal St., Karuhatan, Valenzuela City., through email to vmc_bac@yahoo.com. For any clarification, you may call Lester John Jake R. Divino at telephone no. 294-46-25 or via email at vmc_bac@yahoo.com.

Created by LESTER JOHN JAKE R DIVINO
Date Created 28/04/2025

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.