



**Republic of the Philippines**  
**Department of Health**  
**Metro Manila Center for Health Development**  
**VALENZUELA MEDICAL CENTER**



			<ul style="list-style-type: none"> <li>- Look for signs of damage: Inspect for tears, holes, or any other physical damage to the filter material.</li> <li>- Cleaning and Decontamination of HEPA Filter chamber/box</li> <li>- Replacement of HEPA Filter</li> </ul>		
			<b>Semi-Annual Preventive Maintenance of Exhaust Blowers</b>		
			<p>Check and Inspect:</p> <ul style="list-style-type: none"> <li>- Fan Blades: Check for damage, cracks, or excessive wear.</li> <li>- Motor: Inspect for signs of overheating, loose connections or unusual noises.</li> <li>- Belts: Check for wear, cracks, or slippage.</li> <li>- Bearings: Inspect for excessive wear or play</li> <li>- Mounting hardware: Ensure all bolts and fasteners are tight.</li> <li>- Ductwork: Check for leaks, damage, or loose connection.</li> <li>- Electrical connections: Inspect for loose or corroded connections.</li> <li>- Lubrication: Lubricate moving parts (e.g., bearings, shafts) as recommended by the manufacturer</li> </ul> <p>Testing and Balancing:</p> <ul style="list-style-type: none"> <li>- Check Air flow measurement</li> <li>- Check Air Balancing</li> <li>- Check Air Change Computation</li> <li>- Check Room Pressure Testing</li> <li>- Submission of Testing and Balance Report</li> </ul>		
			*The preventive maintenance shall be conducted by competent and experienced personnel.		
			*Availability: Ensure 24/7 standby support for emergency repairs; service charges shall be incurred only when corrective actions are required due to failure or damage of major system components specifically in cases of mechanical or electrical failure.		
			*Service Provider shall advise the end-user all defective and worn-out parts to be replaced.		
			*Submit PM and Service Report signed by Supervisor		
			***** nothing follows *****		
				<b>TOTAL:</b>	<b>420,000.00</b>

The Valenzuela Medical Center reserves the right to withdraw / terminate this Notice of Award in view of non-delivery on the time specified, delivery of items of poor quality / substandard and any other violation of the terms and conditions provided in the Notice of Award.

*"PHIC Accredited Healthcare Provider"*  
*"Valenzuela Medical Center...Where your health matters most"*



Address: Padrigal St., Karuhatan, Valenzuela City, 1441  
Telephone Nos: 8294-6711 to 17  
Director's Office Direct Line: 8291-4259  
Email Address: valgen\_hosp@yahoo.com  
Website: <https://vmc.doh.gov.ph/>



Republic of the Philippines  
Department of Health  
Metro Manila Center for Health Development  
**VALENZUELA MEDICAL CENTER**



Approved by:

MAY 30 2025

**EDILBERTO V. CAVANEYRO, MD, MHA, FPCGS, FPSGS**  
OIC - Medical Center Chief II


Conformed:

Authorized Representative  
**BOUYANT INDUSTRIAL SYSTEMS, INC.**  
Company

Date: \_\_\_\_\_

/ D.P.

Emailed  
6/2/25 /h



"PHIC Accredited Healthcare Provider"  
"Valenzuela Medical Center...Where your health matters most"



Address: Padrigal St., Karuhatan, Valenzuela City, 1441  
Telephone Nos: 8294-6711 to 17  
Director's Office Direct Line: 8291-4259  
Email Address: valgen\_hosp@yahoo.com  
Website: <https://vmc.doh.gov.ph/>