



PhilGEPS

Philippine Government Electronic Procurement System

Central Portal for
Philippine Government
Procurement Opportunities

[Help](#)

Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 11365284
Procuring Entity VALENZUELA MEDICAL CENTER
Title QUARTERLY PREVENTIVE MAINTENANCE SERVICE OF FIRE DETECTION AND ALARM SYSTEM AT VALENZUELA MEDICAL CENTER - HOSPITAL BUILDING FOR CY 2025
Area of Delivery Metro Manila

Solicitation Number:	VMC 2024-199	Status	Pending
Trade Agreement:	Implementing Rules and Regulations		
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Associated Components	1
Classification:	Goods	Bid Supplements	0
Category:	Fire Fighting & Rescue and Safety Equipment	Document Request List	0
Approved Budget for the Contract:	PHP 168,000.00	Date Published	16/10/2024
Delivery Period:	30 Day/s		
Client Agency:		Last Updated / Time	15/10/2024 16:51 PM
Contact Person:	LESTER JOHN JAKE R DIVINO BAC SECRETARIAT Padrigal St., Karuhatan, Valenzuela City Metro Manila Philippines 63-2-2920604 vmc_bac@yahoo.com	Closing Date / Time	21/10/2024 10:00 AM

Description

STOCK/ PROPERTY NO. UNIT ITEM DESCRIPTION QTY. UNIT COST TOTAL COST

Quarterly Quarterly Preventive Maintenance Service of Fire Detection and Alarm System at Valenzuela Medical Center - 4 42,000.00 168,000.00
Hospital Building

Scope of Work:

A. The service provider shall furnish all tools, labor and supervision necessary for the preventive maintenance of fire detection and alarm system (FDAS) at Valenzuela Medical Center - Hospital Building
All works shall include but not limited to the following:

1. Check connectivity of wiring/system, functionality tests of all devices
2. Initiating Devices: Inspection and Cleaning of Smoke Detectors, Heat Detectors, Supervisory Devices, Waterflow Devices, Manual Pull Station
3. Check-up and cleaning of Fire Alarm Bell. & Push Button/Horn/Strobe Light. Wipe out, Chemical contact cleaner, Air blower, Vacuum Cleaning
4. Check-up and cleaning Fire Alarm Control Panel
5. Inspection of Fuse Terminals and Primary Power Supply
6. Inspection of Panel trouble signal LED's and Lamps
7. Inspection of battery (Swelling or Loose Connection)
8. Test battery-load voltage.
9. Test and inspection of panel functionality, LED's, Fuses and other components.
10. Tightening screw connection and terminal lugs
11. Testing and commissioning.

B. Recommend repair and replacement of all parts of FDAS (if necessary)

NOTES:

- 168,000.00

Other Information

Quotations may be submitted manually at the office of the BAC Secretariat, BAC Office, Valenzuela Medical Center, Padrigal St., Karuhatan, Valenzuela City., through email to vmc_bac@yahoo.com. For any clarification, you may call Lester John Jake R. Divino at telephone no. 294-46-25 or via email at vmc_bac@yahoo.com

Created by LESTER JOHN JAKE R DIVINO

Date Created 15/10/2024

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.