Outage minutes rose because customers lost power more often, not because outages lasted longer

Print test of the brief's type scale: lede 13 pt Semilight, body 10.5 pt, small 8.5 pt, hero figures 40 pt Light. Figures below are the repo's verified 2023→2025 EIA-861 values.

+17%

SAIDI ex-MED, 123.3 → 144.4 minutes per customer

+13%


SAIFI ex-MED, 1.165 → 1.320 interruptions per customer

+3%

CAIDI ex-MED, 105.9 → 109.4 minutes per interruption


Body text at 10.5 pt

Dominion reported that its rolling three-year average SAIDI rose from about 130 minutes (2022–2024) to 133 minutes (2023–2025), excluding major event days. These are overlapping rolling averages, not two separate periods. The public EIA-861 data shows the same direction and lets you split the change into frequency and duration: SAIDI = SAIFI × CAIDI, so ln(SAIDI ratio) = ln(SAIFI ratio) + ln(CAIDI ratio).



SAIFI ex-MED, Dominion Energy Virginia, 2015–2025. Labels on 2019, 2023 and 2025 only. Source: EIA-861 (2025 final), PUDL 2015–2024; data/output/storm_vs_saidi.csv.

Pipeline diagram (drawn, not written)



Sequential ramp, light to dark (greyscale proof must read in order)



#EAF3FE #C9E0FE #AACAF4 #86B1E8 #6298DC #3C7ECF #0A66C2 #00519F #013C78

Measure	2023	2025	Change	What it means
SAIDI ex-MED	123.3	144.4	+17%	outage minutes per customer per year
SAIFI ex-MED	1.165	1.320	+13%	interruptions per customer per year
CAIDI ex-MED	105.9	109.4	+3%	minutes per interruption

> A placeholder the candidate fills in looks like this: [you: start date].

Second page: running footer and page counter

Small text at 8.5 pt for captions and source lines. Curly quotes “like this”, an ellipsis … and a non-breaking space in 26,000 MW.