CALIBRATION CERTIFICATE

PUPUK KUJANG

Issued By: DPLI

PS-PK-WASES-03

Certificate No. Address 2

U.U.T Information

ID: LT-703
Description: Flow Transmitter
Model: Rosemount 3051CD2A
Serial Number: 01220880
Location:Workshop

Procedure Information

Procedure:LT-703
Input Range:0.000 to 106.600mbar
Output Range:4.000 to 20.000mA
Reject Error >:0.10% of Span

Calibration Information

Calibration Date : 11 August 2026
Due Date: 10 August 2027 (52wks)
Temperature: 22.0°C ±4°C
Relative Humidity: 50% RH ±10% RH

Comments:

Calibrator Information

Description	Serial No.	Cert No.	Cal Date	Cal Due
8060 Measure Mode	1129K25	50-35148	21 Nov 2025	20 Nov 2026
8030 Pressure Calibrator	254352591	R251120-1	20 Nov 2025	19 Nov 2026

Results:

Test Point	Input Pressure	Nominal Output	Actual Output	U.U.T Spec.	Error % of Span	Pass/Fail
0%	0.000 mbar	4.0000 mA	3.996 mA	± 0.016 mA	-0.025 %	Pass
25%	26.650 mbar	8.0000 mA	7.998 mA	± 0.016 mA	-0.0125 %	Pass
50%	53.290 mbar	11.9985 mA	11.988 mA	± 0.016 mA	-0.06563 %	Pass
75%	79.940 mbar	15.9985 mA	15.984 mA	± 0.016 mA	-0.09062 %	Pass
100%	106.600 mbar	20.0000 mA	19.986 mA	± 0.016 mA	-0.0875 %	Pass

End Of Results

Comments:

Calibrated by: Technician

Approved By:

Approved Date:

AVP Signed: _____

This certificate has been produced by EasyCal Calibration Software from Time Electronics Ltd