

DATACENTER

Most IT infra H/W, except end user devices is hosted in datacenter.

Datacenters provides power supply, cooling & fire prevention, equipment racks

Datacenter Building Blocks

* Datacenter Categories

- sub equipment room / patch closet: contain patch panels for connections to wall outlets in offices, & small eq like r/w switches
- main equipment room: small datacenter in office
- Org. owned datacenter: main central IT eq
- Multi-tenant datacenter: used by service providers for multiple organizations

* Datacenter Location

- Environment:
 - * Enough space to expand the datacenter
 - * Floods / Hurricane / Earthquake / fireworks storage / waste dump / climate / chemical plant (should be low ambient with low fluctuations)
 - * Crime Rate (vandalism) near Airport (crashes)
 - * Easily reached in emergencies? Close to maint. staff

- Utilities:
 - * 2 independent power providers & Internet providers?
 - * cheap power? renewable power? / Enough power? Reliable?
 - * Cabling routes to the building & inside it determined?
 - * Is present in shared building? How reliable is other users?

- Foreign Countries:
 - * country reachable at all times?
 - * corruption? / politically stable? / legal status of data?

* Physical Structure

- Floors: Must be able to carry $1500 - 2000 \text{ kg/m}^2$.

- * Raised floors: metal frameworks carrying tiles, height 40-120 cm.

Disadvantage:

expensive, height decreased, doors & eq loading slope
Fire can easily spread hard to install

- walls, windows, floors doors

walls: Firewall, fire rating


windows: not desired, if present, should be shatterproof, translucent

Floors: min 1m x min 2.1m, resist forced entry, fire rating

(eq brought in easily), Emergency exits clearly marked, monitored, alarmed

- Water & Gas Pipes: No leakage

- Layout:



Storage of spare material

* Power Supply (kW - mW)
calculated in W/m^2 . Normal density data: $\rightarrow 2-6 \text{ W/m}^2$
high $\rightarrow 10-20 \text{ W/m}^2$

UPS (Uninterruptible Power Supply)

Issues with power supply:

- \rightarrow Blackout (total loss of power) \rightarrow Surge (A period of high V)
- \rightarrow Spike (instant jump) \rightarrow Brownout (voltage drop)
- \rightarrow waveform issues

UPS provides high quality electrical power in emergency, & filters the power
UPS Installⁿ consists of filters, diesel power generator, batteries & flywheel sys

\rightarrow Power generators

0.5 - 2 MW Power, diesel should be refilled regularly, low calorific value

Testing regularly: \rightarrow Test working of generator
 \rightarrow Old diesel is used up
 \rightarrow Use power gen at peak time

\rightarrow Battery powered UPS

Batteries last 5-15 minutes, power generator must be started during this period.

3 types -

- ① standby UPS / off-line systems: used in small setups, provides AC power from battery using electronic inverter
- ② Line Interactive UPS: uses transformer in bfm, works as filter for many power issues, provides AC
- ③ Double Conversion UPS: Convert AC to DC, then back to High Qual. AC using an Inverter. Hence power to IT systems is local & free of power issues. Provides AC from DC batteries, which eliminates switch over moments & avoids AC power phase changes.

\rightarrow Flywheel UPS


Utility grid to motor rotating a flywheel generating electricity
10-20 sec, 50K-55K rotations/minute.

\rightarrow UPS maintenance

- \rightarrow Batteries: Every 3-5 years \rightarrow Flywheel \rightarrow regular bearing suppl. upto 30 yrs.
- \rightarrow Power generator: preheated, monthly testing

\rightarrow Power distribution

2 types of PDUs: \rightarrow floor mounted
 \rightarrow power strips, rack PDUs, feed the rack
usually redundancy of 2 power supp in comp, 2 power strips.



SECURITY

(UNIT-5)

Combination of availability, confidentiality & integrity focused on the recognition & resistance of attacks.

various reasons for committing crime against IT:

- personal exposure & prestige
- financial, damaging org, terrorism, warfare

Risk Management

Process of determining an acceptable level of risk, assessing the current level of risk, taking steps to reduce risk to acceptable level, & maintaining that level.

A risk list used to quantify risks, compiled in Bus Imp. Analysis (BIA) workshop, containing:

- Asset name: component that needs to be protected
- Vulnerability: a weakness, process or physical exposure that makes asset susceptible to exploits
- Exploit: a way to use vulnerabilities to attack an asset
- Probability: estimate of likelihood of occurrence of an exploit
- Impact: Severity of damage when vulnerability is exploited
- Risk = $P \times I$

* Controls mitigate these risks

AVE	PIR

→ Risk Response

- Acceptance of risk: Risk is unlikely & cost of mitigation is high
- Avoidance
- Transfer
- Mitigation of risk:

- Design for minimum risk
- Incorporate * safety devices * warning devices
- Implement training procedures: mitigate people bound risks
- (Firewalls, Hardened screen routers, P same but I ↓)
- (intrusion detection system, warn for unusual sitⁿ)

→ Exploits

- * Key loggers installed (steal password)
- * Disposed PCs/disk in wrong h.
- * Data on backup tapes outside building in wrong h.
- * Corrupt/dissatisfied staff
- * M/N sniffers
- * End users led to malicious websites stealing info (Phishing)

→ Security controls

Three core goals of security: CIA

→ Confidentiality: prevent unauthorized disclosure of data

→ Integrity: ensures-

- * No modification on data by unauth staff or pr.
- * Unauth mod to data not by auth staff or pr.
- * Data is consistent

* controls based on risk lists & CIA classification

→ Availability: reliable & timely access to data or resources by staff.

cl
mines what level of CIA needed)

→ Attack Vectors

②

Attacks on infra can be executed using:

⇒ Malicious code: Apps, when executed can cause n/w or server overload, steal data = passwords, or erase data

multiple forms:

→ Worms: self replicating programs that spread from one comp to another

→ Viruses: program fragment that attaches itself to a program or file, spreading & leaving infections

→ Trojan horse: appears to be legit files from legit src, hence receives tricked to start them, & then they deliver viruses or worms

- * Detecting viruses is done using virus signature, a unique string of bits that identifies a part of the virus.
- * Heuristic scanning is also used, which looks for certain instructions or commands within a program that are not found in typical applications. This way viruses can be scanned even before their signature is known to the anti virus s/w vendor.

⇒ Denial of service Attack: attempt to overload an infra to cause disruption of a service. Attacker fires a large no. of malformed req. Usually one computer alone has insuff. power or bandwidth, distributed DOS attack is used.

Prevention:

- ⇒ split business & public resources
- ⇒ move public facing resources to external cloud provider
- ⇒ setup automatic stability
- ⇒ lower Time to live of DNS records to reroute traffic to other servers on attack.

Measures on a ddos attack:

- ⇒ Inform ISP & ask for help
- ⇒ Run script to terminate connects from same source if > 10
- ⇒ change to an alternative server
- ⇒ Reroute or drop suspected traffic

CDN can take mitigating actions.

⇒ Social engineering: using social skills to manipulate people to obtain info.

⇒ Phishing: email redirecting to seeming legit website asking everything

⇒ Baiting: uses physical media, like USB flash drive, & relies on the curiosity of people to find what is on it.
To mitigate, disable 'auto-run' feature on all org PCs.

* Cooling

Two types of cooling systems:

- CRAC: Computer Room ACS: refrigerant based unit connected to outside condensing unit
- CRAH: Air Handlers: chilled water based & connected to outside chillers.

Metrics for efficiency of cooling sys:


→ EER: eff at max air conditioning load = $\frac{\text{O/P cooling (in BTU) per hr}}{\text{EE I/P in Watts}}$

→ SEER: Seasonal EER, seasonal data is used for measurement (time & year cooling sys is most used)

→ COP: $\frac{\text{cooling load (kW)}}{\text{EE I/P (kW)}} \quad (3-10)$

→ Operating Temp (18-27°C)

→ Airflow: An optimized airflow eliminates hotspots & hence less cooling can do.



→ Humidity & Dust:

- * Dust should be minimized
- * Humidity should be 40-60%

Dry air can cause Electro-static Discharge of 1000s V in ICs.

Humid air can cause corrosion in printed boards tape disks can get mechanical problems.

* Fire prevention, detection, suppression

Fire can spread quickly because of air flow & raised floors.

Four levels in suppressing fire:

→ Fire prevention

- + Avoid cable spaghetti
- + not overloading fans

→ Passive fire protection

- + install fire resistant walls
- + use fire entry pts should be fire res. mat (cables, air ducts, coolant tubes)

→ Fire detection

- + smoke det
- + heat det
- + flame det
- + alarm
- + switch off

→ Fire suppress

- Fire needs Heat, fuel, oxygen

* Gas in datacenter can cause 50% ↑ in pressure → break windows hence proper vent needed.

Reduce heat by water X

Replace O₂ by Halon but can dizziness Now, used Argon

Equipment Racks

Standardized metal enclosures to house IT infra comp.

Front panel: 19 inches

Height in rack units or 'U' (U = 44.5 mm) 42U generally

rack mounted servers: 1-2U

blade server enclosures: 10U