

PROJECT: 600 TPD SULPHURIC ACID PLANT

TECHNICAL SPECIFICATION OF VIBRATION SENSOR

0	8-8-2024	FOR ENQUIREY	FOR ENQUIREY PC			PC
Rev. No Date Description			Prepared	Verified	Approved	
PROJECT		600 TPD SULPH	URIC ACID	PLANT		
OWNER M/s. GSFC						
EPC CONTRACTOR M/s. ISGEC HEAVY ENGINEERING LTD				IG LTD		
DOCUMENT TITLE		TECHNICAL SP	SPECIFICATION OF VIBRATION SENSOR			
DOCUMENT NO. ES0216-83830100-		O-SPC-0015 Rev. No.: 00				
	DOC. NO.	-	No. of Pages: 11			
ject: 600 T	TPD SULPHU	RIC ACID PLANT	<u>-</u>	Project IE	9: ES0216	Page
epared by: PC		Verified by: PC		Approved by: PC		

TECHNICAL SPECIFICATION OF VIBRATION SENSOR Document ID 600 TPD SULPHURIC ACID PLANT Revision: 00 Item Code Description VIBRATION SENSOR Date: 07-08-2024

Noted. For Import portion TC's shall be submitted and for indian portion inspection shall be carried out as per mutually agreed QAP.

1.1 **SCOPE OF SUPPLY:**

1.1.1 The Scope Of Supply Shall Include Design, Manufacturer, Testing And Inspection At Manufacturer's Works, Packing And Forwarding, Transportation & Delivery Of Vibration sensor.

Noted However,Loop powered sensors has inbuilt transmitters.

- 1.1.2 Supply of Looped Power Vibration Sensors (2Wire, 4-20 mA) Transmitter, Mounting Pad (SS-304) with Extension Cables (15 Meter), Metallic Flexible Conduits, SS-304 Junction Box.
- 1.1.3 Junction Box shall be with Double Compressed Brass Nickel Plated Cable Gland of suitable size for all Incoming & Main Out going Cable. Noted.
- 1.2 BILL OF QUANTITIES

Noted.

Bill of Quantities to be supplied:

- Nos. Of Vibration Sensors: 12 No's + 2 Spare(Total- 14 Nos)
- Mounting Pad for Vibration Sensor :12
- Junction Box: 3 No's
- 2.0 TERMINAL POINTS:

Noted.

Mounting Pad to Sensor, Sensor to JB: Vendor Scope

JB to DCS: ISGEC Scope

3.0 <u>TEST AND INSPECTION</u>:

Noted. It shall be as per mutually agreed QAP.

The supplier shall provide inspection to establish and maintain the quality of workmanship to ensure accuracy and reliability of each component, instruments, used to integrate as VMS System. The supplier shall submit test certificates carried out for meeting the technical requirement for purchase, for review and approval before dispatch/inspection of the panel/instruments.

4.0 DOCUMENTS TO BE SUBMITTED WITH THE OFFER

a. GA Drawing & Bill of Material

- b. Typical Scheme for Offered System
- c. Technical Catalogue All Items
- d. Deviation list, if any, on a Separate Deviation Schedule
- 5.0 DRAWINGS/DOCUMENTS TO BE SUBMITTED AFTER AWARD OF CONTRACT

Noted

Noted. However,GAD shall be submitted post order

confirmation.

Project: 600 TPD SULPHURIC ACID PLANT		Project ID: ES0216	Page
Prepared by: PC	Verified by: PC	Approved by: PC	

ISGEC	TECHNICAL SPECIFICATION OF VIBRATION SENSOR	
Document ID	600 TPD SULPHURIC ACID PLANT	Revision: 00
Item Code		
Description	VIBRATION SENSOR	Date: 07-08-2024

a.	Technical Data Sheets - For Approval	Within 07 Days from Date of LOI/PO
b.	JB GA/ IA Drawing, Termination Details, Bill of Material with Make & Model Nos. Details - For Approval.	Within 07 Days from Date of LOI/PO
c.	Quality Assurance Plan - For Review	Within 07 Days from Date of LOI/PO
d.	Test Certificates for Review & Approval	15 Days Before Dispatch
e.	Operation & Maintenance manuals: 6 Sets of the System to be submitted to purchaser's work before dispatch of the system and 01 Set along with Dispatch of the Vibration Monitoring System.	15 Days Before Dispatch

8.0 TECHNICAL SPECIFICATION -

Noted. however,Offered loop powered sensor does not have integral digital display. Hence, Digital Vibration Indicator quoted separately.

2 Wire Looped Power (4-20mA) Vibration Sensors cum Transmitters with Integral Digital Display shall be offered for monitoring the Vibration levels of various Machines (HT Motorss) in BHP. The measurement of vibration levels shall be carried out on the Bearing housings (DE and NDE) of the Machines in both Horizontal & Vertical planes (X &Y planes).

There shall be hardwired data exchange from Vibration JB to DCS for display, trending in HMI (as applicable), alarming and interlocking / protection.

Sensors, JBs and extension

Sensors, JBs and extension cable till JB's offered. Further cables from JB's to PLC/ DCS shall not be by FM

-

Noted.

Vibration Monitoring Probe (Loop powered,4-20mA)

Vibration limits shall be as per applicable IS / IEC / Manufacturer's guidelines.

2) Low Noise Cable & Cable Conduit

Extension cable offered which has connector of MIL-C 2PIN TYPE.

Each sensor shall be furnished with flexible conduit and low noise cable. Conduit fittings shall be furnished for connection to sensor. The other end of the flexible conduit will be connected to a suitable junction box.

The flexible low noise cable shall not be directly terminated to the vibration sensor to avoid any damages due to vibration. A prewired plug-in type connector shall be furnished for connection of the low noise cable to the vibration sensor. Terminals shall be provided for terminating the low noise cable to the JB.

Project: 600 TPD SULPHUR	C ACID PLANT	Project ID: ES0216	Page
Prepared by: PC	Verified by: PC	Approved by: PC	

ISGEC	TECHNICAL SPECIFICATION OF VIBRATION SENSOR	
Document ID	600 TPD SULPHURIC ACID PLANT	Revision: 00
Item Code		
Description	VIBRATION SENSOR	Date: 07-08-2024

Flexible Metallic Conduit of Suitable Size & Length to be provided in accordance to accommodate Pre Feb cable.

—3) Mounting Pads

FM Std Mounting pads of size 30X30X15 offered. MOC - MS with SS insert.

All required mounting pads for mounting the vibration sensor on equipment shall have to be arranged by Supplier. The installation of sensor shall be such that removal of vibration pick-up during overhauling of the bearing will not be necessary. MOC of Mounting Pad shall be SS-304 & dimensions shall be **30x30x15 mm-4Nos and 50x50x10 mm-8 Nos**. Sensor Thread provision in Pad shall be as per Sensor Stud thread.

Wall Mounting-SS304 JB with FRP canopy offered.

Dimension - -300(H)*300(W)*200(D) mm approx....

Make: Activaa

Thickness:

1. Door - 1.6/2 mm 2. Body - 1.6/2 mm 3. Mounting Plate - 2

3. Mounting Plate - 2 mm (GI)

4. Gland Plate - 3 mm Terminals (2.5 SQMM · Screw terminals) - 15 Nos Cable entries (Bottom

Side - 3/4"ET-05 Nos) WEATHERPROOF DC

BRASS NICKEL
PLATED CABLE
GLAND WITH
CHECKNUT & PVC
HOOD

Gland Size: 3/4"ET Gland OD: 15 mm Gland QTY.(Nos.): 05 Nos.

Gasket shall be as per Manufacturer's standard.

4) Junction Box

Junction Box shall be of SS-304 with Canopy. Complete Body Shall be of 2 mm Thk. & Gland plate (removable) shall be of 3 mm Thk. Protection Class Shall be IP-65 min. JB shall be with Synthetic rubber Gasket , Key Lock, Screw Terminal (2.5 Sq. mm) , Din Rail for TB's, Cable Duct , Brass/Copper Earthing Nut & Bolt, Wall/Structure Mounting arrangement.

JB shall be with Double Compressed Brass Nickel Plate Cable & Black PVS shroud for all In & Out Cables-

5) Cable Glands

All Filed JB shall be with Cable gland & Black PVC shroud. Cable gland shall be as follow:-

Type: Double compression type conforming to BS 6121

Entry Thread : NPTMaterial : Brass

Finish: Cadmium Plated.Protection: IP 67 or better

• Size: To suit armored cable diameter

Accessories: Neoprene gasket, locknuts, reducers etc.

Project: 600 TPD SULPHUR	C ACID PLANT	Project ID: ES0216	Page
Prepared by: PC	Verified by: PC	Approved by: PC	

ISGEC	TECHNICAL SPECIFICATION OF VIBRATION SENSOR	
Document ID	600 TPD SULPHURIC ACID PLANT	Revision: 00
Item Code		
Description	VIBRATION SENSOR	Date: 07-08-2024

DATA SHEET FOR VIBRATION SENSOR cum TRANSMITTER

	Shinkawa Japan/ For	orbes	
Make	Marshall Pvt Ltd.		
Model No.	Vendor to Specify	CBT-420 series with DVI	
Display Unit	Integral Digital Displ	Dual Channel DVI offered separately. All the technical details are as per attached catalog.	
Measuring Range	0-25 MM/SEC	Noted and Confirmed. 0-25 mm/sec RMS	
	Current Output	t	
Power	+12 to +35 VDC Ir	Input @ Transmitter Terminal Supply Voltage shall be 15-30 Volts DC (for 4-20mA)	
Signal Output	2 Wire, 4 to 20 mA	Noted and confirmed. 4-20 mA DC.	
4 to 20 mA Loop Accuracy	Within ±1.5% Over	r Specified Full-Scale Range +/-10%	
Туре	Smart , HART Protoc	col without SMART,HART protocol	
Maximum Loop Resistance	hms max. *		
Current Limiting	Supply Voltage shall be 15-30 Volts DC (for 4-20mA)		
Temperature Stability	Temperature Range: -25 to 90°C		
Frequency Response	Juency Response 5 Hz to 6,000 Hz +0, -3 Db 10Hz (600cpm) to 1kHz (60kcpm) ± 5% - ISO10816		
Minimum Target Size		*	
Lead-Wire Length	ngth Maximum Cable Distance is 15 Meters with flexible SS conduit considered.		
Electrical Classification		*	
Environmental Limits Requirements			
Operating Temperature	-35 °C to +85 °C (-3	31 °F to +185 °F)	
Storage Temperature	(-60 °F to +212 °F)		
Probe Temperature Requirements			

Project: 600 TPD SULPHURI	C ACID PLANT	Project ID: ES0216	Page	
Prepared by: PC	Verified by: PC	Approved by: PC		

ISGEC	TECHNICAL SPECIFICATION OF VIBRATION SENSOR	
Document ID	600 TPD SULPHURIC ACID PLANT	Revision: 00
Item Code		
Description	VIBRATION SENSOR	Date: 07-08-2024

Operating Temperature	-35 °C to +177 °C (-31 °F to +	-350 °F) Temperature Range: -25 to	
Storage Temperature	-51 °C to +177 °C (-60 °F to +350 °F)		
Relative Humidity	95 % Condensing, Non-Submerged, with Protection of Coaxial Connectors		
1	Mechanical Requirements	Not Applicable for the contact type probes.	
Transducer Tip Material	Polyphenylene Sulfide (PPS)		
Transducer Case Material	AISI 303 or 304 Stainless Steel (SST)		
Cable Armor	Flexible AISI 302 SST with Optional FEP Outer Jacket		
Tensile Strength	222 N (50 lbf) Probe Case to Probe Lead (Maximum)		

Note: "*" Information to be furnished by Vendor.

Project: 600 TPD SULPHURIC ACID PLANT		Project ID: ES0216	Page
Prepared by: PC	Verified by: PC	Approved by: PC	