

EQUIP. NR.	DESCRIPTION
C-UC-1254001A/B	CO2 COMPRESSOR
CX-5143004-04	JUNCTION BOX FOR GEN. USE 480V POWER SOCKET OUTLET (NOTE 7)
CX-M-B-Z-UC-1254001	JUNCTION BOX FOR TURBINE WASHING WATER TROLLEY MOTOR, TANK HEATER AND LOCAL PANELS FOR CO2 TURBOCOMPRESSORS.
PEE-5263021A/B	EMERGENCY LIGHTING PANEL M-01 (NOTE 5)
PL-5143001	NORMAL LIGHTING PANEL M-01 (NOTE 5)
PL-5148001	ESSENTIAL LIGHTING PANEL M-01 (NOTE 5)
PN-5520002B	CSS TOPSIDES REMOTE I/O PANEL
P-UC-1254001A/B-01	CO2 COMPRESSION-1st STAGE DISCHARGE COOLER
P-UC-1254001A/B-02	CO2 COMPRESSION-2nd STAGE DISCHARGE COOLER
P-UC-1254001A/B-03	CO2 COMPRESSION-3rd STAGE DISCHARGE COOLER
P-UC-1254001A/B-04	CO2 COMPRESSION-4th STAGE DISCHARGE COOLER
TS-C-UC-1254001-A/B	GAS TURBINE FOR CO2 COMPRESSION
UC-1254001 A/B	CO2 COMPRESSION UNIT
V-UC-1254001A/B-01	CO2 COMPRESSION-1st STAGE SUCTION SCRUBBER
V-UC-1254001A/B-02	CO2 COMPRESSION-2nd STAGE SUCTION SCRUBBER
V-UC-1254001A/B-03	CO2 COMPRESSION-3rd STAGE SUCTION SCRUBBER
V-UC-1254001A/B-04	CO2 COMPRESSION-4th STAGE SUCTION SCRUBBER



REFERENCE DOCUMENTS

I-ET-3A26.00-1000-941-PPC-001 - METOCEAN DATA
I-LI-3010.90-1200-940-PPC-001 - EQUIPMENT LIST
I-DE-3010.90-1254-943-PPC-001 - PFD CO2 COMPRESSION UNIT (UC-1254001)


GENERAL NOTES

- ALL DIMENSIONS SHOWN IN MILLIMETERS.
- EQUIPMENT DIMENSIONS ARE PRELIMINARY.
- PATHWAY TO OTHER MODULE.
- COAMING (h=150mm), BY STRUCTURE.
- THE LIGHTING PANELS SHALL BE INSTALLED IN A POINT CLOSE TO THE AXIS "B" OF THE MODULE, BY THE DETAILED DESIGN.
- THE STRUCTURES FOR MAINTENANCE WALKWAYS AND STAIRS, AS WELL AS THE EXHAUST SUPPORTING FRAME SHALL BE PROVIDED BY THE EQUIPMENT MANUFACTURER.
- LOCATION SHALL BE DEFINED BY DETAILED DESIGN.

KEY PLAN



MODULE M-01
EL.37500



MODULE M-01
EL.43500

