

SYNTHETIC DEMONSTRATION DOCUMENT - values are invented for the Wet Stack / Mireye prototype and are not real product or project data.

AURORA DC-1 CAMPUS - EQUIPMENT SUBMITTAL

Section 23 65 00 - Cooling Towers

Tag: CT-01 Revision A

PROPOSED EQUIPMENT

Manufacturer: Basin Works

Model number: BW-XT-900

Type: induced draft, counterflow, closed circuit

PERFORMANCE

Heat rejection: 3150 kW

Entering water temperature: 35 degC

Leaving water temperature: 29.4 degC

Design wet bulb temperature: 24 degC

Evaporation rate at design: 4.2 L/s

Make-up water requirement: 5.6 L/s at 4 cycles of concentration

PHYSICAL

Operating weight: 14800 kg

Shipping weight: 9200 kg

Overall dimensions: length 7300 mm, width 3660 mm, height 4270 mm

Supply voltage: 480 V

Full load amps: 61 A

WATER TREATMENT

Maximum total dissolved solids in circulating water: 1200 mg/l

Basin heater required below 0 degC ambient.