

SYNTHETIC DEMONSTRATION DOCUMENT - values are invented for the Wet Stack / Mireye prototype and are not real product or project data.

AURORA DC-1 CAMPUS - EQUIPMENT SUBMITTAL

Section 26 32 13 - Engine Generators

Tag: GEN-01 Submittal 26-3213-002 Revision B

PROPOSED EQUIPMENT

Manufacturer: Cascade Power Systems

Model number: CPS-2750-DF

Rating: 2750 kW standby at 0.8 power factor

Voltage: 13800 V, three phase, 60 Hz

Full load amps: 143 A

Minimum circuit ampacity: 179 A

Maximum overcurrent protection: 200 A

PHYSICAL DATA

Operating weight: 31200 kg

Shipping weight: 28900 kg

Overall dimensions: length 7620 mm, width 2290 mm, height 3050 mm

Support point load: 78 kN per corner mount

FUEL AND EMISSIONS

Fuel consumption at full load: 712 L/h diesel

On-site storage: 72 hours at N+1 load

Emissions: EPA Tier 4 Final, NFPA 110 Level 1 emergency standby

NOTES

1. Concrete housekeeping pad by others; see structural drawings S-401.
2. Exhaust silencer supplied loose for field mounting.

SYNTHETIC DEMONSTRATION DOCUMENT - values are invented for the Wet Stack / Mireye prototype and are not real product or project data.

GEN-01 SUBMITTAL - PAGE 2 - COORDINATION ITEMS

The proposed CPS-2750-DF is 31200 kg operating weight against the 27500 kg assumed in the basis of design. Support point load increases from 65 kN to 78 kN per mount. Structural review of the generator pad is required before release for fabrication.

Ambient design dry-bulb temperature at the site: 38 degC.

Derate at 38 degC and 512 m elevation: 4 percent, giving 2640 kW available.

Acoustic data: 78 dB at 7 m with the supplied enclosure.