

SYNTHETIC DEMONSTRATION DOCUMENT - values are invented for the Wet Stack / Mireye prototype and are not real product or project data.

AURORA DC-1 CAMPUS - REQUEST FOR INFORMATION

RFI 014 Discipline: Mechanical / Structural Status: Open

SUBJECT

Chiller CH-01 substitution - housekeeping pad and support point load

QUESTION

The proposed substitution for CH-01 has an operating weight of 5290 kg against the 4850 kg carried in the basis of design, an increase of 440 kg. Support point load rises accordingly. Please confirm whether the existing 300 mm housekeeping pad and the roof framing below it remain adequate, or issue revised details.

ATTACHMENTS

Vertex VX-1150 submittal, revision A.

RESPONSE

Pending. Structural engineer of record to review. No fabrication release until this RFI is closed.