

SYNTHETIC DEMONSTRATION DOCUMENT - values are invented for the Wet Stack / Mireye prototype and are not real product or project data.

AURORA DC-1 CAMPUS - FIELD MARKUP (SCANNED)

Section 23 64 16 - Air-Cooled Chillers

CH-04 net cooling capacity shall be 1180 kW at 7 degC leaving water.

Operating weight 5410 kg. Full load amps 385 A at 480 V.

Support point load 21 kN per mount.

Marked up on site 14 March. Confirm against manufacturer submittal before use.