

(Authorised Business Partner)

Star Enterprises

4, Ramadhin Singh Commercial Complex,
Babujanj, Near I. T. Crossing, Lucknow
Phones : 0522-2786453/3296826/4012268
Fax : 0522-4044483 e-mail : star_enterprises21@yahoo.in

**FIELD SERVICE REPORT****EMERSON**

Network Power

☒ AMC ☐ WARRANTY ☐ POST WARRANTY ☐ COMMISSIONING

CC : ECC :

Customer Name, Address & Telephone

APV Indus Pvt Ltd
Vishal Khand
Gumti Nagar

Contact Person : Mr Vishal Khand

Nature of Complaint/Fault Reported 7007804692

PM Visit

| | | |
|------------------------|--------------------|-------------------------------------|
| ENP Engineer's Name | Mr. Prakash + 7700 | No. : 1462 |
| Complaint No. | - | Date : |
| Date of Complaint | - | Region : NORTH |
| Time of Complaint | - | <input type="checkbox"/> Install |
| Equipment Item No. | Nummic | <input type="checkbox"/> PM |
| Model / KVA Rating | 10KVA / 240 | <input type="checkbox"/> Fail |
| Sl. No. of Equipment | V0101000550 | <input type="checkbox"/> Correction |
| Installed on | U/AMC | <input type="checkbox"/> Training |
| Promised Date & Time | 12/4/18 | <input type="checkbox"/> Technical |
| Attended Date & Time | 12/4/18 | Site : |
| Time of Completion | 2:00 Pm | Engineer Code : |
| Man days / Hrs. Worked | | Channel : |
| SO / SC No. | 9919991363 | |

Observation and Work Done

Check the UPS and Battery B.
Service Properly, UPS is working
well. Charging mode and
Backup mode well OK

APV-IMS
ENTRY MADE

SIGN. etDate 12-4-18**A. C. INPUT**

| | |
|-------------|-------|
| L-L (3 Ø) | V |
| L-N | 240 V |
| N-E | 0 V |
| E-L | 240 V |
| Freq | 50 Hz |
| A.C. Output | 230 V |

BATTERYMake : Amerson Quantum

20 No's. 18 Ah

Chg. 2.5 A 270 V

Open 250 V

Health OK

Attach extra sheets if required

Spares Used

Spares Billed

☐ Yes☐ No

| Sl.No. | Part Code | Description | Fault Code | Qty. | Price (Rs.) |
|--------|-----------|-------------|------------|------|-------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Service Charge to be Billed ☐ Yes☐ No

Service Charge

Customer's Remark**Engineer's Remark**

Total

The above job was carried out and completed to
our satisfaction. The equipment is working
satisfactory. We agree to pay the charges.

RSM Remark

Customer's Name, Signature & Seal

Sign. & Stamp of the Engineer

Date :

RSM/BSI's Signature

White : Customer

Green : H.O.

Yellow : Dealer

Pink : Fix