

(Authorised Business Partner)

Star Enterprises

4, Ramadhin Singh Commercial Complex,
Babuganj, Near I. T. Crossing, Lucknow
Phones : 0522-2786453/3296826/4012268
Fax : 0522-4044483 e-mail : star_enterprises21@yahoo.in

**FIELD SERVICE REPORT****EMERSON**

Network Power

☐ AMC ☐ WARRANTY ☐ POST WARRANTY ☐ COMMISSIONING

CC : ECC :

Customer Name, Address & Telephone

AP.V Indira P.V + 2nd
Vishal Khanda
Gandhi Nagar

Contact Person : Mr. Vishnu 7007804692

Nature of Complaint/Fault Reported

Pm
Visit

ENP Engineer's Name Mr. Prakash + Hari

Complaint No. - No. : 1463

Date of Complaint - Date :

Time of Complaint - Region : NORTH

Equipment Item No. - ☐ InstallModel / KVA Rating 6KVA/240 ☐ PMSl. No. of Equipment XT100704636 ☐ FailInstalled on 4AME ☐ CorrectionPromised Date & Time 12/4/18 ☐ TrainingAttended Date & Time 12/4/18 ☐ Technical

Time of Completion 3:00 Site :

Man days / Hrs. Worked Engineer Code :

SO / SC No. Channel :

Observation and Work Done

check the UPS and Battery
servicing properly, UPS is
working on charging mode
and Back up mode well
OK

A. C. INPUT

L-L (3 O)	V
L-N	240 V
N-E	0 V
E-L	240 V
Freq	50 Hz
A.C. Output	23 V

BATTERY

Make :	Exide
20 No's.	17 Ah
Chg.	25 A 270 V
Open	240 V
Health	OK

Attach extra sheets if required

Spares Used

Spares Billed

☐ Yes☐ No

Sl.No.	Part Code	Description	Fault Code	Qty.	Price (Rs.)

Service Charge to be Billed ☐ Yes☐ No

Service Charge

Customer's Remark**Engineer's Remark****Total**

The above job was carried out and completed to
our satisfaction. The equipment is working
satisfactory. We agree to pay the charges.

Prakash

RSM Remark

APV-IMS
ENTRY MADE
SIGN. et
Date 12-4-18

Date : Customer's Name, Signature & Seal

Sign. & Stamp of the Engineer

Date : RSM/BSI's Signature

White : Customer

Green : H.O.

Yellow : Dealer

Pink : Fix