

Star Enterprises

4, Ramadhin Singh Commercial Complex, Near I. T. Crossing, Lucknow-226020 Phone : (0522) 4012269

INSTALLATION/SERVICE CALL REPORT

Name of Service Personnel : RKC Sharmin + Shreyas				
Date 10/1/20	Attended Time : 12:30 PM	Completion Time : 2:30 PM		
Customer's Name & Address Amitoj		Tel.No. 9838078003 Serial No. 1909		
APV India Pvt Ltd 3/31, Nithal Khand Gomti Nagar Luck		Warranty / AMC / Out of Warranty		
		Equipment ONG Inverter Make Humanic		
		S.No. 7100704631 Capacity 6kVA DC BUS V010100550 10A		
Problem	Action Taken	Spare Used		
AMC visit with complaint for VFT-UPF	① Checked UPS Humanic 12V-18AH checked the UPS, found battery fault Required 20Ah battery 12V 18AH - Then UPS worked well. UPS - 11.12	X20 Esidur		
	② Checked VFT-UPF Humanic 12V-18AH X20 Esidur checked VFT-UPF worked well.	(S)		
Remarks :				
This is to certify that our equipment has been repaired to my entire satisfaction.		Payment by Cheque / Cash	Visit Charges	
		Cheque No.	Dt.	Amount Payable
Name 		Received Rupees For billing as per the above detail		
Signature of Customer		 Signature of Service Personnel		
Note : 1- If the equipment is out of warranty visit charge Rs. 250/- will be charged. 2- Repairing has no guarantee.				