

4, Ramadhin Singh Commercial Complex, Near I. T. Crossing, Lucknow-226020 Phone : (0522) 4012269

Name of Service Personnel : R.K. Sharma		
Date 1/2/19	Attended Time : 11:00 AM	Completion Time : 1:30 PM
Customer's Name & Address Mr. Vishnu APV India Pvt. Ltd. 3/311 Vishal Khandel Gomti Nagar Uda	Tel.No. —	Serial No. 1646
	Warranty / AMC / Out of Warranty	
	Equipment ONLine UPS Make Numanic	
	S.No. V1106704631 Capacity 6kVA DC BUS 240	
Problem	Action Taken	Spare Used
AMC Visit	checked the UPS, working well, clean proper UPS and load test. Batteries 20 Nos 12V-18Ah week. UPS is OK	18Ah 12V X 20 Nos
Remarks :		
[Signature]		
This is to certify that our equipment has been repaired to my entire satisfaction.	Payment by Cheque / Cash	
	Visit Charges	
	Cheque No.	Dt.
Name [Signature]	Amount Payable	
	Received Rupees .....	
Signature of Customer	For billing as per the above detail	
	Signature of Service Personnel [Signature]	
Note : 1- If the equipment is out of warranty visit charge Rs. 250/- will be charged. 2- Repairing has no guarantee.		