INSPECTION REPORT - PUMP P-101

Date: 12 September 2026 Inspector: R. Sharma

Equipment: Cooling water pump P-101

Measured impeller wear: 4.2 mm

Shaft vibration: 3.8 mm/s RMS

Bearing temperature: 71 C

Notes: Visible scoring on impeller vanes.

Recommendation: refer to SOP-114.