



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

FINAL DIMENSIONAL INSPECTION REPORT (STRUCTURE)

| | | | | | | | | | |
|------------|---------------------------------|---------|-----------------|---------------|---------------|--------------------|------------------|---------|---------|
| CLIENT | AARTI INDUSTRIES LTD | | | DATE | 04/06/2025 | | | | |
| PROJECT | CORAL-2 | | | WO NO./PO NO. | 4580584722 | | | | |
| REPORT NO. | VE/CORAL-2/STR/FD/10 | | | | | | | | |
| SR No. | FAB.DRAWING NO. | REV.NO. | ASSEMBLY NUMBER | GRID NUMBER | GRID QTY | REQUIRED DIMENSION | ACTUAL DIMENSION | ACC/REJ | REMARKS |
| 1 | PIN-084-TPT-CM1-CS11-002-FAB-B1 | 0 | B1 | C/4-3 | 1 | 3192,40,40 | 3193,41,40 | ACC | -- |
| 2 | PIN-084-TPT-CM1-CS11-002-FAB-B1 | 0 | B1 | B/4-3 | 1 | 3192,40,40 | 3193,41,41 | ACC | -- |
| 3 | PIN-084-TPT-CM1-CS11-002-FAB-B1 | 0 | B1 | D/4-3 | 1 | 3192,40,40 | 3194,42,40 | ACC | -- |
| 4 | PIN-084-TPT-CM1-CS11-002-FAB-B2 | 0 | B2 | E/4-3 | 2 | 3172,30,30 | 3174,32,31 | ACC | -- |
| 5 | PIN-084-TPT-CM1-CS11-002-FAB-B2 | 0 | B2 | G/4-3 | 3 | 3172,30,30 | 3173,31,31 | ACC | -- |
| 6 | PIN-084-TPT-CM1-CS11-002-FAB-B2 | 0 | B2 | F/4-3 | 3 | 3172,30,30 | 3173,32,30 | ACC | -- |
| 7 | PIN-084-TPT-CM1-CS11-002-FAB-B2 | 0 | B2 | C/4-3 | 1 | 3172,30,30 | 3174,30,31 | ACC | -- |
| 8 | PIN-084-TPT-CM1-CS11-002-FAB-B2 | 0 | B2 | D/4-3 | 1 | 3172,30,30 | 3172,31,32 | ACC | -- |
| NOTE | | | | | | | | | |
| | VE QC | | | | CLIENT QC/TPI | | | | |
| SIGNATURE | | | | | | | | | |
| NAME | SURAJ THAKUR | | | | | | | | |
| DATE | 04/06/2025 | | | | | | | | |

VE-DOC-12 REV.00



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED

GROUP OF COMPANIES

| FINAL DIMENSIONAL INSPECTION REPORT (STRUCTURE) | | | | | | | | | |
|---|----------------------------------|---------|-----------------|---------------|---------------|--------------------|------------------|---------|---------|
| CLIENT | AARTI INDUSTRIES LTD | | | DATE | 04/06/2025 | | | | |
| PROJECT | CORAL-2 | | | WO NO./PO NO. | 4580584722 | | | | |
| REPORT NO. | VE/CORAL-2/STR/FD/10 | | | | | | | | |
| SR No. | FAB.DRAWING NO. | REV.NO. | ASSEMBLY NUMBER | GRID NUMBER | GRID QTY | REQUIRED DIMENSION | ACTUAL DIMENSION | ACC/REJ | REMARKS |
| 9 | PIN-084-TPT-CM1-CS11-002-FAB-B2 | 0 | B2 | H/4-3 | 3 | 3172,30,30 | 3173,31,31 | ACC | -- |
| 10 | PIN-084-TPT-CM1-CS11-002-FAB-B10 | 0 | B10 | D-E/2 | 1 | 4142,30,30 | 4144,31,29 | ACC | -- |
| 11 | PIN-084-TPT-CM1-CS11-002-FAB-B10 | 0 | B10 | B-C/2 | 1 | 4142,30,30 | 4143,31,30 | ACC | -- |
| NOTE | | | | | | | | | |
| | VE QC | | | | CLIENT QC/TPI | | | | |
| SIGNATURE | | | | | | | | | |
| NAME | SURAJ THAKUR | | | | | | | | |
| DATE | 04/06/2025 | | | | | | | | |
| VE-DOC-12 REV.00 | | | | | | | | | |