



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

SURFACE PREPARATION & PRIMER PAINT INSPECTION REPORT

CLIENT	GFCL EV Products Limited	PROJECT	HH-2700 TPA	REPORT NO.	VE/HH-2700 TPA/STR/SP/1
WO/PO NO	9252100056	PROCEDURE NO.	VEPL/GFCL/HH-2700 TPA/ITP/001	OFFER DATE	01/06/2025

WEATHER CONDITION

ACTIVITY	DATE PERFORMED	START TIME - 14:30				FINISH TIME- 19:45			
		SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C	SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C
Blasting / Surf. Prep.	31/05/2025	33	29	56.4	38.9	32	28.2	61.7	36.5
Primer Application	31/05/2025	32	28.2	61.7	36.5	33	27.1	73.5	32.3

SURFACE CONDITION

ORIGINAL STATUS	NON COATED	METAL CONDITION	NON COATED	METAL RUST GRADE	B
PAINT SYSTEM NO.	GFL STRUCTURAL			BLASTING DATE	31/05/2025

SURFACE PREPARATION

BLASTING METHOD	CU-SLG	PREP. STANDARD	SA 2 1/2	ABRASIVE TYPE	GU-SLG
SURFACE PROFILE REQUIREMENT	40 - 70 Microns	ACTUAL SURFACE PROFILE	50-60		
DUST LEVEL	01	SALT TEST REQUIRED	Maximum 80 mg/m2	SALT TEST READING	20.4mg/m2

PRIMER COATING

PRIMER PAINT/SHADE	SIGMACOVER 620	APP. METHOD	SPRAY	PRIMER DATE	31/05/2025
PAINT MANUFACTURER	ASIAN PPG	DFT RANGE	150 Micron	HARD DRY TIME	6
PAINT BATCH NO. (BASE)	'0537500151	MANUFACTURE DATE	26/04/2025	SHELF LIFE	36 MONTHS
PAINT BATCH NO. (HARDNER)	'0537500151				

SR. NO.	DRAWING NO.	REV	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	Average DFT	ACC/REJ
						PRIMER	
1	1619-CS-STR-504-FD-1C15	0	1C15	E-4	1	150-165	ACC
2	1619-CS-STR-504-FD-2C14	0	2C14	E-3	1	152-170	ACC

NOTE	--				
	VISHAL QC			CLIENT / TPIA	
SIGN					
NAME	BIRENDRA KUMAR				
DATE	02/06/2025				

VE-DOC-24 REV.00



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

SURFACE PREPARATION & PRIMER PAINT INSPECTION REPORT

CLIENT	GFCL EV Products Limited	PROJECT	HH-2700 TPA		REPORT NO.	VE/HH-2700 TPA/STR/SP/1	
WO/PO NO	9252100056	PROCEDURE NO.	VEPL/GFCL/HH-2700 TPA/ITP/001		OFFER DATE	01/06/2025	
SR. NO.	DRAWING NO.	REV	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	Average DFT	ACC/REJ
						PRIMER	
3	1619-CS-STR-504-FD-2C15	0	2C15	E-4	1	155-168	ACC
4	1619-CS-STR-504-FD-1C14	0	1C14	E-3	1	154-165	ACC
5	1619-CS-STR-504-FD-1C35	0	1C35	C-2	1	160-174	ACC
6	1619-CS-STR-504-FD-2C13	0	2C13	E-2	1	150-175	ACC
7	1619-CS-STR-504-FD-2C35	0	2C35	C-2	1	155-170	ACC
NOTE	--						
	VISHAL QC			CLIENT / TPIA			
SIGN							
NAME	BIRENDRA KUMAR						
DATE	02/06/2025						

VE-DOC-24 REV.00