



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

MIO PAINT INSPECTION REPORT

| | | | | | |
|----------|--------------|---------------|------------------|------------|-----------------------|
| CLIENT | SURAJ ROSHNI | PROJECT | SURYA-25 | REPORT NO. | VE/SURYA-25/STR/MIO/8 |
| WO/PO NO | 898989890000 | PROCEDURE NO. | VEPL/DCM/ITP/001 | OFFER DATE | 25/03/2025 |

WEATHER CONDITION

| ACTIVITY | DATE PERFORMED | START TIME - 18:26 | | | | FINISH TIME- 21:26 | | | |
|----------|----------------|--------------------------|--------------|---------------------|-----------------|--------------------------|--------------|---------------------|-----------------|
| | | SURFACE OR METAL TEMP °C | DEW POINT °C | RELATIVE HUMIDITY % | AMBIENT TEMP °C | SURFACE OR METAL TEMP °C | DEW POINT °C | RELATIVE HUMIDITY % | AMBIENT TEMP °C |
| MIO Coat | 24/03/2025 | 32 | 27 | 60 | 32 | 30 | 25 | 67 | 29 |

INTERMEDIATE / MIO COATING

| | | | | | |
|---------------------------|------------------------------|------------------|--|---------------|------------|
| MIO PAINT/SHADE | Intergard 475HS / Light gray | APP. METHOD | SPRAY | MIO DATE | 24/03/2025 |
| PAINT MANUFACTURER | AKZONOBEL INDIA | DFT RANGE | 200 microns (Including Primer : 300 microns) | HARD DRY TIME | 4 HOUR |
| PAINT BATCH NO. (BASE) | Q089256 | MANUFACTURE DATE | 16/01/2025 | SHELF LIFE | 1 YEAR |
| PAINT BATCH NO. (HARDNER) | Q089255 | | | | |

| SR. NO. | DRAWING NO. | REV | ASSEMBLY NUMBER | GRID NUMBER | GRID QTY | Average DFT | ACC/REJ |
|---------|------------------------------------|-----|-----------------|-------------|----------|-------------|---------|
| | | | | | | MIO | |
| 1 | TCE-13282A-CV-2026-ST-30306-ASS-B2 | 0 | B2 | B2-3 | 10 | 302 - 319 | ACC |

| | |
|------|-----------------|
| NOTE | -- |
| | VISHAL QC |
| | CLIENT / TPIA |
| SIGN | |
| NAME | SHIVANG DIWAKAR |
| DATE | 25/03/2025 |

VE-STR-16C