



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

RADIOGRAPHY TEST REPORT (STRUCTURAL)

CLIENT	SURAJ ROSHNI	PO/W.O. NO.	9558569011	REPORT NO.	VE/SURYA-26/STR/RT/2		
PROJECT	SURYA-26	PROCEDURE NO.	ABC	REPORT DATE	16/05/2025		
SOURCE	OK	FILM TYPE	OK	TEST DATE	16/05/2025		
STRENGTH	OK	SENSITIVITY	OK	DENSITY	OK		
PENETRAMETER	OK	ACCEPTANCE STANDARD	OK	FRONT	OK	BACK	OK

RESULT SUMMARY

SR No.	GRID NUMBER	GRID QTY	DRAWING NO.	ASSEMBLY NUMBER	PROFILE	WELDING PROCESS	WELDER NO.	THICKNESS (mm)	SFD	EXPO TIME	TECHNIQUE	SEGMENT	FILM SIZE	OBSERVATION	RESULT
1	B7-1	1	B7	B7	ISMC300	FCAW	S-AB13	10 MM	OK	OK	OK	A-B	5X4	NRI	ACC
2	B7-1	1	B7	B7	ISMC300	FCAW	S-AB13	10 MM	OK	OK	OK	B-C	5X4	NRI	ACC

NOTE

VE QC (L-II/III)

CLIENT-QC / TPI

SIGNATURE

NAME

HARDIK PRAJAPATI

DATE

16/05/2025

VE-DOC-16 REV.00