



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

MIO PAINT INSPECTION REPORT

CLIENT	SURAJ ROSHNI	PROJECT	SURYA-25	REPORT NO.	VE/SURYA-25/STR/MIO/6
WO/PO NO	898989890000	PROCEDURE NO.	VEPL/DCM/ITP/001	OFFER DATE	22/03/2025

WEATHER CONDITION

ACTIVITY	DATE PERFORMED	START TIME - 13:01				FINISH TIME- 15:02			
		SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C	SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C
MIO Coat	22/03/2025	27	22	65	28	29	24	68	28

INTERMEDIATE / MIO COATING

MIO PAINT/SHADE	Intergard 475HS / Light gray	APP. METHOD	SPRAY	MIO DATE	22/03/2025
PAINT MANUFACTURER	AKZONOBEL INDIA	DFT RANGE	200 microns (Including Primer : 300 microns)	HARD DRY TIME	4 HOUR
PAINT BATCH NO. (BASE)	Q089256	MANUFACTURE DATE	10/01/2025	SHELF LIFE	1 YEAR
PAINT BATCH NO. (HARDNER)	Q089255				

SR. NO.	DRAWING NO.	REV	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	Average DFT	ACC/REJ
						MIO	
1	TCE-13282A-CV-2026-ST-30306-ASS-VBR2	0	VBR2	VBR2-2	6	310 - 319	ACC
2	TCE-13282A-CV-2026-ST-30306-ASS-VBR2	0	VBR2	VBR2-1	6	312 - 329	ACC
3	TCE-13282A-CV-2026-ST-30306-ASS-VBR3	0	VBR3	VBR3-1	3	315 - 330	ACC
4	TCE-13282A-CV-2026-ST-30306-ASS-VBR3	0	VBR3	VBR3-2	3	320 - 330	ACC
5	TCE-13282A-CV-2026-ST-30306-ASS-VBR4	0	VBR4	VBR4-1	3	319 - 329	ACC
6	TCE-13282A-CV-2026-ST-30306-ASS-VBR4	0	VBR4	VBR4-2	3	307 - 319	ACC

NOTE	--				
	VISHAL QC			CLIENT / TPIA	
SIGN					
NAME	SHIVANG DIWAKAR				
DATE	22/03/2025				

VE-STR-16C