



# VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

## MIO PAINT INSPECTION REPORT

CLIENT	SURAJ ROSHNI	PROJECT	SURYA-25	REPORT NO.	VE/SURYA-25/STR/MIO/11
WO/PO NO	898989890000	PROCEDURE NO.	VEPL/DCM/ITP/001	OFFER DATE	09/05/2025

## WEATHER CONDITION

ACTIVITY	DATE PERFORMED	START TIME - 21:40				FINISH TIME - 22:40			
		SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C	SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C
MIO Coat	09/05/2025	1	1	1	1	1	1	1	1

## INTERMEDIATE / MIO COATING

MIO PAINT/SHADE	Intergard 475HS / Light gray	APP. METHOD	SPRAY	MIO DATE	09/05/2025
PAINT MANUFACTURER	AKZONOBEL INDIA	DFT RANGE	200 microns (Including Primer : 300 microns)	HARD DRY TIME	1
PAINT BATCH NO. (BASE)	1	MANUFACTURE DATE	02/05/2025	SHELF LIFE	1
PAINT BATCH NO. (HARDNER)	1				

SR. NO.	DRAWING NO.	REV	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	Average DFT	ACC/REJ
						MIO	
1	TCE-13282A-CV-2026-ST-30306-ASS-VBR9	0	VBR9	VBR9-1	1	200	ACC
2	TCE-13282A-CV-2026-ST-30306-ASS-VBR11	0	VBR11	VBR11	3	200	ACC

NOTE	--					
	VISHAL QC			CLIENT / TPIA		
SIGN						
NAME	HARDIK PRAJAPATI					
DATE	09/05/2025					

VE-DOC-26 REV.00