



# VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

## FINAL / TOP COAT PAINT INSPECTION REPORT

<b>CLIENT</b>	SURAJ ROSHNI	<b>PROJECT</b>	SURYA-25	<b>REPORT NO.</b>	VE/SURYA-25/STR/FINAL-PAINT/13
<b>WO/PO NO</b>	898989890000	<b>PROCEDURE NO.</b>	VEPL/DCM/ITP/001	<b>OFFER DATE</b>	14/05/2025

### WEATHER CONDITION

ACTIVITY	DATE PERFORMED	START TIME - 10:43				FINISH TIME- 12:43			
		SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C	SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C
Top Coat / Final	14/05/2025	1	1	1	1	1	1	1	1

### FINAL / TOP COATING

<b>FINAL PAINT/SHADE</b>	Interthane 990 / RAL 7012 Dark Admiralty Gray	<b>APP. METHOD</b>	SPRAY	<b>FINAL DATE</b>	14/05/2025
<b>PAINT MANUFACTURER</b>	AKZONOBEL INDIA	<b>DFT RANGE</b>	60 Microns	<b>TIME</b>	QA
<b>PAINT BATCH NO. (BASE)</b>	QA	<b>MANUFACTURE DATE</b>	02/05/2025	<b>SHELF LIFE</b>	QA
<b>PAINT BATCH NO. (HARDNER)</b>	QA				

SR. NO.	DRAWING NO.	REV	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	Average DFT	ACC/REJ
						FINAL / TOP COAT	
1	TCE-13282A-CV-2026-ST-30306-ASS-VBR9	0	VBR9	VBR9-2	2	244	ACC

<b>NOTE</b>	--					
	<b>VISHAL QC</b>			<b>CLIENT / TPIA</b>		
<b>SIGN</b>						
<b>NAME</b>	HARDIK PRAJAPATI					
<b>DATE</b>	14/05/2025					

VE-DOC-28 REV.00