



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

MIO PAINT INSPECTION REPORT

CLIENT	SURAJ ROSHNI	PROJECT	SURYA-25	REPORT NO.	VE/SURYA-25/STR/MIO/6
WO/PO NO	898989890000	PROCEDURE NO.	VEPL/DCM/ITP/001	OFFER DATE	13/05/2025

WEATHER CONDITION

ACTIVITY	DATE PERFORMED	START TIME - 16:31				FINISH TIME- 20:31			
		SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C	SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C
MIO Coat	13/05/2025	1	1	1	1	1	1	1	1

INTERMEDIATE / MIO COATING

MIO PAINT/SHADE	Intergard 475HS / Light gray	APP. METHOD	SPRAY	MIO DATE	13/05/2025
PAINT MANUFACTURER	AKZONOBEL INDIA	DFT RANGE	200 microns (Including Primer : 300 microns)	HARD DRY TIME	1
PAINT BATCH NO. (BASE)	1	MANUFACTURE DATE	01/01/2025	SHELF LIFE	OK
PAINT BATCH NO. (HARDNER)	OK				

SR. NO.	DRAWING NO.	REV	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	Average DFT	ACC/REJ
						MIO	
1	TCE-13282A-CV-2026-ST-30306-ASS-VBR7A	0	VBR7A	VBR7-1	3	210	ACC
2	TCE-13282A-CV-2026-ST-30306-ASS-VBR7A	0	VBR7A	VBR7-2	2	215	ACC
3	TCE-13282A-CV-2026-ST-30103-ASS-B5	0	B5	B5	5	218	ACC

NOTE	--				
	VISHAL QC			CLIENT / TPIA	
SIGN					
NAME	HARDIK PRAJAPATI				
DATE	13/05/2025				

VE-DOC-26 REV.00