



VISHAL ENTERPRISE & VRISHAL ENGINEERING PRIVATE LIMITED GROUP OF COMPANIES

MIO PAINT INSPECTION OFFER

CLIENT	PIYUSH ENTERPRISE	PROJECT	PIYUSH BUILDING	REPORT NO.	VE/PIYUSH BUILDING/STR/MIO/1
WO/PO NO	9558569010	PROCEDURE NO.	PRS/4	OFFER DATE	08/03/2025

WEATHER CONDITION

ACTIVITY	DATE PERFORMED	START				FINISH			
		SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C	SURFACE OR METAL TEMP °C	DEW POINT °C	RELATIVE HUMIDITY %	AMBIENT TEMP °C
MIO Coat	08/03/2025	28	22	65	29	27	21	65	28

INTERMEDIATE / MIO COATING

MIO PAINT/SHADE	APCODUR MIO 400	APP. METHOD	SPRAY	MIO DATE	08/03/2025
PAINT MANUFACTURER	ASIAN PPG	DFT RANGE	200 microns (Including Primer : 300 microns)	TIME	5:45 PM
PAINT BATCH NO. (BASE)	Q089256	MANUFACTURE DATE	09/01/2025	SHELF LIFE	1 YEAR
PAINT BATCH NO. (HARDNER)	Q089255				

SR. NO.	DRAWING NO.	ASSEMBLY NUMBER	GRID NUMBER	GRID QTY	REMARKS
1	TCE-13282A-CV-3066-ST-31020-ASS-FR1	FR1	FR1-3	1	--
2	TCE-13282A-CV-3066-ST-31020-ASS-FR1	FR1	FR1-4	1	--
3	TCE-13282A-CV-3066-ST-31020-ASS-FR1	FR1	FR1-5	1	--
4	TCE-13282A-CV-3066-ST-31020-ASS-FR1	FR1	FR1-1	1	--
5	TCE-13282A-CV-3066-ST-31020-ASS-FR1	FR1	FR1-2	1	--

NOTE	--
	OFFERED BY
SIGN	
NAME	VIVEK SINGH
DATE	08/03/2025

VE-STR-16B