

DATE PRINTED 19/08/2017  
ID# - 601669

CUST - PT IP UJP PLTU  
JERANJANG

SUB NAME -  
CITY - MATARAM LOMBOK  
UNIT# - **ASH HANDLING**

LOCATION - OUTDOOR  
OTHER -

VISUAL INSPECTION

| DATE       | STATUS | OIL TEMP °C | W. TEMP °C | OIL LEVEL | PAINT | S. GEL | LEAKS |
|------------|--------|-------------|------------|-----------|-------|--------|-------|
| 04/07/2017 | ONLINE |             | 46         |           |       |        |       |
| 31/07/2017 | ONLINE |             |            |           |       |        |       |

NAMEPLATE DATA

|                   |                   |
|-------------------|-------------------|
| MFG               | - WOLONG          |
| DATE MFG          | - 2011            |
| MAIN TANK S/N     | - <b>10820108</b> |
| KVA               | - 1600            |
| PRI               | - 6300 V          |
| SEC               | - 400 V           |
| KILOGRAMS         | - 4505            |
| EQUIP TYPE        | - TRANSFORMER     |
| TRANS CLASS       | - ONAN            |
| IMPEDENCE         | - 5.56%           |
| PHASE/CYCLE       | - 3/50 Hz         |
| LIQUID TYPE       | - OIL             |
| LITRES LIQUID     | - 1023            |
| LTC MFG           | -                 |
| LTC S/N           | -                 |
| LTC FAB NO        | -                 |
| LTC MODEL         | -                 |
| LTC LITRES LIQUID | -                 |
| LTC ENERGIZED     | -                 |

LIQUID SCREEN TEST DATA

| DATE       | SERVICES | ASTM D974<br>ACID<br>(mgKOH/gm) | ASTM D971<br>IFT<br>(mN/m) | IEC 156<br>DIEL<br>(kV) | ASTM D1500<br>COLOUR | ASTM D4052<br>SP. GR. | ASTM D1524<br>VISUAL | ASTM D1698<br>® SEDIMENT |
|------------|----------|---------------------------------|----------------------------|-------------------------|----------------------|-----------------------|----------------------|--------------------------|
| 04/07/2017 | ROUTINE  | 0.022 AC                        | 38.1 AC                    | 38 AC                   | 1.0 AC               | 0.8779 AC             | CLEAR AC             |                          |
| 31/07/2017 | ROUTINE  | 0.025 AC                        |                            | 56 AC                   | 1.0 AC               |                       | CLEAR AC             |                          |

DISSOLVED GAS ANALYSIS (ASTM D3612), EXPRESSED IN PPM

| DATE       | HYDROGEN | OXYGEN | NITROGEN | METHANE | CARBON<br>MONOXIDE | CARBON<br>DIOXIDE | ETHANE | ETHYLENE | ACETYLENE | TOTAL<br>COMBUSTIBLE | TOTAL<br>GAS |
|------------|----------|--------|----------|---------|--------------------|-------------------|--------|----------|-----------|----------------------|--------------|
| 04/07/2017 | 35       | 10984  | 71058    | 20      | 441                | 5037              | 7      | 8        | ND        | 511                  | 87590        |

ADDITIONAL EQUIPMENT

|                 |   |
|-----------------|---|
| RADIATORS       | - |
| FANS            | - |
| H2O COOLED      | - |
| OIL PUMPS       | - |
| TOP FPV         | - |
| BOTTOM FPV      | - |
| BUCHOLZ         | - |
| CONSERVATOR     | - |
| LTC COMPARTMENT | - |
| BUSHING LOC     | - |
| FREE BREATHER   | - |
| HOSE LENGTH     | - |
| POWER AVAILABLE | - |

RECOMMENDATION:  
CARBON MONOXIDE AND CARBON DIOXIDE LEVEL ARE HIGH. OTHER GASES LEVELS ARE ASSESSED AS ACCEPTABLE.

WATER CONTENT (ASTM D1533), EXPRESSED IN PPM

| DATE       | TEMP°C | PPM | %M/dw | GRADE |
|------------|--------|-----|-------|-------|
| 04/07/2017 | 34     | 28  | 2.30  | C     |
| 31/07/2017 | 26     | 21  | 2.73  | D     |

FIELD SERVICE  
DATE                  SERVICE

DATE PRINTED 19/08/2017

ID# - 601669

CUST - PT IP UJP PLTU  
JERANJANG

SUB NAME -  
CITY - MATARAM LOMBOK  
UNIT# - ASH HANDLING

LOCATION - OUTDOOR  
OTHER -

NAMEPLATE DATA

|                   |               |
|-------------------|---------------|
| MFG               | - WOLONG      |
| DATE MFG          | - 2011        |
| MAIN TANK S/N     | - 10820108    |
| KVA               | - 1600        |
| PRI               | - 6300 V      |
| SEC               | - 400 V       |
| KILOGRAMS         | - 4505        |
| EQUIP TYPE        | - TRANSFORMER |
| TRANS CLASS       | - ONAN        |
| IMPEDENCE         | - 5.56%       |
| PHASE/CYCLE       | - 3/50 Hz     |
| LIQUID TYPE       | - OIL         |
| LITRES LIQUID     | - 1023        |
| LTC MFG           | -             |
| LTC S/N           | -             |
| LTC FAB NO        | -             |
| LTC MODEL         | -             |
| LTC LITRES LIQUID | -             |
| LTC ENERGIZED     | -             |

ADDITIONAL EQUIPMENT

|                 |   |
|-----------------|---|
| RADIATORS       | - |
| FANS            | - |
| H2O COOLED      | - |
| OIL PUMPS       | - |
| TOP FPV         | - |
| BOTTOM FPV      | - |
| BUCHOLZ         | - |
| CONSERVATOR     | - |
| LTC COMPARTMENT | - |
| BUSHING LOC     | - |
| FREE BREATHER   | - |
| HOSE LENGTH     | - |
| POWER AVAILABLE | - |

FURAN ANALYSIS (ASTM D5837), EXPRESSED IN PPB

|            |      |      |      |      |      |       |
|------------|------|------|------|------|------|-------|
| DATE       | 5H2F | 2FOL | 2FAL | 2ACF | 5M2F | TOTAL |
| 04/07/2017 | ND   | ND   | ND   | ND   | ND   | ND    |

RECOMMENDATION:  
RETEST 12 MONTHS:  
TEST RESULT OBTAINED IN THIS TEST IS IN LINE WITH A HEALTHY PAPER INSULATION OF TRANSFORMER.

METALS-IN-OIL (ASTM D3635), EXPRESSED IN PPM

|            |           |      |        |
|------------|-----------|------|--------|
| DATE       | ALUMINIUM | IRON | COPPER |
| 04/07/2017 | ND        | 0.01 | 0.01   |

LIQUID POWER FACTOR (ASTM D924)

|            |          |          |
|------------|----------|----------|
| DATE       | 25°C     | 100°C    |
| 04/07/2017 | 0.000 AC | 0.730 AC |

INHIBITOR CONTENT, DBPC (ASTM D2668)

|            |            |
|------------|------------|
| DATE       | %BY WEIGHT |
| 04/07/2017 | 0.23 AC    |

CORROSIVE SULFUR (ASTM 1275B)

|            |         |       |             |
|------------|---------|-------|-------------|
| DATE       | STATUS  | CLASS | APPEARANCE  |
| 04/07/2017 | NON-COR | 1B    | DARK ORANGE |

PASSIVATOR COUNT, EXPRESSED IN PPM

|      |     |
|------|-----|
| DATE | PPM |
|------|-----|

FIELD SERVICE

|      |         |
|------|---------|
| DATE | SERVICE |
|------|---------|