

DATE PRINTED 25/07/2017

ID# - 601669

CUST - PT IP UJP PLTU  
JERANJANG

SUB NAME -  
CITY - MATARAM LOMBOK  
UNIT# - **TRAFO 3 ESP UNIT 3**

LOCATION - OUTDOOR  
OTHER -

VISUAL INSPECTION

| DATE       | STATUS | OIL TEMP °C | W. TEMP °C | OIL LEVEL | PAINT | S. GEL | LEAKS |
|------------|--------|-------------|------------|-----------|-------|--------|-------|
| 04/07/2017 | ONLINE |             |            |           |       |        |       |

NAMEPLATE DATA

|                   |                     |
|-------------------|---------------------|
| MFG               | - ZHEJIANG          |
| DATE MFG          | -                   |
| MAIN TANK S/N     | - <b>0072084208</b> |
| KVA               | -                   |
| PRI               | - 72000 V           |
| SEC               | - 415 V             |
| KILOGRAMS         | - 1350              |
| EQUIP TYPE        | - TRANSFORMER       |
| TRANS CLASS       | - ONAN              |
| IMPEDENCE         | -                   |
| PHASE/CYCLE       | - 3/50 Hz           |
| LIQUID TYPE       | - OIL               |
| LITRES LIQUID     | - 731               |
| LTC MFG           | -                   |
| LTC S/N           | -                   |
| LTC FAB NO        | -                   |
| LTC MODEL         | -                   |
| LTC LITRES LIQUID | -                   |
| LTC ENERGIZED     | -                   |

LIQUID SCREEN TEST DATA

| DATE       | SERVICES | ASTM D974<br>ACID<br>(mgKOH/gm) | ASTM D971<br>IFT<br>(mN/m) | IEC 156<br>DIEL<br>(kV) | ASTM D1500<br>COLOUR | ASTM D4052<br>SP. GR. | ASTM D1524<br>VISUAL | ASTM D1698<br>® SEDIMENT |
|------------|----------|---------------------------------|----------------------------|-------------------------|----------------------|-----------------------|----------------------|--------------------------|
| 04/07/2017 | ROUTINE  | 0.025 AC                        | 27.8 UN                    | 40 AC                   | 1.5 AC               | 0.8415 AC             | CLEAR AC             |                          |

DISSOLVED GAS ANALYSIS (ASTM D3612), EXPRESSED IN PPM

| DATE       | HYDROGEN | OXYGEN | NITROGEN | METHANE | CARBON<br>MONOXIDE | CARBON<br>DIOXIDE | ETHANE | ETHYLENE | ACETYLENE | TOTAL<br>COMBUSTIBLE | TOTAL<br>GAS |
|------------|----------|--------|----------|---------|--------------------|-------------------|--------|----------|-----------|----------------------|--------------|
| 04/07/2017 | 21       | 16364  | 70694    | 3       | 38                 | 1068              | ND     | ND       | ND        | 62                   | 88188        |

ADDITIONAL EQUIPMENT

|                 |   |
|-----------------|---|
| RADIATORS       | - |
| FANS            | - |
| H2O COOLED      | - |
| OIL PUMPS       | - |
| TOP FPV         | - |
| BOTTOM FPV      | - |
| BUCHOLZ         | - |
| CONSERVATOR     | - |
| LTC COMPARTMENT | - |
| BUSHING LOC     | - |
| FREE BREATHER   | - |
| HOSE LENGTH     | - |
| POWER AVAILABLE | - |

WATER CONTENT (ASTM D1533), EXPRESSED IN PPM

| DATE       | TEMP°C | PPM | %M/dw | GRADE |
|------------|--------|-----|-------|-------|
| 04/07/2017 | 37     | 27  | 1.75  | D     |

FIELD SERVICE

| DATE | SERVICE |
|------|---------|
|------|---------|

RECOMMENDATION:  
RETEST 12 MONTHS:  
TEST RESULT INDICATES NORMAL OPERATION.

DATE PRINTED 25/07/2017

ID# - 601669

CUST - PT IP UJP PLTU  
JERANJANG

SUB NAME -  
CITY - MATARAM LOMBOK  
UNIT# - **TRAFO 3 ESP UNIT 3**

LOCATION - OUTDOOR  
OTHER -

NAMEPLATE DATA

|                   |                     |
|-------------------|---------------------|
| MFG               | - ZHEJIANG          |
| DATE MFG          | -                   |
| MAIN TANK S/N     | - <b>0072084208</b> |
| KVA               | -                   |
| PRI               | - 72000 V           |
| SEC               | - 415 V             |
| KILOGRAMS         | - 1350              |
| EQUIP TYPE        | - TRANSFORMER       |
| TRANS CLASS       | - ONAN              |
| IMPEDENCE         | -                   |
| PHASE/CYCLE       | - 3/50 Hz           |
| LIQUID TYPE       | - OIL               |
| LITRES LIQUID     | - 731               |
| LTC MFG           | -                   |
| LTC S/N           | -                   |
| LTC FAB NO        | -                   |
| LTC MODEL         | -                   |
| LTC LITRES LIQUID | -                   |
| LTC ENERGIZED     | -                   |

ADDITIONAL EQUIPMENT

|                 |   |
|-----------------|---|
| RADIATORS       | - |
| FANS            | - |
| H2O COOLED      | - |
| OIL PUMPS       | - |
| TOP FPV         | - |
| BOTTOM FPV      | - |
| BUCHOLZ         | - |
| CONSERVATOR     | - |
| LTC COMPARTMENT | - |
| BUSHING LOC     | - |
| FREE BREATHER   | - |
| HOSE LENGTH     | - |
| POWER AVAILABLE | - |

FURAN ANALYSIS (ASTM D5837), EXPRESSED IN PPB

|            |      |      |      |      |      |       |
|------------|------|------|------|------|------|-------|
| DATE       | 5H2F | 2FOL | 2FAL | 2ACF | 5M2F | TOTAL |
| 04/07/2017 | ND   | ND   | ND   | ND   | ND   | ND    |

RECOMMENDATION:  
RETEST 12 MONTHS:  
TEST RESULT OBTAINED IN THIS TEST IS IN LINE WITH A HEALTHY PAPER INSULATION OF TRANSFORMER.

METALS-IN-OIL (ASTM D3635), EXPRESSED IN PPM

|            |            |       |        |
|------------|------------|-------|--------|
| DATE       | ®ALUMINIUM | ®IRON | COPPER |
| 04/07/2017 | ND         | 0.01  | ND     |

LIQUID POWER FACTOR (ASTM D924)

|            |          |          |
|------------|----------|----------|
| DATE       | 25°C     | 100°C    |
| 04/07/2017 | 0.000 AC | 0.620 AC |

INHIBITOR CONTENT, DBPC (ASTM D2668)

|            |            |
|------------|------------|
| DATE       | %BY WEIGHT |
| 04/07/2017 | 0.01 UN    |

®CORROSIVE SULFUR (ASTM 1275B)

|            |         |       |               |
|------------|---------|-------|---------------|
| DATE       | STATUS  | CLASS | APPEARANCE    |
| 04/07/2017 | NON-COR | 2C    | LAVENDER BLUE |

®PASSIVATOR COUNT, EXPRESSED IN PPM

|      |     |
|------|-----|
| DATE | PPM |
|------|-----|

FIELD SERVICE

|      |         |
|------|---------|
| DATE | SERVICE |
|------|---------|