

DATE PRINTED 30/06/2017
ID# - 601692

CUST - PT PJB UBJOM
PLTU TENAYAN

SUB NAME - MAIN TRAF0
CITY - RIAU
UNIT# - UNIT-2

LOCATION - OUTDOOR
OTHER -

VISUAL INSPECTION

DATE STATUS OIL TEMP °C W. TEMP °C OIL LEVEL PAINT S. GEL LEAKS

LIQUID SCREEN TEST DATA

DATE	SERVICES	ASTM D974 ACID (mgKOH/gm)	ASTM D971 IFT (mN/m)	IEC 156 DIEL (kV)	ASTM D1500 COLOUR	ASTM D4052 SP. GR.	ASTM D1524 VISUAL	ASTM D1698 ® SEDIMENT
08/06/2017	ROUTINE	0.011 AC	45.5 AC	72 AC	0.5 AC	0.8033 QU	CLEAR AC	

DISSOLVED GAS ANALYSIS (ASTM D3612), EXPRESSED IN PPM

DATE	HYDROGEN	OXYGEN	NITROGEN	METHANE	CARBON MONOXIDE	CARBON DIOXIDE	ETHANE	ETHYLENE	ACETYLENE	TOTAL COMBUSTIBLE	TOTAL GAS
08/06/2017	8	13866	53753	ND	67	570	ND	ND	ND	75	68264

RECOMMENDATION:
RETEST 12 MONTHS:
TEST RESULT INDICATES NORMAL OPERATION.

NAMEPLATE DATA

MFG - CHONG QING AEA
DATE MFG - 2014
MAIN TANK S/N - 20120257
KVA - 125000
PRI - 150000 V
SEC - 13800 V
KILOGRAMS - 135000
EQUIP TYPE - TRANSFORMER
TRANS CLASS - OFAF
IMPEDENCE -
PHASE/CYCLE - 3/50 Hz
LIQUID TYPE - OIL
LITRES LIQUID - 32457

LTC MFG -
LTC S/N -
LTC FAB NO -
LTC MODEL -
LTC LITRES LIQUID -
LTC ENERGIZED -

ADDITIONAL EQUIPMENT

RADIATORS - YES
FANS -
H2O COOLED -
OIL PUMPS -
TOP FPV -
BOTTOM FPV -
BUCHOLZ -
CONSERVATOR - YES
LTC COMPARTMENT -
BUSHING LOC -
FREE BREATHER -
HOSE LENGTH -
POWER AVAILABLE -

WATER CONTENT (ASTM D1533), EXPRESSED IN PPM

DATE	TEMP°C	PPM	%M/dw	GRADE
08/06/2017	40	12	0.66	A

FIELD SERVICE
DATE SERVICE

DATE PRINTED 30/06/2017

ID# - 601692

CUST - PT PJB UBJOM
PLTU TENAYAN

SUB NAME - MAIN TRAF0
CITY - RIAU
UNIT# - UNIT-2

LOCATION - OUTDOOR
OTHER -

NAMEPLATE DATA

MFG - CHONG QING AEA
DATE MFG - 2014
MAIN TANK S/N - 20120257
KVA - 125000
PRI - 150000 V
SEC - 13800 V
KILOGRAMS - 135000
EQUIP TYPE - TRANSFORMER
TRANS CLASS - OFAF
IMPEDENCE -
PHASE/CYCLE - 3/50 Hz
LIQUID TYPE - OIL
LITRES LIQUID - 32457

LTC MFG -
LTC S/N -
LTC FAB NO -
LTC MODEL -
LTC LITRES LIQUID -
LTC ENERGIZED -

ADDITIONAL EQUIPMENT

RADIATORS - YES
FANS -
H2O COOLED -
OIL PUMPS -
TOP FPV -
BOTTOM FPV -
BUCHOLZ -
CONSERVATOR - YES
LTC COMPARTMENT -
BUSHING LOC -
FREE BREATHER -
HOSE LENGTH -
POWER AVAILABLE -

FURAN ANALYSIS (ASTM D5837), EXPRESSED IN PPB

DATE	5H2F	2FOL	2FAL	2ACF	5M2F	TOTAL
08/06/2017	ND	ND	ND	ND	ND	ND

RECOMMENDATION:
RETEST 12 MONTHS:
TEST RESULT OBTAINED IN THIS TEST IS IN LINE WITH A HEALTHY PAPER INSULATION OF TRANSFORMER.

METALS-IN-OIL (ASTM D3635), EXPRESSED IN PPM

DATE	ALUMINIUM	IRON	COPPER
08/06/2017	0.05	0.03	0.01

LIQUID POWER FACTOR (ASTM D924)

DATE	25°C	100°C
08/06/2017	0.000 AC	0.020 AC

INHIBITOR CONTENT, DBPC (ASTM D2668)

DATE	%BY WEIGHT
08/06/2017	0.26 AC

CORROSIVE SULFUR (ASTM 1275B)

DATE	STATUS	CLASS	APPEARANCE
08/06/2017	NON-COR	2E	BRASSY GOLD

PASSIVATOR COUNT, EXPRESSED IN PPM

DATE	PPM
------	-----

FIELD SERVICE

DATE	SERVICE
------	---------