

2014 PD Database Statistical Analysis

Air-cooled Capacitors

		PDA 6-9	PDA 10-12	PDA 13-15	PDA 16-18	PDA >19	BUS 2-5	BUS 6-9	BUS 10-12	BUS 13-15	BUS 16-18	BUS >=19
Negligible	< 25th	12	19	35	26	107	8	28	41	55	41	42
Low	< 50th	31	50	90	83	208	22	75	89	124	72	85
Typical	< 75th	72	114	190	218	698	65	177	196	265	157	165
Moderate	< 90th	184	245	373	543	886	243	353	385	529	310	504
High	< 95th	308	391	562	727	990	391	553	638	778	579	750

Air-cooled SSC - Slot PD

		11-15kV	>=16kV
Negligible	< 25th	0	0
Low	< 50th	15	1
Typical	< 75th	37	13
Moderate	< 90th	87	77
High	< 95th	119	122

Air-cooled SSC - EW PD

		11-15kV	>=16kV
Negligible	< 25th	0	0
Low	< 50th	0	0
Typical	< 75th	12	1
Moderate	< 90th	41	8
High	< 95th	64	22

Variable from 2010 results - be sure to comment in report

Variable from 2012 results - be sure to comment in report

Bus-Hydrogen-Cooled (TGA)

	Rated kV	13-15kV			16-18kV				>=19kV		
	H2 (psi)	11-20	21-30	>=31	11-20	21-30	31-50	>=51	21-30	31-50	>=51
Negligible	< 25th	33	20	16	17	34	24	9	43	23	9
Low	< 50th	91	46	43	81	86	43	18	89	55	28
Typical	< 75th	189	94	81	146	333	85	38	163	108	77
Moderate	< 90th	438	198	198	268	791	194	141	203	161	548
High	< 95th	756	393	485	389	976	307	322	229	206	951

SSC Slot-Hydrogen-Cooled (TGA)

	Rated kV	13-15kV			16-18kV			19-22kV			23-27kV	
	H2 (psi)	11-20	21-30	>=31	11-30	31-50	>=51	11-30	31-50	>=51	31-50	>=51
Negligible	< 25th	0	0	0	0	0	0	1	0	0	0	0
Low	< 50th	9	0	9	0	5	2	9	7	3	8	3
Typical	< 75th	31	14	17	13	15	10	23	19	11	31	9
Moderate	< 90th	48	66	32	58	22	24	97	41	25	66	18
High	< 95th	60	92	47	90	34	32	229	57	39	100	29

SSC EW-Hydrogen-Cooled (TGA)

	Rated kV	13-15kV			16-18kV			19-22kV			23-27kV	
	H2 (psi)	11-20	21-30	>=31	11-30	31-50	>=51	11-30	31-50	>=51	31-50	>=51
Negligible	< 25th	0	0	0	0	0	0	0	0	0	0	0
Low	< 50th	0	0	0	0	0	0	0	0	0	0	0
Typical	< 75th	0	0	4	0	2	0	1	1	4	0	0
Moderate	< 90th	20	9	10	14	12	9	9	11	16	3	6
High	< 95th	34	19	15	20	18	29	28	19	35	8	28