

|                                                                                   |                                                   |  |                |   |          |
|-----------------------------------------------------------------------------------|---------------------------------------------------|--|----------------|---|----------|
|  | PT.PLN INDONESIA POWER - PLTU JERANJANG 3 x 25 MW |  | No. Dokumen    | : |          |
|                                                                                   | INTEGRATED MANAGEMENT SYSTEM                      |  | Revisi         | : | 0        |
|                                                                                   | FORMULIR                                          |  | Tanggal terbit | : |          |
|                                                                                   | PENGUJIAN DGA                                     |  | Halaman        | : | 1 dari 1 |

|         |                       |
|---------|-----------------------|
| No. WO  |                       |
| Tanggal | 7/8/2026              |
| Lokasi  | Unit 2 PLTU Jeranjang |

#### 1. Spesifikasi

|             |                  |  |  |
|-------------|------------------|--|--|
| Name        | TRAFO ESP UNIT 2 |  |  |
| KKS         | -                |  |  |
| Manufacture | Ninas            |  |  |
| Type        | -                |  |  |

#### 2. Hasil Pengukuran

| No | Properties                    | Standart (ppm)            | Hasil pengujian |          |          |          | Keterangan |
|----|-------------------------------|---------------------------|-----------------|----------|----------|----------|------------|
|    |                               |                           | ESP 1           | ESP 2    | ESP 3    | ESP 4    |            |
|    |                               |                           | 7/8/2026        | 7/8/2026 | 7/8/2026 | 7/8/2026 |            |
| 1  | O <sub>2</sub>                | -                         | -               | -        |          |          |            |
| 2  | N <sub>2</sub>                | -                         | -               | -        |          |          |            |
| 3  | H <sub>2</sub> O              | 30                        | 23              | 24       | 25       | 25       |            |
| 4  | CO <sub>2</sub>               | 2500                      | 703             | 852      | 838      | 754      |            |
| 5  | CO                            | 350                       | 23              | 33       | 33       | 32       |            |
| 6  | H <sub>2</sub>                | 100                       | <5              | <5       | <5       | <5       |            |
| 7  | CH <sub>4</sub>               | 120                       | 3               | 6        | 3        | 6        |            |
| 8  | C <sub>2</sub> H <sub>6</sub> | 90                        | 4               | 7        | 6        | 9        |            |
| 9  | C <sub>2</sub> H <sub>4</sub> | 50                        | 7               | 8        | 8        | 9        |            |
| 10 | C <sub>2</sub> H <sub>2</sub> | 1                         | <0,5            | <0,5     | <0,5     | <0,5     |            |
| 11 | TDCG                          | 720                       | 42              | 60       | 55       | 61       |            |
| 12 | CONDITION                     | IEEE STD.<br>C57.104-2019 | COND 1          | COND 1   | COND 1   | COND 1   |            |

**Table 1—Dissolved gas concentrations**

| Status      | Dissolved key gas concentration limits [µL/L (ppm) <sup>a</sup> ] |                            |                                            |                                           |                                         |                      |                                   |                   |
|-------------|-------------------------------------------------------------------|----------------------------|--------------------------------------------|-------------------------------------------|-----------------------------------------|----------------------|-----------------------------------|-------------------|
|             | Hydrogen (H <sub>2</sub> )                                        | Methane (CH <sub>4</sub> ) | Acetylene (C <sub>2</sub> H <sub>2</sub> ) | Ethylene (C <sub>2</sub> H <sub>4</sub> ) | Ethane (C <sub>2</sub> H <sub>6</sub> ) | Carbon monoxide (CO) | Carbon dioxide (CO <sub>2</sub> ) | TDCG <sup>b</sup> |
| Condition 1 | 100                                                               | 120                        | 1                                          | 50                                        | 65                                      | 350                  | 2 500                             | 720               |
| Condition 2 | 101–700                                                           | 121–400                    | 2–9                                        | 51–100                                    | 66–100                                  | 351–570              | 2 500–4 000                       | 721–1920          |
| Condition 3 | 701–1800                                                          | 401–1000                   | 10–35                                      | 101–200                                   | 101–150                                 | 571–1400             | 4 001–10 000                      | 1921–4630         |
| Condition 4 | >1800                                                             | >1000                      | >35                                        | >200                                      | >150                                    | >1400                | >10 000                           | >4630             |

NOTE 1—Table 1 assumes that no previous tests on the transformer for dissolved gas analysis have been made or that no recent history exists. If a previous analysis exists, it should be reviewed to determine if the situation is stable or unstable. Refer to 6.5.2 for appropriate action(s) to be taken.

NOTE 2—An ASTM round-robin indicated variability in gas analysis between labs. This should be considered when having gas analysis made by different labs.

Analisa :

|                                                        |  |                                                       |  |                                                            |  |
|--------------------------------------------------------|--|-------------------------------------------------------|--|------------------------------------------------------------|--|
| Pengambil Sample<br>Tanggal : 08 Juli 2026<br>Budiawan |  | Penguji<br>Tanggal : 08 Juli 2026<br>Rizki Firmansyah |  | Mengetahui<br>Tanggal : 08 Juli 2026<br>Slamet Suprianto N |  |
|--------------------------------------------------------|--|-------------------------------------------------------|--|------------------------------------------------------------|--|