

	PT. PLN INDONESIA POWER	No. Dok : FORM-JRG.F.05.001
	UNIT BISNIS PEMBANGKITAN JERANJANG	Tgl Terbit : 1 Sep 2016
	BIDANG ENJINERING	Rev : 00
	LAPORAN PDM TEKNOLOGI VIBRASI	Hal :
HASIL PENGUKURAN PADA EQUIPMENT BULAN JANUARI 2026		

UNIT	LEVEL VIBRASI				
	LEVEL A	LEVEL B	LEVEL C	LEVEL D	STANDBY
UNIT 1	8	10	0	1	7
UNIT 2	3	10	1	0	4
UNIT 3	6	8	0	0	8
COAL HANDLING	3	7	1	3	0
TOTAL	20	35	2	4	19
PERSENTASE (%)	25%	44%	3%	5%	24%

KETERANGAN

A	Sangat halus (New machine condition)
B	Diperbolehkan beroperasi dalam jangka waktu lama yang tak terbatas (Unlimited long-term operation allowable)
C	Diperbolehkan beroperasi dalam jangka waktu singkat (Short-term operation allowable)
D	Bila dioperasikan mengakibatkan kerusakan yang lebih parah (Vibration causes damage)
E	Peralatan Stand By

