

		PT. PLN INDONESIA POWER																No. Dok		: FORM.JRG.F.05.001		
		UNIT BISNIS PEMBANGKITAN JERANJANG																Tgl Terbit		: 1 Sep 2016		
		BIDANG ENJINERING																Rev		: 00		
		LAPORAN PDM TEKNOLOGI VIBRASI																Hal		:		
HASIL PENGUKURAN PADA EQUIPMENT BULAN JANUARI 2026																						
NO	EQUIPMENT	CLASS / GROUP	POSISI																		VIB MAX	STATUS
			1V	1H	1A	2V	2H	2A	3V	3H	3A	4V	4H	4A	5V	5H	5A	6V	6H	6A		
UNIT 1																						
1	Motor ID Fan 1#1	GROUP 1	0.63	0.83	0.63	1.31	1.39	0.74	0.44	0.67	1.09	0.51	0.59	0.74	0.81	0.67	0.69	0.89	1.29	1.07	1.39	NORMAL
2	Motor ID Fan 2#1	GROUP 1	0.33	0.63	0.37	0.34	0.87	0.37	0.3	0.72	0.93	0.28	0.63	0.47	0.48	0.64	0.67	0.76	1.96	0.43	1.96	NORMAL
3	Motor Primary Air Fan 1#1	GROUP 1	0.64	2.43	1.08	1.36	1.52	1.23	1.96	1.99	2.29	2.99	2	2.36	NA	NA	NA	NA	NA	NA	2.99	PREWARNING
4	Motor Primary Air Fan 2#1	GROUP 1	0.86	1.49	0.86	1.15	1.56	1.16	0.72	0.81	0.54	0.62	1.59	0.58	NA	NA	NA	NA	NA	NA	1.59	NORMAL
5	Motor Secondary Air Fan 1#1	GROUP 1	0.42	2.06	0.62	0.63	1.65	0.6	0.4	1.34	0.64	0.49	0.89	0.42	NA	NA	NA	NA	NA	NA	2.06	NORMAL
6	Motor Secondary Air Fan 2#1	GROUP 1	2.75	3.42	2.9	3.76	7.31	2.99	1.09	4.01	2.87	5.23	5.83	3.48	NA	NA	NA	NA	NA	NA	7.31	ALARM
7	Turbin-Generator#1	GROUP 1	2.78	1.31	1.04	3.52	1.9	2.35	3.47	2.46	2.29	1.35	0.34	0.73	NA	NA	NA	NA	NA	NA	3.52	NORMAL
8	Motor Condensat Pump 1#1	GROUP 2	0.48	0.77	0	0.25	0.71	0.56	0.45	0.39	0.63	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.77	NORMAL
9	Motor Condensat Pump 2#1	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	0	STAND BY
10	Motor Vacuum Pump 1#1	GROUP 2	0.71	0.83	0.44	0.74	0.82	0.54	0.9	0.85	0.42	1.43	1.22	0.44	NA	NA	NA	NA	NA	NA	1.43	PREWARNING
11	Motor Vacuum Pump 2#1	GROUP 2	0.49	0.71	0.33	0.5	0.62	0.46	0.86	0.75	0.47	1.03	1.61	0.36	NA	NA	NA	NA	NA	NA	1.61	PREWARNING
12	Motor Boiler Feed Pump 1#1	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
13	Motor Boiler Feed Pump 2#1	GROUP 2	0.66	0.71	1.26	0.75	0.59	0.69	3.94	0.71	0.56	0.43	0.83	0.76	2.5	4.17	0.77	1.81	3.64	0.66	4.17	PREWARNING
14	Motor CCCWP 1#1	GROUP 2	2.51	2.51	NA	1.58	1.09	1.03	1.08	0.8	0.48	NA	NA	NA	NA	NA	NA	NA	NA	NA	2.51	PREWARNING
15	Motor CCCWP 2#1	GROUP 2	1.41	1.61	NA	0.49	0.54	0.52	0.75	0.38	0.33	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.61	PREWARNING
16	Motor CWP 355 Kw 1#1	GROUP 2	1.63	1.86	1.58	0.81	0.81	0.76	0.57	0.55	0.69	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.86	NORMAL
17	Motor CWP 355 Kw 2#1	GROUP 2	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
18	Motor BWRO 1#1	GROUP 2	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
19	Motor BWRO 2#1	GROUP 2	1.85	1.58	0	1.59	0.79	0.42	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.85	PREWARNING
20	Motor SWRO 1 #1	GROUP 2	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
21	Motor SWRO 2#1	GROUP 2	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
22	AC OIL PUMP UNIT 1	GROUP 2	0.61	1.07	0.39	0.52	1.04	0.37	0.84	0.97	0.34	0.66	0.61	0.54	NA	NA	NA	NA	NA	NA	1.07	NORMAL
23	DC OIL PUMP UNIT 1	GROUP 2	0.86	0.78	0.93	0.83	1.36	0.95	1.17	1.51	0.49	0.74	1.16	0.55	NA	NA	NA	NA	NA	NA	1.51	PREWARNING
24	DIESEL FIRE FIGHTING UNIT 1		6.56	5.65	6.93	10.25	9.45	8.43	5.54	2.75	4.36	4.42	3.14	4.72	NA	NA	NA	NA	NA	NA	10.25	PREWARNING
25	ELECTRIC FIRE FIGHTING UNIT 1	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	0	STAND BY
26	JOCKEY FIGHTING UNIT 1	GROUP 2	1.19	1.41	N/A	0.6	0.64	0.27	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.41	PREWARNING
UNIT 2																						
1	Motor ID Fan 1#2	GROUP 1	1.01	2.32	1	1.67	2.18	1.14	0.9	1.67	1.25	0.92	1.48	1	1.17	1.39	0.9	0.45	1.07	0.85	2.32	PREWARNING
2	Motor ID Fan 2#2	GROUP 1	0.88	0.97	0.9	1.42	1.22	0.76	0.55	0.76	2.34	0.48	0.63	1.91	0.59	0.89	0.65	0.87	0.73	1.64	2.34	PREWARNING
3	Motor Primary Air Fan 1#2	GROUP 1	0.47	1.56	1.03	0.89	1.3	0.62	0.93	1.46	0.82	1.58	2.32	1.1	NA	NA	NA	NA	NA	NA	2.32	PREWARNING
4	Motor Primary Air Fan 2#2	GROUP 1	0.91	2.95	1.1	1.7	2.59	0.83	0.75	2.32	1.44	2.16	2.63	1.14	NA	NA	NA	NA	NA	NA	2.95	PREWARNING
5	Motor Secondary Air Fan 1#2	GROUP 1	3.01	3	3.34	2.13	2.74	2.86	1.75	1.49	1.06	0.81	1.94	1.04	NA	NA	NA	NA	NA	NA	3.34	PREWARNING
6	Motor Secondary Air Fan 2#2	GROUP 1	1.36	1.27	1.2	0.34	2.59	0.84	1.18	1.73	1.01	0.85	1.3	0.97	NA	NA	NA	NA	NA	NA	2.59	PREWARNING
7	Turbin-Generator#2	GROUP 1	0	0	0	1.34	1.4	1.56	1.6	1.89	0.94	2.69	1.81	4.57	NA	NA	NA	NA	NA	NA	4.57	PREWARNING
8	Motor Condensat Pump 1#2	GROUP 2	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
9	Motor Condensat Pump 2#2	GROUP 2	3.75	2.42	0	1.23	0.88	0.79	0.5	0.51	0.91	NA	NA	NA	NA	NA	NA	NA	NA	NA	3.75	WARNING
10	Motor Vacuum Pump 1#2	GROUP 2	0.45	0.41	0.36	0.61	0.78	0.62	0.95	1.32	0.62	1.86	1.99	0.37	NA	NA	NA	NA	NA	NA	1.99	PREWARNING
11	Motor Vacuum Pump 2#2	GROUP 2	0.8	0.57	1.09	1.6	2.06	1.43	1.95	1.76	1.25	2.31	2.79	1.32	NA	NA	NA	NA	NA	NA	2.79	PREWARNING
12	Motor Boiler Feed Pump 1#2	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
13	Motor Boiler Feed Pump 2#2	GROUP 2	0.78	1.09	0.89	0.77	1.07	1.51	0.5	0.52	0.61	0.35	0.45	0.81	1.19	1.01	0.49	0.45	0.89	0.31	1.51	NORMAL
14	Motor CCCWP 1#2	GROUP 2	0	0	NA	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
15	Motor CCCWP 2#2	GROUP 2	1	0.9	NA	0.64	0.71	0.87	0.46	0.5	0.55	NA	NA	NA	NA	NA	NA	NA	NA	NA	1	NORMAL
16	Motor CCCWP 2C	GROUP 2	1.19	1.52	0.87	0.83	1.04	0.5	0.4	0.44	0.55	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.52	PREWARNING
17	Motor CWP 355 Kw 1#2	GROUP 2	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
18	Motor CWP 355 Kw 2#2	GROUP 2	0.82	1.07	0.55	1.39	0.44	1.4	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.4	NORMAL
19	AC OIL PUMP UNIT 2	GROUP 2	0.33	1.21	0.39	0.45	0.85	0.61	2.24	2.74	0.94	1.43	1.87	0.74	NA	NA	NA	NA	NA	NA	2.74	PREWARNING
20	DC OIL PUMP UNIT 2	GROUP 2	0.92	0.94	1.27	0.95	1.14	1.05	1.26	1.88	0.59	0.76	1.19	0.59	NA	NA	NA	NA	NA	NA	1.88	PREWARNING

		PT. PLN INDONESIA POWER																No. Dok : FORM.JRG.F.05.001				
		UNIT BISNIS PEMBANGKITAN JERANGJANG																Tgl Terbit : 1 Sep 2016				
		BIDANG ENJINERING																Rev : 00				
		LAPORAN PDM TEKNOLOGI VIBRASI																Hal :				
HASIL PENGUKURAN PADA EQUIPMENT BULAN JANUARI 2026																						
NO	EQUIPMENT	CLASS / GROUP	POSISI																		VIB MAX	STATUS
			1V	1H	1A	2V	2H	2A	3V	3H	3A	4V	4H	4A	5V	5H	5A	6V	6H	6A		
UNIT 3																						
1	Motor ID Fan 1#3	GROUP 1	0.57	0.75	0.81	0.87	0.57	0.35	0.66	1.09	0.38	0.44	1.13	0.28	NA	NA	NA	NA	NA	1.13	NORMAL	
2	Motor ID Fan 2#3	GROUP 1	0.3	0.5	0.46	0.45	0.58	0.41	0.33	0.47	0.33	0.52	0.68	0.32	NA	NA	NA	NA	NA	0.68	NORMAL	
3	Motor Primary Air Fan#3	GROUP 1	1.87	1.97	1.43	1.52	2.24	1.65	1.4	1.47	1.32	1.78	2.35	1.35	NA	NA	NA	NA	NA	2.35	NORMAL	
4	Motor Secondary Air Fan#3	GROUP 1	1.61	2.83	1.16	2.08	2.34	1.51	1.48	1.58	1.6	2.27	2.28	1.62	NA	NA	NA	NA	NA	2.83	PREWARNING	
5	Motor Recirculating Air Fan 1#3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY	
6	Motor Recirculating Air Fan 2#3	GROUP 2	1.19	1.33	0.89	0.8	1.32	0.91	2.36	3.2	2.66	2.24	2.99	2.57	2.18	2.97	2.52	2.14	2.7	2.36	3.2	PREWARNING
7	Turbin-Generator#3	GROUP 2	2.06	1.1	0.89	2.69	1.92	2.63	0.46	1.17	2.79	0.85	0.63	1.09	NA	NA	NA	NA	NA	2.79	NORMAL	
8	Motor Condensat Pump 1#3	GROUP 2	0.95	2.06	0.28	0.96	1.88	0.72	1.22	1.55	0.68	1.27	1.45	1.07	NA	NA	NA	NA	NA	2.06	PREWARNING	
9	Motor Condensat Pump 2#3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	0	STAND BY	
10	Motor Condensat Pump 3#3	GROUP 2	0.78	1.69	0.38	0.72	1.75	0.95	0.67	1.59	1	1.44	1.66	1.22	NA	NA	NA	NA	NA	1.75	PREWARNING	
11	Motor Water jet Pump 1#3	GROUP 2	0.69	1.33	0.24	0.88	1.3	0.68	0.8	0.99	0.54	0.97	0.88	0.67	NA	NA	NA	NA	NA	1.33	NORMAL	
12	Motor Water jet Pump 2#3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	0	STAND BY	
13	Motor Boiler Feed Pump 1#3	GROUP 1	0.65	1.68	1.15	0.85	1.25	1.15	0.91	1.94	1.51	0.74	1.8	1.18	0.67	0.97	0.22	0.98	0.88	0.27	1.94	NORMAL
14	Motor Boiler Feed Pump 2#3	GROUP 1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY	
15	Motor CCWP 1#3	GROUP 2	1	0.84	0.93	1.53	2.47	1.48	1.27	1.27	0.74	0.79	0.57	1.11	NA	NA	NA	NA	NA	2.47	PREWARNING	
16	Motor CCWP 2#3	GROUP 2	1.08	1.3	0.58	2	2.15	1.79	1.9	1.05	1.54	1.26	1.15	1.82	NA	NA	NA	NA	NA	2.15	PREWARNING	
17	Motor CWP 355 Kw 1#3	GROUP 1	3.68	2.79	2.42	2.04	1.45	2.46	1.06	1.16	1.66	NA	NA	NA	NA	NA	NA	NA	NA	3.68	PREWARNING	
18	Motor CWP 355 Kw 2#3	GROUP 1	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY	
19	Motor BWRO 1#3	GROUP 2	1.87	2.09	NA	0.5	0.6	0.38	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	2.09	PREWARNING	
20	Motor BWRO 2#3	GROUP 2	0	0	NA	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY	
21	Motor SWRO 1#3	GROUP 2	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY	
22	Motor SWRO 2#3	GROUP 2	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY	
24	Fire Fighting Jockey Pump 1	GROUP 2	0.79	0.95	0.53	0.47	0.46	0.49	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.95	NORMAL	
25	Fire Fighting Jockey Pump 2	GROUP 2	0.75	1.02	0.45	0.15	0.35	0.62	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.02	NORMAL	
26	Fire Fighting Pump With Motor	GROUP 2	0.69	0.98	0.23	1.36	1.19	0.93	1.09	1.35	1.06	0.95	1.52	1.09	NA	NA	NA	NA	NA	1.52	PREWARNING	
27	Fire Fighting Pump With Diesel		5.64	13.96	4.86	4.8	5.36	5.83	2.44	1.81	6.13	2.49	2.91	6.46	NA	NA	NA	NA	NA	13.96	WARNING	
28	AC Oil Pump Unit 3	GROUP 2	0.89	2.55	2.33	2.86	4.94	2.04	4.3	3.76	3.25	2.46	6.44	1.11	NA	NA	NA	NA	NA	6.44	ALARM	
29	DC Oil Pump Unit 3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	0	STAND BY	
30	Jacking Oil Pump 3A	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	0	STAND BY	
31	Jacking Oil Pump 3B	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	0	STAND BY	
COAL ASH HANDLING																						
1	BC 4.1	GROUP 2	1.28	2.55	1.43	2.03	2.61	1.84	1.62	1.61	1.6	1.2	1.79	1.27	1.68	1.39	1.93	1.76	1.43	1.64	2.61	PREWARNING
2	BC 4.2	GROUP 2	0.69	1.03	0.62	0.77	1.18	0.74	0.9	1.06	1.32	1.06	0.94	1.61	0.97	1.07	1.39	0.99	1.19	1.28	1.61	NORMAL
3	BC 5.1	GROUP 2	1.77	2.17	1.35	1.95	1.7	1.23	1.83	1.47	2.23	1.64	1.45	1.11	1.46	1.57	2.11	1.63	1.59	2.17	2.23	NORMAL
4	BC 5.2	GROUP 2	1.08	1.86	0.91	2.14	1.55	0.88	1.82	1.47	2.22	1.43	1.43	1.11	1.47	1.62	1.05	1.41	1.51	1	2.22	NORMAL
5	BC 7.1	GROUP 2	1.25	1.74	0.73	1.64	1.68	0.75	3.04	2.37	2.09	2.08	1.41	1.11	0.35	0.71	0.87	0.39	1	1.07	3.04	PREWARNING
6	BC 7.2	GROUP 2	4.41	3.36	3.52	8.81	7.61	4.2	1.88	2.31	7.51	1.78	2.16	7.03	0.45	0.77	1.09	0.41	0.57	1.07	8.81	ALARM
7	BC 8.1	GROUP 2	2.72	3.56	NA	2.36	2.82	2.47	1.44	1.67	2.79	1.86	2.89	2.42	1.08	1.07	0.34	1.08	1.02	0.29	3.56	PREWARNING
8	BC 8.2	GROUP 2	3.14	3.01	NA	1.87	2.37	1.57	1.95	1.95	1.64	1.95	1.78	1.95	1.73	1.91	0.61	1.07	1.34	0.58	3.14	PREWARNING
9	BC 10.1	GROUP 2	2.62	3.96	NA	1.47	3.3	2.75	1.45	1.53	NA	2.08	1.32	2.36	1.08	1.28	2.08	1.5	1.28	2.17	3.96	PREWARNING
10	BC 10.2	GROUP 2	2.59	1.7	NA	1.46	1.41	1.57	1.05	0.56	NA	1.31	0.66	1.13	2.04	0.67	0.95	2.04	0.58	0.79	2.59	PREWARNING
11	ROLLER SCREEN 1	GROUP 2	8.21	7.34	NA	5.5	4.78	4.36	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	8.21	ALARM	
12	ROLLER SCREEN 2	GROUP 2	6.43	6.77	NA	4.31	3.63	3.45	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	6.77	WARNING	
13	Motor Crusser 185kW 1	GROUP 2	2.64	5.71	1.62	4.27	6.33	1.69	4.55	7.83	7.4	5.54	6.73	9.42	NA	NA	NA	NA	NA	9.42	ALARM	
14	Motor Crusser 185kW 2	GROUP 2	2.19	5.25	1.57	2.57	5.63	2.67	1.76	5.73	4.34	3.57	3.01	5.29	NA	NA	NA	NA	NA	5.73	PREWARNING	