

		PT. PLN INDONESIA POWER																No. Dok : FORM.JRG.F.05.001				
		UNIT BISNIS PEMBANGKITAN JERANJANG																Tgl Terbit : 1 Sep 2016				
		BIDANG ENJINERING																Rev : 00				
		LAPORAN PDM TEKNOLOGI VIBRASI																Hal :				
HASIL PENGUKURAN PADA EQUIPMENT BULAN OKTOBER 2025																						
NO	EQUIPMENT	CLASS / GROUP	POSISI																		VIB MAX	STATUS
			1V	1H	1A	2V	2H	2A	3V	3H	3A	4V	4H	4A	5V	5H	5A	6V	6H	6A		
UNIT 1																						
1	Motor ID Fan 1#1	GROUP 1	0.76	0.8	0.74	1.52	1.46	0.8	0.41	0.66	1.14	0.59	0.67	0.72	0.89	0.6	0.77	0.73	1.29	0.92	1.52	NORMAL
2	Motor ID Fan 2#1	GROUP 1	0.36	0.94	0.42	0.61	1	0.37	0.49	0.78	0.99	0.26	0.79	0.48	0.59	0.88	0.67	0.61	2.34	0.43	2.34	PREWARNING
3	Motor Primary Air Fan 1#1	GROUP 1	1.09	2.58	1.58	1.43	1.6	1.8	2.66	2.3	2.86	3.94	2.51	2.87	NA	NA	NA	NA	NA	NA	3.94	PREWARNING
4	Motor Primary Air Fan 2#1	GROUP 1	0.59	1.22	0.74	1.13	1.19	0.96	0.45	0.86	0.4	0.55	1.37	0.39	NA	NA	NA	NA	NA	NA	1.37	NORMAL
5	Motor Secondary Air Fan 1#1	GROUP 1	0.63	2.46	0.65	0.53	2.09	0.57	0.64	1.36	0.65	0.83	1.2	0.63	NA	NA	NA	NA	NA	NA	2.46	PREWARNING
6	Motor Secondary Air Fan 2#1	GROUP 1	2.44	3.96	3.4	2.38	4.14	2.93	2.25	2.93	2.5	2.65	1.75	2.69	NA	NA	NA	NA	NA	NA	4.14	PREWARNING
7	Turbin-Generator#1	GROUP 1	3.41	1.34	1.09	2.53	1.38	1.32	2.96	2.33	1.05	1.35	0.69	0.79	NA	NA	NA	NA	NA	NA	3.41	NORMAL
8	Motor Condensat Pump 1#1	GROUP 2	0.63	0.55	0	0.38	0.26	0.55	0.42	0.21	0.58	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.63	NORMAL
9	Motor Condensat Pump 2#1	GROUP 2	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
10	Motor Vacuum Pump 1#1	GROUP 2	0.68	0.87	0.53	0.83	0.9	0.54	1.17	1.13	0.77	1.64	1.33	0.45	NA	NA	NA	NA	NA	NA	1.64	PREWARNING
11	Motor Vacuum Pump 2#1	GROUP 2	0.51	0.65	0.3	0.53	0.67	0.35	0.85	0.8	0.44	0.92	1.92	0.32	NA	NA	NA	NA	NA	NA	1.92	PREWARNING
12	Motor Boiler Feed Pump 1#1	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
13	Motor Boiler Feed Pump 2#1	GROUP 2	0.71	0.78	1.25	0.67	0.73	0.86	0.49	0.76	0.81	0.43	0.77	1.31	3.16	3.95	0.7	2	2.96	0.78	3.95	PREWARNING
14	Motor CCCWP 1#1	GROUP 2	1.61	2.72	NA	0.96	1.22	0.66	0.82	1.02	0.37	NA	NA	NA	NA	NA	NA	NA	NA	NA	2.72	PREWARNING
15	Motor CCCWP 2#1	GROUP 2	1.03	1.08	NA	0.56	0.47	0.58	0.62	0.44	0.33	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.08	NORMAL
16	Motor CWP 355 Kw 1#1	GROUP 2	1.22	1.58	1.45	0.6	0.54	0.45	0.49	0.44	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.58	NORMAL
17	Motor CWP 355 Kw 2#1	GROUP 2	0.58	1.43	0.93	0.43	0.79	0.46	0.31	0.35	0.4	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.43	NORMAL
18	Motor BWRO 1#1	GROUP 2	1.42	1.22	0	1.02	1.2	0.78	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.42	NORMAL
19	Motor BWRO 2#1	GROUP 2	1.72	1.46	0	0.77	1	0.51	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.72	PREWARNING
20	Motor SWRO 1 #1	GROUP 2	0.28	0.54	0.2	0.33	0.67	0.24	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.67	NORMAL
21	Motor SWRO 2#1	GROUP 2	0.47	1.03	0.15	0.33	1.29	0.13	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.29	NORMAL
22	AC OIL PUMP UNIT 1	GROUP 2	0.71	1.23	0.32	0.33	0.88	0.34	0.8	0.9	0.53	1.05	0.64	0.49	NA	NA	NA	NA	NA	NA	1.23	NORMAL
23	DC OIL PUMP UNIT 1	GROUP 2	0.84	0.79	0.89	0.81	1.27	0.84	1.17	1.59	0.47	0.89	1.23	0.53	NA	NA	NA	NA	NA	NA	1.59	PREWARNING
UNIT 2																						
1	Motor ID Fan 1#2	GROUP 1	0.99	1.9	1.16	1.65	2.14	1.26	1	1.54	2.69	1.69	1.73	2.16	1.38	1.58	1.28	0.98	1.41	1.04	2.69	PREWARNING
2	Motor ID Fan 2#2	GROUP 1	0.93	0.72	0.87	1.46	0.126	0.76	0.5	0.77	3.16	0.46	0.48	1.43	0.52	0.87	0.46	0.53	0.39	0.72	3.16	PREWARNING
3	Motor Primary Air Fan 1#2	GROUP 1	0.51	1.64	0.59	0.84	1.43	0.69	0.99	1.71	1.08	2.1	2.19	1.16	NA	NA	NA	NA	NA	NA	2.19	NORMAL
4	Motor Primary Air Fan 2#2	GROUP 1	0.58	0.23	1.06	1.6	2.26	1.06	0.72	2.34	1.06	1.23	1.73	0.96	NA	NA	NA	NA	NA	NA	2.34	PREWARNING
5	Motor Secondary Air Fan 1#2	GROUP 1	1.91	2.53	2.97	1.48	1.98	1.99	1.04	1.06	0.76	0.76	1.67	0.79	NA	NA	NA	NA	NA	NA	2.97	PREWARNING
6	Motor Secondary Air Fan 2#2	GROUP 1	1.4	2.83	1.06	0.36	2.45	0.8	1.02	1.48	0.95	0.71	1.3	1.03	NA	NA	NA	NA	NA	NA	2.83	PREWARNING
7	Turbin-Generator#2	GROUP 1	2.31	2.01	0.61	1.3	0.86	1.27	0.7	1.27	1.4	1.61	2.71	2.5	NA	NA	NA	NA	NA	NA	2.71	NORMAL
8	Motor Condensat Pump 1#2	GROUP 2	1.07	0.92	0	0.49	0.36	0.49	0.49	0.3	0.51	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.07	NORMAL
9	Motor Condensat Pump 2#2	GROUP 2	2.08	4.38	0	1.09	1.49	1.02	0.68	0.55	0.96	NA	NA	NA	NA	NA	NA	NA	NA	NA	4.38	WARNING
10	Motor Vacuum Pump 1#2	GROUP 2	0.5	0.48	0.29	0.62	0.8	0.48	0.89	1.1	0.54	1.22	1.87	0.48	NA	NA	NA	NA	NA	NA	1.87	PREWARNING
11	Motor Vacuum Pump 2#2	GROUP 2	0.78	0.76	1.13	1.48	1.77	1.48	1.91	2.1	1.14	2.47	2.62	1.23	NA	NA	NA	NA	NA	NA	2.62	PREWARNING
12	Motor Boiler Feed Pump 1#2	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
13	Motor Boiler Feed Pump 2#2	GROUP 2	0.54	0.73	0.92	0.68	0.76	1.76	0.36	0.5	0.56	0.31	0.38	0.91	1.13	1.16	0.46	0.41	0.86	0.4	1.76	NORMAL
14	Motor CCCWP 1#2	GROUP 2	2.33	0.89	NA	1.1	1.09	0.89	0.77	0.8	0.83	NA	NA	NA	NA	NA	NA	NA	NA	NA	2.33	PREWARNING
15	Motor CCCWP 2#2	GROUP 2	4.08	4.59	NA	2.74	2.51	1.75	1.34	2.17	0.56	NA	NA	NA	NA	NA	NA	NA	NA	NA	4.59	ALARM
16	Motor CWP 355 Kw 1#2	GROUP 2	2.04	3.12	1.63	0.73	0.99	0.8	0.38	0.42	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	3.12	PREWARNING
17	Motor CWP 355 Kw 2#2	GROUP 2	0.87	1.28	0.98	0.65	0.48	1.04	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.28	NORMAL
18	AC OIL PUMP UNIT 2	GROUP 2	0.36	1.51	0.53	0.43	0.94	0.26	1.56	2.16	0.68	0.88	1.65	0.72	NA	NA	NA	NA	NA	NA	2.16	PREWARNING
19	DC OIL PUMP UNIT 2	GROUP 2	0.86	1.14	1.3	1.02	1.36	1.29	1.04	2.16	0.58	0.84	1.36	0.56	NA	NA	NA	NA	NA	NA	2.16	PREWARNING

		PT. PLN INDONESIA POWER															No. Dok : FORM.JRG.F.05.001				
		UNIT BISNIS PEMBANGKITAN JERANGJANG															Tgl Terbit : 1 Sep 2016				
		BIDANG ENJINERING															Rev : 00				
		LAPORAN PDM TEKNOLOGI VIBRASI															Hal :				

HASIL PENGUKURAN PADA EQUIPMENT BULAN OKTOBER 2025																						
NO	EQUIPMENT	CLASS / GROUP	POSISI																		VIB MAX	STATUS
			1V	1H	1A	2V	2H	2A	3V	3H	3A	4V	4H	4A	5V	5H	5A	6V	6H	6A		
UNIT 3																						
1	Motor ID Fan 1#3	GROUP 1	0.66	0.72	0.82	0.97	0.63	0.44	0.95	1.2	0.45	0.5	1.24	0.36	NA	NA	NA	NA	NA	NA	1.24	NORMAL
2	Motor ID Fan 2#3	GROUP 1	0.25	0.4	0.73	0.46	0.6	0.4	0.23	0.37	0.34	0.36	0.5	0.24	NA	NA	NA	NA	NA	NA	0.73	NORMAL
3	Motor Primary Air Fan#3	GROUP 1	2.13	2.7	1.65	1.24	2.31	1.45	1.31	1.5	1.44	1.75	2.45	1.43	NA	NA	NA	NA	NA	NA	2.7	PREWARNING
4	Motor Secondary Air Fan#3	GROUP 1	1.52	2.43	1.62	1.29	2.13	1.07	1.42	1.49	1.52	2.16	2.35	1.48	NA	NA	NA	NA	NA	NA	2.43	PREWARNING
5	Motor Recirculating Air Fan 1#3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
6	Motor Recirculating Air Fan 2#3	GROUP 2	1.42	1.42	1.37	0.74	1.51	0.83	2.76	3.38	3.83	2.47	2.87	3.76	3.12	2.92	3.8	3.01	3.16	2.81	3.83	PREWARNING
7	Turbin-Generator#3	GROUP 2	3.96	1.24	0.76	0.371	2.59	3.58	0.52	1.5	3.67	0.95	0.66	0.77	NA	NA	NA	NA	NA	NA	3.96	PREWARNING
8	Motor Condensat Pump 1#3	GROUP 2	0.79	2.24	0.3	0.87	1.79	0.74	0.99	1.58	0.62	1.04	1.87	0.94	NA	NA	NA	NA	NA	NA	2.24	PREWARNING
9	Motor Condensat Pump 2#3	GROUP 2	1.74	2.23	0.57	2.34	2.48	2.16	1.16	2.72	0.7	1.46	2.75	2.15	NA	NA	NA	NA	NA	NA	2.75	PREWARNING
10	Motor Condensat Pump 3#3	GROUP 2	0.81	2.06	0.29	0.74	1.61	0.28	0.86	1.23	0.59	1.24	1.3	1.4	NA	NA	NA	NA	NA	NA	2.06	PREWARNING
11	Motor Water jet Pump 1#3	GROUP 2	1.39	1.2	0.28	0.96	1.32	0.3	0.77	1.15	0.37	0.83	0.87	0.63	NA	NA	NA	NA	NA	NA	1.39	NORMAL
12	Motor Water jet Pump 2#3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
13	Motor Boiler Feed Pump 1#3	GROUP 1	0.57	1.45	0.96	0.68	1.07	1.07	0.78	1.66	1.39	0.9	1.92	1.29	1.2	1.48	0.43	1.01	1.11	0.54	1.92	NORMAL
14	Motor Boiler Feed Pump 2#3	GROUP 1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
15	Motor CCWP 1#3	GROUP 2	1.01	1.35	0.95	1.52	1.87	1.31	1.48	1.46	1.01	0.81	0.57	1.37	NA	NA	NA	NA	NA	NA	1.87	PREWARNING
16	Motor CCWP 2#3	GROUP 2	1.12	2.21	0.63	2.13	2.29	1.56	1.96	1.22	1.55	1.57	0.63	2.09	NA	NA	NA	NA	NA	NA	2.29	PREWARNING
17	Motor CWP 355 Kw 1#3	GROUP 1	2.78	1.92	1.78	1.65	1.74	2.46	1.2	1	1.61	NA	NA	NA	NA	NA	NA	NA	NA	NA	2.78	PREWARNING
18	Motor CWP 355 Kw 2#3	GROUP 1	2.57	2.58	1.53	1.22	1.43	2.06	0.76	0.72	1.34	NA	NA	NA	NA	NA	NA	NA	NA	NA	2.58	PREWARNING
19	Motor BWRO 1#3	GROUP 2	0	0	NA	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
20	Motor BWRO 2#3	GROUP 2	0	0	NA	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
21	Motor SWRO 1#3	GROUP 2	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
22	Motor SWRO 2#3	GROUP 2	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	STAND BY
24	Fire Fighting Jockey Pump 1	GROUP 2	0.97	0.81	0.35	0.41	0.49	0.41	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.97	NORMAL
25	Fire Fighting Jockey Pump 2	GROUP 2	1.11	0.63	0.57	0.27	0.15	0.66	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	1.11	NORMAL
26	Fire Fighting Pump With Motor	GROUP 2	0.82	0.91	0.12	1.33	1.17	0.63	0.62	0.84	1.03	0.54	0.77	1.3	NA	NA	NA	NA	NA	NA	1.33	NORMAL
27	Fire Fighting Pump With Diesel		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	STAND BY
28	AC Oil Pump Unit 3	GROUP 2	2.17	2.19	2.73	2.26	1.79	2.38	2.45	2.41	2.25	2.18	3.15	1.61	NA	NA	NA	NA	NA	NA	3.15	WARNING
29	DC Oil Pump Unit 3	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	0	STAND BY
30	Jacking Oil Pump 3A	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	0	STAND BY
31	Jacking Oil Pump 3B	GROUP 2	0	0	0	0	0	0	0	0	0	0	0	0	NA	NA	NA	NA	NA	NA	0	STAND BY

COAL ASH HANDLING																						
1	BC 4.1	GROUP 2	1.19	2.68	1.37	2.1	2.95	1.98	1.79	1.59	1.65	1.2	2.01	1.28	2.02	2.39	3.22	1.99	2.47	3.41	3.41	PREWARNING
2	BC 4.2	GROUP 2	0.76	0.87	0.64	0.76	1.14	0.62	0.98	1.17	1.85	0.86	1.06	1.64	1.03	1.01	1.85	1.05	1.02	1.81	1.85	NORMAL
3	BC 5.1	GROUP 2	2.81	1.78	1.33	1.94	1.62	1.17	3.65	2.37	4.42	3.99	2.61	1.98	3.3	2.48	3.41	3.37	2.05	3.92	4.42	PREWARNING
4	BC 5.2	GROUP 2	0.98	1.7	1.5	1.34	2.26	1.08	1.84	1.65	2.17	1.38	1.41	1.08	1.49	1.04	1.19	1.43	1.04	1.17	2.26	NORMAL
5	BC 7.1	GROUP 2	0.98	1.44	0.68	1.55	1.56	0.64	2.73	1.91	2.47	2.47	1.27	0.82	0.29	0.54	0.28	0.31	0.58	0.3	2.73	PREWARNING
6	BC 7.2	GROUP 2	0.93	2.14	2.07	2.8	3.43	2.4	1.54	1.9	3.39	1.1	1.28	2.73	0.29	0.59	0.29	0.28	0.64	0.29	3.43	PREWARNING
7	BC 8.1	GROUP 2	2.85	4.38	NA	2.5	2.97	2.28	1.84	1.82	2.65	2.3	2.75	2.39	0.72	0.37	0.47	0.62	0.46	0.33	4.38	PREWARNING
8	BC 8.2	GROUP 2	3.25	3.12	NA	1.84	2.25	1.98	1.84	1.82	2.24	2.48	3.58	2.17	0.83	0.9	0.41	1.15	0.94	0.41	3.58	PREWARNING
9	BC 10.1	GROUP 2	2.27	3.68	NA	1.28	4.13	2.97	1.32	1.59	NA	1.41	1.1	2.55	1.25	0.59	0.64	1.65	0.48	0.62	4.13	PREWARNING
10	BC 10.2	GROUP 2	2.39	1.88	NA	1.68	1.81	1.55	0.98	0.52	NA	1.33	0.67	1.26	1.28	0.47	0.74	1.08	0.58	0.88	2.39	NORMAL
11	ROLLER SCREEN 1	GROUP 2	6.02	5.6	NA	4.67	4.07	4.07	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	6.02	PREWARNING
12	ROLLER SCREEN 2	GROUP 2	4.95	3.42	NA	2.89	2.41	2.44	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	4.95	PREWARNING
13	Motor Crusser 185kW 1	GROUP 2	1.59	6.98	1.23	2.04	6.41	1.23	3.45	6.35	3.81	3.55	4.43	5.41	NA	NA	NA	NA	NA	NA	6.98	PREWARNING
14	Motor Crusser 185kW 2	GROUP 2	0.92	0.545	0.41	1.74	3.85	1.12	1.94	4.67	1.61	1.55	2.21	2.99	NA	NA	NA	NA	NA	NA	4.67	PREWARNING