



CERTIFICATE OF SUPERVISION OF FINAL ASSESSMENT AND PRESSURE EQUIPMENT CHECKS AT RANDOM INTERVALS ACCORDING TO EUROPEAN DIRECTIVE 2014/68/EU (MODULE A2)

Certificate No.
10.07.12272

Date of initial Issue
26/11/2025

Valid From
26/11/2025

The Certificate is valid until
25/11/2026

Applicant/ Manufacturer (Name & Address)	Hexnovas Heat Exchanger Technology Co., Ltd No. 24, Xiangyang Road, Sanshipu Town, Jin'an District, Lu'an City, Anhui Province, China
Type of Pressure Equipment	Heat Exchanger
Technical Description of Pressure Equipment	Annex to this certificate
Category of Pressure Equipment	II
Number of Samples Assessed	4
Against the Provisions of	EUROPEAN PRESSURE EQUIPMENT DIRECTIVE 2014/68/EU, ANNEX III (MODULE A2)
Audit Report No.	10.07.12272.AR
Conditions & Limitations	According to the inspection results, the manufacturer is entitled to mark the pressure equipment manufactured within the range of this certificate. The manufacturer must affix the CE Marking and Eurocert's Identification No. to each item of pressure equipment as displayed below. Each pressure equipment should be accompanied with manufacturer's declaration of conformity and instructions of use.  1128



The data of this certificate were gathered with every possible thoroughness.
This certificate reflects the findings of the time and place of the audit.
Reproduction of this document is strictly forbidden.

Check the validity of the Certificate by scanning the QR code at right.
EUROCERT S.A. 89 Chlois & Lykovriseos str., 144 52, Metamorphosi – Greece
T +30 210 62.52.495, +30 210 62.53.927, F +30 210 62.03.018, M eurocert@otenet.gr



AT13.18/E03/14-02-2022



ANNEX TO CERTIFICATE No.: 10.07.12272

TECHNICAL DESCRIPTION OF HEAT EXCHANGERS

Item	Model	Volume/ L		Design pressure (bar)	Temperature (°C)	Standard
		Side I	Side II			
1	BH16	3.3	3.5	Max. 16	-50~250	GB/T 151: 2014
2	BH25	4.5	4.7			
3	BH45	7.2	7.2			
4	BH60	8.7	8.7			
5	BH88	11.5	11.5			
6	BH105	14.2	14.2			
7	BH120	23.1	23.1			
8	BH150	56.9	56.9			
9	BH200	77.6	77.6			
10	BH250	98.6	98.6			
11	BH300	119.5	119.5			
12	BH350	132.5	132.5			
13	BH450	155.5	155.5			
14	BH500	166.7	166.7			
15	BH650	189.2	189.2			



The data of this certificate were gathered with every possible thoroughness.
This certificate reflects the findings of the time and place of the audit.
Reproduction of this document is strictly forbidden.

Check the validity of the Certificate by scanning the QR code at right.
EUROCERT S.A. 89 Chlois & Lykovriseos str., 144 52, Metamorphosi – Greece
T +30 210 62.52.495, +30 210 62.53.927, F +30 210 62.03.018, M eurocert@otenet.gr



ΔΠ13.18/Ε03/14-02-2022