

Facilities Inspection Report

Riverside Hall · Block C · Quarterly cycle

1. Summary

This inspection covers the mechanical plant, the two passenger lifts and the roof-level plant room at Riverside Hall, Block C. It was carried out over a single morning, with the building in normal operation.

Seven items were raised. Four are routine and can be handled by the on-site team; three need a specialist visit. No item is classified as urgent, and the building remains fit for use. The next inspection is due in the following quarter, and the inspection record should be read alongside the maintenance log.

Outcome

Pass, with actions. 7 items raised · 0 urgent · 3 requiring a specialist visit.
Inspection reference RH-C-2609 · Recorded by the site maintenance team.

2. Equipment inventory

Plant recorded during the inspection, with the condition noted on the day.

Asset	Location	Condition
AHU-03	Roof plant room	Filters due
AHU-04	Roof plant room	Serviceable
LIFT-01	Core, north	Serviceable
LIFT-02	Core, south	Door sensor
PMP-11	Basement	Serviceable
PMP-12	Basement	Seal weeping
TANK-02	Roof plant room	Serviceable

3. Actions

1. Replace the supply filters on AHU-03 before the next inspection.
2. Adjust the door sensor on LIFT-02 and re-test the closing cycle.
3. Reseal the pump gland on PMP-12 and confirm there is no weeping.
4. Clear the stored items blocking the plant room access route.
5. Record the filter part numbers in the maintenance log.

Photograph of the roof plant room recorded during the inspection

4. Sign-off

Complete the field below and sign to confirm the actions have been reviewed. This page is the inspection record for the quarter.

Reviewer notes

Reviewed by

Date