

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
Directorate of I.P.M,P.H.Labs, Food (H) Administration, Narayanaguda.

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From: J R S School, # Sy.No:725, Korremula X road Narapally, Ghatkesar,
R R Dist.

2. Collected by: (Samples collected by Party)

3. Collected on : 27-06-2025

4. Received on: 27-06-2025

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total coliform bacteria (MPN Index) per 100ml	Faecal coliform bacteria per 100ml	Esch. coli per 100ml
7665	R.O water	Direct R.O Water		Nil		
7666	R.O water (TPC)	Direct R.O Water	Total Aerobic Bacterial Plate Count for 24 hrs at 37 ⁰ c = ≤1 CFU / ml			

Remarks: The above samples are bacteriologically satisfactory .

[Signature] 23/6/25
Dy. Chief Water Analyst
Institute of Preventive Medicine
Public Health Labs & Food (H) Admin.
Narayanaguda, Hyderabad-29, T.S

GOVERNMENT OF TELANGANA

DEPARTMENT OF WATER AND WASTE WATER EXAMINATION

Directorate of I.P.M,P.H.Labs, Food (H) Administration, Narayanaguda, Hyderabad – 29.

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample From	J R S School,	Collected by	(Samples collected by Party)
Address	# Sy.No:725, Korremula X road Narapally, Ghatkesar, R R Dist.	Collected on	27-06-2025
District	R R Dist.	Received on	27-06-2025
State	TS	Sample volume	2 ltr
Source profile	R.O Water	Sample ID	7667

S.No	Parameter	Source / Sample ID	Drinking Water -Specification As per IS 10500 :2012	
		R.O Water / 7667	Requirement (Acceptable)	Permissible limit in the absence of alternative source

Physical parameters

1	colour(Hazen),max	<5	5	15
2	Turbidity (NTU),max	1.41	1	5
3	Odour	UnObjectionable	UnObjectionable	UnObjectionable
4	Taste	Agreeable	Agreeable	Agreeable
5	p ^H	7.3	6.5 - 8.5	No relaxation
6	Electrical Conductivity at 25°C (Micro Mhos/cm)	196		
7	TDS(mg/L),max	128	500	2000

Chemical parameters (mg/L)

1	Alkalinity(as CaCO ₃) ,phenolphthalein ,max	Nil	...	...
2	Total alkalinity (as CaCO ₃) ,max	28	200	600
3	Total hardness (as CaCO ₃),max	64	200	600
4	Calcium hardness (as CaCO ₃),max	32		
5	Magnesium hardness (as CaCO ₃),max	32		
6	Calcium (as Ca),max	12.8	75	200
7	Magnesium (as Mg),max	7.8	30	100
8	Ammonical Nitrogen,max	Nil		
9	Nitrite(as N),max	Nil		
10	Nitrate(as N),max	Nil	45	No relaxation
11	Sulphate (as SO ₄),max	2	200	400
12	Chloride(as Cl),max	32	250	1000
13	Fluoride(as F),max	0.08	1.0	1.5
14	Iron (as Fe),max	Nil	0.3	No relaxation

Remarks: The given sample is physico chemically satisfactory .

Dy.Chief Water Analyst

*Institute of Preventive Medicine
Public Health Labs & Food (H) Admn.
Narayanaguda, Hyderabad-29, T.S.*