Periodic inspection findings

Lift no. LFT-59656

Address 68 Orchard Way, Westmere

Date 28/09/2026

Inspector Luis Vidal

Ref	Finding
F-01	building: Owner asks for an extra stop at the basement (qty 1)
F-02	floor 1: Hall position indicator, TFT colour loose (qty 4)
F-03	car top: Emergency telephone, GSM module broken (qty 1)
F-04	floor 8: Hall position indicator, dot-matrix corroded (qty 2)
F-05	pit: Governor rope, 8 mm loose (qty 70 m)
F-06	pit: TRAV CBL 24-CORE BRKN (qty 30 m)