Periodic inspection findings

Lift no. LFT-75789

Address 120 Larch Street, Eastbrook

Date 23/10/2026

Inspector Marta Rubio

Ref	Finding
F-01	machine room: Machine room lighting fitting damaged (qty 1)
F-02	machine room: Deflector pulley bearing worn (qty 2)
F-03	car top: Slack rope switch broken (qty 1)
F-04	machine room: Phase monitoring relay damaged (qty 1)
F-05	building: Graffiti on the car walls (qty 1)
F-06	car top: Alarm push button not working (qty 2)
F-07	floor 8: Landing door closer out of adjustment (qty 3)
F-08	machine room: Earthing conductor repair required (qty 1)
F-09	machine room: RESIDUAL CURRENT DEVICE DMGD (qty 1)
F-10	pit: Governor rope, 6 mm broken (qty 80 m)
F-11	pit: Shaft lighting fitting faulty (qty 4)
F-12	floor 8: LDG CALL BTN SINGLE WRN (qty 1)
F-13	car top: Final limit switch, lower broken (qty 2)
F-14	pit: Pit ladder loose (qty 1)