GP3201-G41-PA081-000007

CONFIDENTIAL: THIS DRAWING IS THE PROPERTY OF RELIANCE INDUSTRIES LIMITED AND ISSUED FOR USE IN ACCORDANCE WITH THE CONTRACT. IT SHALL NOT BE REPRODUCED, LOANED, EXHIBITED OR DISCLOSED WITHOUT WRITTEN PERMISSION OF RIL.

NOTES

GENERAL NOTES:

1. FOR GENERAL NOTES & LEGEND REFER DRAWINGS GP3201-G11-PA081-050001 TO GP3201-G11-PA081-050008.
2. INSTRUMENT TAG NUMBER ON THIS DRAWING ARE TO BE PREFIXED WITH "081".
3. ELEVATION 100.5M CORRESOPOND TO FGL.
4. DELETED.

NOTES:

1. TO BE ROUTED TO NEAREST TRENCH.
2. DEVIATION ALARM SHALL BE GENERATED IN DCS WHENEVER 2 NOS. OF LEVEL TRANSMITTERS ARE PROVIDED ON THE SAME TANK/VESSEL & THE DIFFERENCE BETWEEN THEIR MEASURED VALUES ARE BEYOND LIMIT.
3. REFER DRAWING GP3201-G11-PA081-050007 FOR PUMP MOTOR DETAILS.
4. MOTOR TO BE SELECTED FOR END OF CURVE OPERATION.
5. PROVIDE STRUCTURE FOR AGITATOR, MAINTENANCE.
6. XV-000001 AND XV-000010 OPENING TO BE RESET AFTER RECEIPT OF LOW LEVEL SIGNAL FROM LT-000003 AND LT-000004 RESPECTIVELY.
7. TO BE INSTALLED IN VERTICAL PIPING.
8. REFER SELECTOR SWITCH TABLE FOR DETAILS.
9. REFER DETAILED P&ID (G23P05-D1GPA-MHH001-TEM-P-03) FOR SODA ASH HANDLING SYSTEM.
10. PG SHALL BE INSTALLED AT THE MECHANICAL SEAL OUTLET BEFORE THE ISOLATION VALVE IN PUMP SEAL PLAN. ISOLATION VALVE IS IN VENDOR SCOPE.

HOLDS:

1. DELETED.
2. DELETED.
3. SIZE IS UNDER HOLD & SIZES TO BE UPDATED BASED ON THE VENDOR INPUTS

ALARM/INTERLOCK SCHEDULE

INTERLOCK NO.	INSTRUMENT NO.	INTERLOCK DESCRIPTION	ACTION
I-000008	XV-000001	AT OPEN POSITION 04	CLOSE XV-000010
I-000009	LT-000003	AT LOW LOW LEVEL	TRIP AGITATOR A000071A
I-000010	LT-000003	AT HIGH LEVEL	CLOSE VALVE XV-000001
I-000011	LT-000003	AT LOW LOW LOW LEVEL	TRIP PUMP P000071A/B
I-000012	LT-000004	AT LOW LOW LEVEL	TRIP AGITATOR A000071B
I-000013	LT-000004	AT HIGH LEVEL	CLOSE VALVE XV-000010
I-000014	LT-000004	AT LOW LOW LOW LEVEL	TRIP PUMP P000071A/B
I-000015	LT-000006	AT HIGH LEVEL	TRIP PUMP P000071A/B
I-000016	LT-000006	AT LOW LOW LEVEL	TRIP AGITATOR A000070
I-000017	LT-000006	AT LOW LOW LOW LEVEL	TRIP PUMP P000070A/B
I-000058	XV-000010	AT OPEN POSITION	CLOSE XV-000001

SELECTOR SWITCH DESCRIPTION

NO	SWITCH NO.	P&ID	SELECTION	EFFECT
1.	S-000002	GP3201-G41-PA081-000007	SELECTION OF T000071 A/B	ACTIVATION OF ALL ASSOCIATED INTERLOCKS OF T000071A OR T000071B

REV	DATE	REVISION	BY	CHECK	APPD.	HOD	PROJ ENG	PMT
04	06 Oct 25	ISSUED FOR CONSTRUCTION	SBD	TSB	MPB	SN	MPB	MPG
03	20 Mar 25	RE-ISSUED FOR DESIGN	ANS	VKB	MPB	SN	MPB	VRK
02	26 Sep 24	ISSUED FOR DESIGN	CSL	TSB	MPB	SN	MPB	AJ
01	15 Aug 24	ISSUED FOR HAZOP	ANS	TSB	MPB	SN	MPB	AJ
00	20 Jun 24	ISSUED FOR REVIEW	ASK	TSB	MPB	SN	MPB	AJ

TATA CONSULTING ENGINEERS LIMITED
MUMBAI

JOB IDENTIFIER: G23P05 | MOC NO: NA

Reliance

RELIANCE INDUSTRIES LIMITED
DAHEJ MANUFACTURING DIVISION

BECHTEL

PMC : BNT Offshore Solutions, Inc.

PROJECT :
VINYLS PROGRAM
CHLOR ALKALI (1035 KTA CHLORINE)

DRAWING TITLE:
PIPING AND INSTRUMENTATION DIAGRAM
PRIMARY BRINE PURIFICATION
(SODA ASH PREPARATION)

SCALE	PROJECT NO.	DRAWING NO.	REV.
NTS	GP3201	GP3201-G41-PA081-000007	04

MS-PA081-000072
SODA ASH HANDLING SYSTEM

PA081-WCS-000730-XX"-RC12ABDR-NI
FROM HEADER
5689 900002 SHT1
COOLING WATER SUPPLY
HOLD-3

PA081-WCR-000731-XX"-RC12ABDR-NI
HOLD-3
COOLING WATER RETURN
5585 900002 SHT1
TO HEADER

PA081-CH-000723-2"-RP1092DRP-NI
SODA ASH
705 000008
TO REACTOR R010020

PA081-CH-000724-2"-RP1092DRP-NI
SODA ASH
708 000009
TO REACTOR R020020

PA081-CH-000725-2"-RP1092DRP-NI
SODA ASH
706 000010
TO REACTOR R030020

DEMINERALIZED WATER
721 900004 SHT2
FROM HEADER
DEMINERALIZED WATER
5871 900004 SHT2
FROM HEADER
PA081-WA-000712-4"-RV12EKFR-NI

PA081-WA-000718-4"-RV12EKFR-NI
DEMINERALIZED WATER
900004 SHT2 5872
FROM HEADER
PA081-WA-900470-2"-RV12EKFR-NI

RETURN BRINE
718 200019 SHT1
FROM RETURN BRINE PUMP P200080A/B/C
PA081-BRR-201915-6"-RP1092DRP-NI
PA081-BRR-000915-6"-RP1092DRP-NI
PA081-BRR-000713-6"-RP1092DRP-NI
PA081-CH-000717-4"-RP1092DRP-NI

PA081-CH-000792-4"-RP1092DRP-NI
PA081-CH-000727-2"-RP1092DRP-NI
PA081-CH-000719-4"-RP1092DRP-NI
PA081-CH-000711-8"-RP1092DRP-NI
PA081-CH-000780-6"-RP1092DRP-NI
PA081-CH-000777-10"-RP1092DRP-NI
PA081-CH-000772-10"-RP1092DRP-NI
PA081-CH-000708-10"-RP1092DRP-NI
PA081-CH-000781-6"-RP1092DRP-NI
PA081-CH-000709-10"-RP1092DRP-NI
PA081-CH-000721-4"-RP1092DRP-NI
PA081-CH-000722-4"-RP1092DRP-NI
PA081-CH-000790-4"-RP1092DRP-NI
PA081-CH-000773-10"-RP1092DRP-NI

PA081-WA-000760-1"-RV12EKFR-NI
PA081-WA-000761-1"-RV12EKFR-NI
PA081-WA-000765-1"-RV12EKFR-NI
PA081-WA-000766-1"-RV12EKFR-NI
PA081-WA-000767-1"-RV12EKFR-NI
PA081-WA-000768-1"-RV12EKFR-NI
PA081-WA-000763-1"-RV12EKFR-NI
PA081-WA-000764-1"-RV12EKFR-NI
PA081-WA-000762-2"-RV12EKFR-NI

PA081-CH-000726-3"-RP1092DRP-NI

NOTE-9

D-071A
MT-PA081-T000071A
SODA ASH PREPARATION TANK
A-071A
MF-PA081-A000071A
SODA ASH PREPARATION TANK AGITATOR
MF-PA081-M000071A
SODA ASH PREPARATION TANK AGITATOR MOTOR

D-071B
MT-PA081-T000071B
SODA ASH PREPARATION TANK
A-071B
MF-PA081-A000071B
SODA ASH PREPARATION TANK AGITATOR
MF-PA081-M000071B
SODA ASH PREPARATION TANK AGITATOR MOTOR

D-070
MT-PA081-T000070
SODA ASH TANK
A-070
MF-PA081-A000070
SODA ASH TANK AGITATOR
MF-PA081-M000070
SODA ASH TANK AGITATOR MOTOR

P-071A
MP-PA081-P000071A
SODA ASH PREPARATION PUMP
MP-PA081-M000071A
SODA ASH PREPARATION PUMP MOTOR

P-071B
MP-PA081-P000071B
SODA ASH PREPARATION PUMP
MP-PA081-M000071B
SODA ASH PREPARATION PUMP MOTOR

P-070A
MP-PA081-P000070A
SODA ASH PUMP
MP-PA081-M000070A
SODA ASH PUMP MOTOR

P-070B
MP-PA081-P000070B
SODA ASH PUMP
MP-PA081-M000070B
SODA ASH PUMP MOTOR

TAG: MT-PA081-T000071A/B	
SERVICE: SODA ASH PREPARATION TANK	
ID X HEIGHT (mm)	9000 X 11200
NOMINAL CAPACITY (m3)	712
DESIGN PRESS.MAX (kg/cm2g)	FULL LIQUID
DESIGN TEMP. MIN / MAX (°C)	5.8 / 60
INSULATION / INSULATION THK. (mm)	-/ -
MOC: SA36 + HRL	
TRIM: PA081-CH-000791-4"-RP1092DRP-NI	

TAG: MT-PA081-T000070	
SERVICE: SODA ASH TANK	
ID X HEIGHT (mm)	9000 X 9800
NOMINAL CAPACITY (m3)	624
DESIGN PRESS.MAX (kg/cm2g)	FULL LIQUID
DESIGN TEMP. MIN / MAX (°C)	5.8 / 60
INSULATION / INSULATION THK. (mm)	/
MOC: SA36 + HRL	
TRIM: PA081-CH-000792-4"-RP1092DRP-NI	

TAG: MP-PA081-P000071A/B	
SERVICE: SODA ASH PREPARATION PUMP	
RATED CAPACITY (m3 /hr)	130
DIFFERENTIAL PRESS. (Kg/cm2g)	2.32
DRIVER POWER (kW)	30
INSULATION / INSULATION THK. (mm)	/
TRIM: RP1092DRP	
MOC: CD4MCU	

TAG: MP-PA081-P000070A/B	
SERVICE: SODA ASH PUMP	
RATED CAPACITY (m3 /hr)	30
DIFFERENTIAL PRESS. (Kg/cm2g)	3.67
DRIVER POWER (kW)	15
INSULATION / INSULATION THK. (mm)	/
TRIM: RP1092DRP	
MOC: CD4MCU	

TAG:MF-PA081-A000071A/B
SERVICE:SODA ASH PREPARATION TANK AGITATOR
DRIVER RATED POWER (kw): 90.00 kW

TAG:MF-PA081-A000070
SERVICE:SODA ASH TANK AGITATOR
DRIVER RATED POWER (kw): 90.00 kW