

DESCRIPTION : 1100 VOLT GRADE CIRCULAR STRANDED ANNEALED BARE COPPER CONDUCTOR, XLPE INSULATED, FRLS PVC TYPE ST-2 SHEATHED, ARMoured POWER CABLES CONFIRMING TO IS : 7098 (PART-1) 1988 WITH LATEST AMMENDMENTS AND THIS DATA SHEET.

S. No.	DISCRPTION	UNIT	2 CORE X 1.5 SQ.MM	7 CORE X 1.5 SQ.MM	16 CORE X 1.5 SQ.MM	3 CORE X 2.5 SQ.MM
1	CABLE TYPE		Circular Stranded Annealed Bare Copper Conductor, XLPE Insulated, PVC Type ST-2 Inner Sheathed, Armoured, FRLS PVC Type ST-2 Sheathed Power Cable			
2	NAME OF THE MANUFACTURER		M/s POLYVION CABLES PVT. LTD.			
3	BRAND NAME		POLYCORE			
4	APPLICABLE STANDARDS		IS : 7098 (Part-1) 1988, IS : 8130/2013 & This Data Sheet.			
5	VOLTAGE GRADE	VOLTS	1100V			
6	NO. OF CORES	NOS.	2 Core	7 Core	16 Core	3 Core
7	CONDUCTOR					
8	Material		High Conductivity Electrolyte Grade Circular Stranded Annealed Bare Copper Conductor Conf. To IS : 8130/2013			
9	Size	Sq.mm	1.5			2.5
10	No. of Strands	Nos.	7			
11	Shape of Conductor		Circular Stranded Annealed Bare Copper Conductor Class - 2			
12	Temperature Rise on Normal Condition	Deg. C	90 ⁰ C			
13	Temperature Rise on Short Circuit Condition	Deg. C	250 ⁰ C			
14	INSULATION					
15	Material		XLPE Compound Conf. To IS : 7098 (Part-1) 1988			
16	Type		Extruded XLPE			
17	Thickness (Nom. / Min.)	mm	0.70 / 0.53			
18	Core Identification		Red & Black	All Cores Grey Colour With No. Printing On Each Cores For Core Identification		Red, Yellow & Blue
19	INNER SHEATH					
20	Materials		Extruded PVC TYPE ST-2 Conf. to IS : 5831/84			
21	Type		Extruded PVC			
22	Thickness (Min.)	mm	0.30			
23	Colour		Black			
24	ARMOURING					
25	Material		Galvanised Round Wire		Galvanised Steel Flat Formed Wire	Galvanised Round Wire
26	Dimension	mm	1.40 ± 0.040		4.00 X 0.80 ± 10%	1.40 ± 0.040
27	OUTER SHEATH					
28	Material		Extruded FRLS PVC TYPE ST-2 Conf. to IS : 5831/84			
29	Type		Extruded FRLS PVC			
30	Thickness (Min.)	mm	1.24		1.40	1.24
31	Overall Diameter of Cable *	mm	12.00	14.00	18.00	13.00
32	Colour Of Outer Sheath		Black			
33	Printing On Outer Sheath		Manufacturer's name, Year of manufacture, Voltage Grade and Size of cable (i.e., No. Of Core x Size) FRLS Sequential Length Marking shall be printed on outer sheath of cable at every 1 mtr interval .			
34	Standard Drum Length (Packing shall be done in non-returnable wooden drum)	meter	1000 Mtrs. ±5 % Tolerance			
35	ELECTRICAL PARAMETERS					
36	Max. DC resistance of conductor of completed cable at 20°C	ohm / km	12.10			7.41
37	High Voltage Test	kV rms	3.0 kV. (rms) for 5 minutes Core to Core / Armour Each Connection			
38	TEST ON FRLS					
a	Oxygen Index Test (Min)	%	29			
b	Temperature Index Test (Min.)	Deg. C	250			
c	Smoke Density Test Rating (Max.)	%	60			
d	Acid Gas Emission	%	20 (By Weight)			
39	Flammability Test	Sec / mm	Period of burning after of removal flame max time (60 Sec.) , Unaffected Portion of cable min (50 mm)			

*OD of cable is calculated and given for reference purpose, actual OD of cable will vary, variation tolerance 10 To 15%

Note:- The values given above are subject to tolerances as per the relevant standards.

FOR :- M/S - POLYVION CABLES PVT. LTD.

