

DESCRIPTION : 1100 VOLTAGE GRADE CIRCULAR STRANDED ANNEALED BARE COPPER CONDUCTOR, XLPE INSULATED, PVC TYPE ST-2 SHEATHED, ARMoured CABLES CONFIRMING TO IS : 7098 (Part-1)/2025 AND THIS DATA SHEET.

SR. No.	DISCRIPTION	UNIT	2 CORE X 1.5 SQ.MM	3 CORE X 1.5 SQ.MM
1	CABLE TYPE		Circular Stranded Annealed Bare Copper Conductor Class - 2, XLPE Insulated, PVC Type ST-2 Inner Sheathed, Armoured, PVC Type ST-2 Sheathed Cable.	
2	NAME OF THE MANUFACTURER		M/s POLYVION CABLES PVT. LTD.	
3	BRAND NAME		POLYCORE	
4	APPLICABLE STANDARDS		IS : 7098 (Part-1)/2025, IS : 8130/2013 & This Data Sheet.	
5	VOLTAGE GRADE	VOLTS	1100 Volt	
6	NO. OF CORES	NOS.	2 Core	3 Core
7	CONDUCTOR			
8	Material		High Conductivity Electrolyte Grade Annealed Bare Circular Copper Conductor Conf. To IS : 8130/2013	
9	Size	Sq.mm	1.5	
10	No. of Strands	Nos.	7	
11	Shape of Conductor		Circular Stranded Annealed Bare Copper Conductor	
12	Temperature Rise on Normal Condition	Deg. C	90°C	
13	Temperature Rise on Short Circuit Condition	Deg. C	250°C	
14	INSULATION			
15	Material		XLPE Compound Conf. To IS : 7098 (Part-1)/2025	
16	Type		Extruded XLPE	
17	Thickness (Nom.)	mm	0.70	
18	Core Identification		Red & Black	Red, Yellow & Blue
19	INNER SHEATH			
20	Materials		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84	
21	Type		Extruded PVC	
22	Thickness (Min.)	mm	0.30	
23	Colour		Black	
24	ARMOURING			
25	Material		Galvanised Steel Round Wire	
26	Dimension	mm	1.40 mm ± 0.040 mm	
27	OUTER SHEATH			
28	Material		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84	
29	Type		Extruded PVC	
30	Thickness (Min.)	mm	1.24	
31	Overall Diameter of Cable *	mm	12.00	12.50
32	Colour Of Outer Sheath		Black	
33	Printing On Outer Sheath		Manufacturer's name, Year of manufacture, Voltage Grade and Size of cable, Sequential Length Marking shall be printed on outer sheath of cable at every 1 mtr interval .	
34	Standard Drum Length (Packing shall be done in non-returnable wooden drum)	meter	1000 Mtrs. +2 % Tolerance	
35	ELECTRICAL PARAMETERS			
36	Max. DC resistance of conductor of completed cable at 20°C	ohm / km	12.10	
37	High Voltage Test	kV rms	3.0 kV. (rms) for 5 minutes	
38	Flammability Test As Per IS : 10810 (Part-53)	Sec / mm	Period of burning after removal of flame max time (60 Sec.) , Unaffected Portion of cable min (50 mm)	

Note - * OD of cable is calculated and given for reference purpose, actual OD of cable will vary, Variation Tolerance 10 To 15 %

Note:- The values given above are subject to tolerances as per the relevant standards.

FOR :- M/S - POLYVION CABLES PVT. LTD.



DESCRIPTION : 1100 VOLTAGE GRADE CIRCULAR STRANDED ANNEALED BARE COPPER CONDUCTOR, XLPE INSULATED, PVC TYPE ST-2 SHEATHED, ARMoured CABLES CONFIRMING TO IS : 7098 (Part-1)/2025 AND THIS DATA SHEET.

SR. No.	DISCRPTION	UNIT	4 CORE X 1.5 SQ.MM
1	CABLE TYPE		Circular Stranded Annealed Bare Copper Conductor Class - 2, XLPE Insulated, PVC Type ST-2 Inner Sheathed, Armoured, PVC Type ST-2 Sheathed Cable.
2	NAME OF THE MANUFACTURER		M/s POLYVION CABLES PVT. LTD.
3	BRAND NAME		POLYCORE
4	APPLICABLE STANDARDS		IS : 7098 (Part-1)/2025, IS : 8130/2013 & This Data Sheet.
5	VOLTAGE GRADE	VOLTS	1100 Volt
6	NO. OF CORES	NOS.	4 Core
7	CONDUCTOR		
8	Material		High Conductivity Electrolyte Grade Annealed Bare Circular Copper Conductor Conf. To IS : 8130/2013
9	Size	Sq.mm	1.5
10	No. of Strands	Nos.	7
11	Shape of Conductor		Circular Stranded Annealed Bare Copper Conductor
12	Temperature Rise on Normal Condition	Deg. C	90°C
13	Temperature Rise on Short Circuit Condition	Deg. C	250°C
14	INSULATION		
15	Material		XLPE Compound Conf. To IS : 7098 (Part-1)/2025
16	Type		Extruded XLPE
17	Thickness (Nom.)	mm	0.70
18	Core Identification		Red, Yellow, Blue & Black
19	INNER SHEATH		
20	Materials		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84
21	Type		Extruded PVC
22	Thickness (Min.)	mm	0.30
23	Colour		Black
24	ARMOURING		
25	Material		Galvanised Steel Round Wire
26	Dimension	mm	1.40 mm ± 0.040 mm
27	OUTER SHEATH		
28	Material		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84
29	Type		Extruded PVC
30	Thickness (Min.)	mm	1.24
31	Overall Diameter of Cable *	mm	13.50
32	Colour Of Outer Sheath		Black
33	Printing On Outer Sheath		Manufacturer's name, Year of manufacture, Voltage Grade and Size of cable, Sequential Length Marking shall be printed on outer sheath of cable at every 1 mtr interval .
34	Standard Drum Length (Packing shall be done in non-returnable wooden drum)	meter	1000 Mtrs. +2 % Tolerance
35	ELECTRICAL PARAMETERS		
36	Max. DC resistance of conductor of completed cable at 20°C	ohm / km	12.10
37	High Voltage Test	kV rms	3.0 kV. (rms) for 5 minutes
38	Flammability Test As Per IS : 10810 (Part-53)	Sec / mm	Period of burning after removal of flame max time (60 Sec.) , Unaffected Portion of cable min (50 mm)

Note - * OD of cable is calculated and given for reference purpose, actual OD of cable will vary, Variation Tolerance 10 To 15 %

Note:- The values given above are subject to tolerances as per the relevant standards.

FOR :- M/S - POLYVION CABLES PVT. LTD.



DESCRIPTION : 1100 VOLTAGE GRADE CIRCULAR STRANDED ANNEALED BARE COPPER CONDUCTOR, XLPE INSULATED, PVC TYPE ST-2 SHEATHED, ARMoured CABLES CONFIRMING TO IS : 7098 (Part-1)/2025 AND THIS DATA SHEET.

Sr. No.	DISCRIPTION	UNIT	14 CORE X 1.5 SQ.MM	24 CORE X 1.5 SQ.MM
1	CABLE TYPE		Circular Stranded Annealed Bare Copper Conductor Class - 2, XLPE Insulated, PVC Type ST-2 Inner Sheathed, Armoured, PVC Type ST-2 Sheathed Cable.	
2	NAME OF THE MANUFACTURER		M/s POLYVION CABLES PVT. LTD.	
3	BRAND NAME		POLYCORE	
4	APPLICABLE STANDARDS		IS : 7098 (Part-1)/2025, IS : 8130/2013 & This Data Sheet.	
5	VOLTAGE GRADE	VOLTS	1100 Volt	
6	NO. OF CORES	NOS.	14 Core	24 Core
7	CONDUCTOR			
8	Material		High Conductivity Electrolyte Grade Annealed Bare Circular Copper Conductor Conf. To IS : 8130/2013	
9	Size	Sq.mm	1.5	
10	No. of Strands	Nos.	7	
11	Shape of Conductor		Circular Stranded Annealed Bare Copper Conductor Class - 2	
12	Temperature Rise on Normal Condition	Deg. C	90 ⁰ C	
13	Temperature Rise on Short Circuit Condition	Deg. C	250 ⁰ C	
14	INSULATION			
15	Material		XLPE Compound Conf. To IS : 7098 (Part-1)/2025	
16	Type		Extruded XLPE	
17	Thickness (Nom.)	mm	0.70	
18	Core Identification		All Cores Grey Colour With No. Printing On Each Cores For Core Identification	
19	INNER SHEATH			
20	Materials		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84	
21	Type		Extruded PVC	
22	Thickness (Min.)	mm	0.30	
23	Colour		Black	
24	ARMOURING			
25	Material		Galvanised Steel Flat Strip	
26	Dimension	mm	4.00 X 0.80+/-10%	
27	OUTER SHEATH			
28	Material		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84	
29	Type		Extruded PVC	
30	Thickness (Min.)	mm	1.40	
31	Overall Diameter of Cable *	mm	19.50	23.50
32	Colour Of Outer Sheath		Black	
33	Printing On Outer Sheath		Manufacturer's name, Year of manufacture, Voltage Grade and Size of cable, Sequential Length Marking shall be printed on outer sheath of cable at every 1 mtr interval .	
34	Standard Drum Length (Packing shall be done in non-returnable wooden drum)	meter	1000 Mtrs. +2 % Tolerance	
35	ELECTRICAL PARAMETERS			
36	Max. DC resistance of conductor of completed cable at 20°C	ohm / km	12.10	
37	High Voltage Test	kV rms	3.0 kV. (rms) for 5 minutes	
38	Flammability Test As Per IS : 10810 (Part-53)	Sec / mm	Period of burning after removal of flame max time (60 Sec.) , Unaffected Portion of cable min (50 mm)	

Note - * OD of cable is calculated and given for reference purpose, actual OD of cable will vary, Variation Tolerance 10 To 15 %

Note:- The values given above are subject to tolerances as per the relevant standards.

FOR :- M/S - POLYVION CABLES PVT. LTD.



DESCRIPTION : 1100 VOLTAGE GRADE CIRCULAR STRANDED ANNEALED BARE COPPER CONDUCTOR, XLPE INSULATED, PVC TYPE ST-2 SHEATHED, ARMoured CABLES CONFIRMING TO IS : 7098 (Part-1)/2025 AND THIS DATA SHEET.

SR. No.	DISCRIPTION	UNIT	2 CORE X 2.5 SQ.MM	3 CORE X 2.5 SQ.MM	4 CORE X 2.5 SQ.MM
1	CABLE TYPE		Circular Stranded Annealed Bare Copper Conductor Class - 2, XLPE Insulated, PVC Type ST-2 Inner Sheathed, Armoured, PVC Type ST-2 Sheathed Cable.		
2	NAME OF THE MANUFACTURER		M/s POLYVION CABLES PVT. LTD.		
3	BRAND NAME		POLYCORE		
4	APPLICABLE STANDARDS		IS : 7098 (Part-1)/2025, IS : 8130/2013 & This Data Sheet.		
5	VOLTAGE GRADE	VOLTS	1100 Volt		
6	NO. OF CORES	NOS.	2 Core	3 Core	4 Core
7	CONDUCTOR				
8	Material		High Conductivity Electrolyte Grade Annealed Bare Circular Copper Conductor Conf. To IS : 8130/2013		
9	Size	Sq.mm	2.5		
10	No. of Strands	Nos.	7		
11	Shape of Conductor		Circular Stranded Annealed Bare Copper Conductor Class - 2		
12	Temperature Rise on Normal Condition	Deg. C	90 ⁰ C		
13	Temperature Rise on Short Circuit Condition	Deg. C	250 ⁰ C		
14	INSULATION				
15	Material		XLPE Compound Conf. To IS : 7098 (Part-1)/2025		
16	Type		Extruded XLPE		
17	Thickness (Nom.)	mm	0.70		
18	Core Identification		Red & Black	Red, Yellow & Blue	Red, Yellow, Blue & Black
19	INNER SHEATH				
20	Materials		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84		
21	Type		Extruded PVC		
22	Thickness (Min.)	mm	0.30		
23	Colour		Black		
24	ARMOURING				
25	Material		Galvanised Steel Round Wire		
26	Dimension	mm	1.40 mm ± 0.040 mm		
27	OUTER SHEATH				
28	Material		Extruded PVC TYPE ST - 2 Conf. to IS : 5831/84		
29	Type		Extruded PVC		
30	Thickness (Min.)	mm	1.24		
31	Overall Diameter of Cable *	mm	12.50	13.50	14.50
32	Colour Of Outer Sheath		Black		
33	Printing On Outer Sheath		Manufacturer's name, Year of manufacture, Voltage Grade and Size of cable, Sequential Length Marking shall be printed on outer sheath of cable at every 1 mtr interval .		
34	Standard Drum Length (Packing shall be done in non-returnable wooden drum)	meter	1000 Mtrs. +2 % Tolerance		
35	ELECTRICAL PARAMETERS				
36	Max. DC resistance of conductor of completed cable at 20°C	ohm / km	7.41		
37	High Voltage Test	kV rms	3.0 kV. (rms) for 5 minutes		
38	Flammability Test As Per IS : 10810 (Part-53)	Sec / mm	Period of burning after removal of flame max time (60 Sec.) , Unaffected Portion of cable min (50 mm)		

Note - * OD of cable is calculated and given for reference purpose, actual OD of cable will vary, Variation Tolerance 10 To 15 %

Note:- The values given above are subject to tolerances as per the relevant standards.

FOR :- M/S - POLYVION CABLES PVT. LTD.

