

COMPANY NAME:

Golden Triangle Polymers Company LLC

PROJECT NAME :

Golden Triangle Polymers Project

PURCHASER :

JKJV

PURCHASER JOB CODE :

0-8936-2

PURCHASE ORDER NO. :

0-8936-2-P215A-201-A

VENDOR NAME :

Siemens Energy

EQUIPMENT/MATERIAL NAME:

Process Water Clean-up Unit

ITEM NO.:

X-2400


DOCUMENT TITLE:

INSTRUMENT DATASHEET FOR MEDIA SCRUBBER PUMP (10-P-2401A/B/C)

ISSUE PURPOSE :				FA						
PURCHASER DOC.NO.	SDR CODE				PURCHASE ORDER NO.	DOC. TYPE CODE			SERIAL NO.	REV.
			V	-	215A-201-A	-	DGN	-	544	3
COMPANY DOC. NO.	C16	-	10-JKVN							
VENDOR DOC. No.	SEI-EIC-544									

Contractor Use

Reviewe Result Stamp

GENERAL	1	Tag Number				PG-240690/ PG-240890/ PG-241090 [Rev.1]			
	2	Service				Pressure Gauge - Plan 32+54 (MOD)			
	3	P&ID No.				10-PID-2406/ 10-PID-2408/ 10-PID-2410 [Rev.1]			
	4	Line No.				NA			
	5	Equipment item no				10-P-2401 A/B/C			
PROCESS CONDITIONS	6	Fluid Name		Fluid State		LP BOILER FEED WATER		Liquid	
	7	Pressure	Psig	Nor.	Max.	115		115	
	8	Temperature	Deg.F	Nor.	Max.	115		115	
	9	Pulsation	Vibration		NA		NA		
	10	Design Pressure	Psig	Min.	Max.	NA		230 [Rev.2]	
	11	Design Temperature	Deg.F	Min.	Max.	NA		300	
	12	Special Requirement				NA		NA	
	13								
GAUGE	15	Type				C Type Bourdon Tube			
	16	Calibration Range	Psig	Min.	Max.	0		200 [Rev.2]	
	17	Figure Interval				25 [Rev.3]			
	18	Minor Graduation	Psi				5 [Rev.3]		
	19	Mounting				Direct			
	20	Dial Size				4.5 "			
	21	Dial Color				Aluminum White Background Black Figures and Intervals			
	22	Case Material	Case Form		SS316 Ti		Circular		
	23	Ring Construction	Ring Material		Bayonet Bezel		SS 316		
	24	Blow-Out Protection				Solid-Front Type with Blow-Out Back			
	25	Lens Material				Laminated shattered proof (Thickness - 3mm)			
	26	Pressure Element Type				Bourdon Tube			
	27	Pressure Element Material				SS 316			
	28	Socket Material				SS 316			
	29	Connection Size				1/2" NPT(M)			
	30	Connection Location				Bottom			
	31	Movement Material				SS 316			
	32	Nominal Accuracy	Ingress Protection		+/- 1% of FSD		IP66		
	33	Zero Adjustment				Required - External Adjustment			
	34	Over Range Protection				130% FS			
35									
36									
DIAPHRAGM SEAL	37	Seal Type				N/A			
	38	Diaphragm Material				N/A			
	39	Flange Material				N/A			
	40	Connection	Size	Rating	N/A		N/A		
	41	Connection	Facing	Finish	N/A		N/A		
	42	Capillary	Type	Material	N/A		N/A		
	43	Capillary	Length	Fill Fluid	N/A		N/A		
	44	Flushing	Conn.Size	Material	N/A	N/A	N/A		
45									
OPTIONS	49	Syphon: Type	Syphon Material		N/A		N/A		
	50	Snubber: Type	Snubber Material		N/A		N/A		
	51	Movement Damping				N/A			
	52	Gauge Saver: Type	Gauge Saver Material		Required - Inbuilt Type		SS316		
	53	Manifold Type	Manifold Material & Make		2 Valve Manifold (FSPL Scope)		SS316 & EXCEL HYDRO PNEUMATIC		
	54	Mainfold Connection				1/2" NPT(F)			
	55	Liquid Filled Casing				N/A			
	56	NACE	IBR	H2	NA	N/A	N/A		
57	Mounting Bracket				N/A				
PURCHASE	58	Manufacturer				ASHCROFT [Rev.5]			
	59	Model				100=T6500=S=D=04=L=200#=X=YW=E6=MP=NH=C3=C4=EN [Rev.2]			
	60	Requisition No.				-			
5	Comments updated	13-06-2024	SSK	MS	JM	INSTRUMENT DATASHEET FOR PRESSURE GAUGE		 FSPL DOC NO: 2H-169708:PG	
4	Comments updated	09-04-2024	SSK	MS	JM				
3	Comments updated	13-02-2023	SSK	MS	JM				
2	Comments updated	16-08-2023	SV	GR	SDP				
1	Comments updated	15-06-2023	SV	GR	SDP				
No.	Description	Date	Pred	Chk	App			Rev.: 5	

NOTES:-


1. Operating Pressure to fall in middle third of the range
2. Stainless steel name plate which is engraved with the Make, Model No., Tag No., Range, Serial No. shall be permanently affixed on the case or body.
3. No Asbestos material shall be used
4. A visible stopper pin shall be used to restrict the upper limit and lower limit of the pointer travel.


CERTIFICATES:-

1. 5 Point Calibration Certificate.
2. Certificate of Compliance to Flowserve Sanmar IDS specification.
3. Ingress Protection Certificate.
4. 3.1 Material Test Certificate (Socket, Bourdon).
5. PMI test report.
6. Pressure Test Certificate.


DECODIFICATION:- [Rev.2]

100 : Dial Size- 100 mm
T6500 ; Solid front stainless steel pressure gauge
S : Wetted Parts Material- Stainless steel 316L (1.4404) tube and socket
D : Case Filling -Dry case
04 ; Process Connection- 1/2" NPT male
L: Connection Location - Lower
200# : Range- 0- 200Psi
X ; Additional options
YW: Case Material- Case and ring material stainless steel 316L
E6 : Dial options- Dial pin in 6 o'clock position
MP : Pointer- Adjustable micrometer pointer
NH ; Marking And Tagging - Stainless steel tagging wired
C3 ; Material Certificate- Certificate according to EN 10204 3.1
C4 ; Test Certificate - CD-4 calibration certificate
EN ; Language-English

5	Comments updated	13-06-2024	SSK	MS	JM	<div>INSTRUMENT DATASHEET</div> <div>Pressure Gauge</div>		<div></div>	
4	Comments updated	09-04-2024	SSK	MS	JM				
3	Comments updated	13-02-2023	SSK	MS	JM				
2	Comments updated	16-08-2023	SV	GR	SDP				
1	Comments updated	15-06-2023	SV	GR	SDP			FSPL DOC NO: 2H-169708:PG	
No.	Description	Date	Pred	Chk	App	Code: 1044	Doc. No.	Rev.: 5	

GENERAL	1	Tag Number				FT/FI-240690/ FT/FI-240890/ FT/FI-241090 [Rev.1]				
	2	Service				Flow indication and Transmission Plan 32+54 (MOD)				
	3	P&ID No.				10-PID-2406/ 10-PID-2408/ 10-PID-2410 [Rev.1]				
	4	Design Pressure	Psi G	Min.	Max.	N/A		230 [Rev.2]		
	5	Design Temperature	°F	Min.	Max.	N/A		300		
	6	Elec.Haz.Area Class. STD/Zone/Method/Gr./Temp.				FM Flame Proof Class I, Division 1 Groups A, B, C, D Temp. class T3 [Rev.3]				
PROCESS CONDITIONS	7	Fluid Name	Fluid State	Fluid Phase		LP Boiler Feed Water		Liquid		
	8									
	9	Flow	GPM		2 [Rev.2]		3 [Rev.2]		4 [Rev.2]	
	10	Pressure @ Flow	Psi G		115		115		115	
	11	Temperature	°F		115		115		115	
	12	Viscosity	cP		1					
	13	Density (Liq.)	lb/ft³		62.43					
	14	Vapour Pressure (Liq.)	Kg/cm²a		N/A					
	15	Cp / Cv (Gas)	-		N/A					
	16	Z (Compressibility) (Gas)	-		N/A					
	17	% Solid	Density @ Standard (Liq.) kg/m³		N/A				-	
	18	Mol. Wt. (Gas)	Z @ Normal (Gas)		N/A				-	
	19	Allowable Max. Permanent Pressure Loss		Psi		0.7251887				
	20									
21										
METERING ELEMENT	22	Type				Metal tube				
	23	Function				Local and DCS indication				
	24	Flow Direction				Bottom to top				
	25	Instrument Range	GPM	Min.	Max.	0.7 [Rev.2]		7.0 [Rev.2]		
	26	Accuracy				+/- 1.6% VDI				
	27	Tube Material	Liner Material			SS 316		N/A		
	28	Float Material	Other Wetted Parts Material			SS 316		SS 316		
	29	Connection	Size	Rating	Facing	Finish	3/4"	300#	SWRF	125-250 AARH
	30	Permanent Pressure Loss @ Max. Flow				PPLUnit 0.7251887				
	31	Scale length & Type				6" Dial Non-linear				
	32	Scale Graduation				Direct reading				
	33									
TRANSMITTER / GAUGE	34	Meter / Calibration Range	GPM	Min.	Max.	0.7 [Rev.2]		7.0 [Rev.2]		
	35	Ingress Protection				Weatherproof to NEMA 4x, IP 66				
	36	Power Supply				24 VDC				
	37	Output Signal				4 to 20 mA -HART Version 7				
	38	Electrical connection				1/2" NPT (F) (2 No's)				
	39	Housing Material				Die Cast Aluminium [Rev.3]				
	40	Ex-Certification				Flame Proof (Ex'd)				
OPTIONS	41	Dampener				N/A				
	42	Cooling Fin				N/A				
	43	Needle Valve				N/A				
	44	Remote Indicator	Remote Indicator Tag No.			N/A				
	45	Remote Indicator Range	RI_Unit	Min.	Max.	N/A				
	46	Burnout Direction	Surge Protection			N/A		Required		
	47	NACE	IBR	H2	PWHT	N/A				
	48	LCD Display				Required				
PURGE METER	49	Mounting Plate				Required				
	50	Filter Regulator				N/A				
	51	Purge Meter				N/A				
	52									
	53									
LINE	54	Line No.				N/A				
	55	Size	Class		Sch.	N/A				
PURCHASE	56	Manufacturer				Khronne marshall				
	57	Model				H250/RR/M40/ESK4-Ex				
	58	Requisition No.				N/A				
						INSTRUMENT DATASHEET Variable Area Flowmeter				
3	Comments updated	20-02-24	SSK	JM	SDP					
2	Comments updated	14-08-23	SV	GR	SDP					
1	Comments updated	15-06-23	SV	GR	SDP					
0	For Approval	12-06-23	SV	GR	SDP					
No.	Description	Date	Pred	Chk	App	Code: 1029	Doc. No. 2H-169708:FT		[Rev.:]	

Tag Number:																																												
<p>Notes :-</p> <ol style="list-style-type: none"> 1. Stainless steel name plate which is engraved with the tag no, model no, size, rating, materials, Area Class. etc shall be permanently affixed on the case or body. 2. No Asbestos material shall be used 3. 1/2" NPT ISO Double compression type SS cable glands (Exd/e) shall be provided by the vendor. 4. Offered Transmitter shall comply NAMUR NE43. <p>Certificates:-</p> <ol style="list-style-type: none"> 1. Calibration Certificate 2. Certificate of Compliance to Flowserve Sanmar IDS Specification 3. Flame Proof : FM Flame Proof Class I, Division 1 Groups A, B, C, D 4. 3.1 Material Test Certificate 5 .PMI Test report <p>Decodification: [Rev.2]</p> <p>H250/RR/M40/ESK4-T-Ex ; Indicator along with Transmitter 4-20 milliAmp ,HART 7</p> <p>T- Totalizer</p> <p>Ex- FM Flame Proof Class I, Division 1 Groups A, B, C, D</p>																																												
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 5%; text-align: center;">3</td> <td style="width: 25%;">Comments updated</td> <td style="width: 15%;">20-02-24</td> <td style="width: 10%;">SSK</td> <td style="width: 10%;">JM</td> <td style="width: 10%;">SDP</td> <td rowspan="4" style="width: 20%; text-align: center; vertical-align: middle;"> INSTRUMENT DATASHEET Variable Area Flowmeter </td> <td rowspan="4" style="width: 25%; text-align: center; vertical-align: middle;"> </td> </tr> <tr> <td style="text-align: center;">2</td> <td>Comments updated</td> <td>14-08-23</td> <td>SV</td> <td>GR</td> <td>SDP</td> </tr> <tr> <td style="text-align: center;">1</td> <td>Comments updated</td> <td>15-06-23</td> <td>SV</td> <td>GR</td> <td>SDP</td> </tr> <tr> <td style="text-align: center;">0</td> <td>For Approval</td> <td>12-06-23</td> <td>SV</td> <td>GR</td> <td>SDP</td> </tr> <tr> <td style="text-align: center;">No.</td> <td>Description</td> <td>Date</td> <td>Pred</td> <td>Chk</td> <td>App</td> <td style="text-align: center;">Code: 1029</td> <td style="text-align: center;">Doc. No. 2H-169708:FT</td> <td style="text-align: center;">Rev.:3</td> </tr> </table>										3	Comments updated	20-02-24	SSK	JM	SDP	INSTRUMENT DATASHEET Variable Area Flowmeter		2	Comments updated	14-08-23	SV	GR	SDP	1	Comments updated	15-06-23	SV	GR	SDP	0	For Approval	12-06-23	SV	GR	SDP	No.	Description	Date	Pred	Chk	App	Code: 1029	Doc. No. 2H-169708:FT	Rev.:3
3	Comments updated	20-02-24	SSK	JM	SDP	INSTRUMENT DATASHEET Variable Area Flowmeter																																						
2	Comments updated	14-08-23	SV	GR	SDP																																							
1	Comments updated	15-06-23	SV	GR	SDP																																							
0	For Approval	12-06-23	SV	GR	SDP																																							
No.	Description	Date	Pred	Chk	App	Code: 1029	Doc. No. 2H-169708:FT	Rev.:3																																				


GENERAL	1	Tag Number				RO-240691/ RO-240891/RO-241091 [Rev.2]				
	2	Service				Restriction Orifice Plate Plan 32+54 (MOD)				
	3	P&ID No.				10-PID-2406/10-PID-2408/10-PID-2410 [Rev.1]				
	4	Design Pressure	Psi G	Min.	Max.	NA		230 [Rev.2]		
	5	Design Temperature	°F	Min.	Max.	NA		300		
PROCESS CONDITIONS	6	Fluid Name	Fluid State	Fluid Phase		LP Boiler Feed Water		liquid	-	
	7					Min.	Nor.	Max.		
	8	Flow			GPM	2 [Rev.2]		3 [Rev.2]	4 [Rev.2]	
	9	Outlet Pressure			Psi G	86		86	86	
	10	Normal Operating Temperature			Deg F	115		115	115	
	11	Viscosity			cP	1				
	12	Density (Liq.)			lb/ft ³	62.43				
	13	Vapor Pressure (Liq.)			Kg/cm ² a	NA				
	14	Cp / Cv (Gas)			NA					
	15	Z (Compressibility) (Gas)			NA					
	16	% Solid			NA					
	17	Mol. Wt. (Gas)	Z @ Normal (Gas)		NA					
	18	Allowable Pressure Loss			Psi	29				
	19	Supply Pressure			Psi	115				
ORIFICE PLATE	20	Type				Concentric Square Edge				
	21	Design Standard				R.W Miller				
	22	Plate Material				SS 316L				
	23	Holder Ring Material				NA				
	24	Plate Thickness				3.2 mm				
	25	Drain or Vent Hole Size	Diameter (mm)		NA		1.5			
	26	Centre Distance				N/A				
27	Number of Stages (For Restriction Orifice)				Single Stage Restriction					
ORIFICE FLANGE	28	Connection	Size	Rating	Facing	Finish	3/4"	300#	RF	125-250 AARH
	29	Taps Type		Taps Size		N/A		N/A		
	30	Tapping Orientation		No. of tapping's		N/A		N/A		
	31	Pipe Material		Flange Material		SS 316L		SS 316L		
	32	Plug Material		Flange Type		N/A		N/A		
	33	Gasket Material		Gasket Thickness		SS 316L Spiral Wound		4.5 mm		
	34	Bolt / Nut Material				ASTM A 193 GR. B CLASS 1 / ASTM A 194 GR.8				
35	Jackscrew Material				N/A					
METER RUN	36	Spool Piece Length				N/A				
	37	End Connection	Size	Rating	Facing	Finish	N/A	N/A	N/A	N/A
	38	Meter Run Material				N/A				
	39	Integral orifice block Material				N/A				
CALCULATION RESULT	40	Bore diameter	Beta Ratio (d / D)		5.05 [Rev.2]		0.26796 [Rev.2]			
	41	Flow Full Scale (Meter Max)				N/A				
	42	Differential Pressure Range		Min.	Max.	N/A		N/A		
	43	Flow Range		Min.	Max.	N/A		N/A		
	44	Permanent Pressure Loss @ Max. Flow		Kg/cm2g		N/A				
45	Noise (dBA)				N/A					
SPECIAL OPTIONS	46	IBR Certification				N/A				
	47	NACE Requirement				N/A				
	48	PWHT Requirement				N/A				
	49	Radiography Requirement				N/A				
LINE	50	Line No.	Equipment item No		N/A		10-P-2401 A/B/C			
	50	Size	Class	Sch.	3/4"		300#		Sch. 80	
PURCHASE	51	Manufacturer				MINCO				
	52	Model				No Model Number				
	53	Requisition No.				-				
						INSTRUMENT DATASHEET FOR ORIFICE PLATE		 FSPL CODE: 2H-169708:OR		
2	Comments updated		14-08-23	SV	GR					SDP
1	Comments updated		15-06-23	SV	GR					SDP
0	For approval		12-06-23	SV	GR					SDP
No.	Description		Date	Pred	Chk	App			Rev.:2	

NOTES: -

1. The following to be marked on the holder - Tag no, Nominal pipe size, Rating, material of Plate & Bore Size, Upstream (or) Up, Orifice diameter.
2. No Asbestos material is used.
3. Orifice Plate is used for creating back pressure and not for pressure drop / pressure measurement.
4. Plate holder shall be Integral Handle- which upon assembly extend to a distance of 50mm length.

CERTIFICATES: -

1. Type, Size, Rating, Material & Dimension test report
2. 3.1 Material Test Certificate
3. PMI Required.

						INSTRUMENT DATASHEET FOR ORIFICE PLATE	
2	Comments updated	15-06-23	SV	GR	SDP		
1	Comments updated	15-06-23	SV	GR	SDP		
0	For approval	12-06-23	SV	GR	SDP	FSPL CODE: 2H-169708:OR	
No.	Description	Date	Pred	Chk	App	Rev.:2	


GENERAL	1	Tag Number	P&ID No.		PCV-240690/PCV-240890/PCV-241090 [Rev.1]		10-PID-2406/10-PID-2408/10-PID-2410 [Rev.1]			
	2	Service	Process Case		Pressure Control Valve Plan 32+54 (MOD)		N/A			
	3	Design Pressure Psi.G	Min.	Max.	NA		230 [Rev.2]			
	4	Design Temperature °F	Min.	Max.	NA		300			
	5	Air Supply Pressure Kg/cm ² a	Min.	Max.	NA					
	6	Hazardous Area Classification			NA					
	7	Ex-Certification			NA					
PROCESS CONDITIONS	8	Fluid Name	Fluid State	Fluid Phase	LP BOILER FEED WATER		Liquid	-		
	9				Min.		Nor.	Max.		
	10	Flow		GPM	2 [Rev.2]		3 [Rev.2]	4 [Rev.2]		
	11	Pressure @ Flow		Psi G	150		150	150		
	12	Diff. Pressure @ Flow		Psi			35			
	13	Temperature	Oper.	Max.	°F		115			
	14	Viscosity			cP		1			
	15	Density (Liq. / Steam)			lb/ft ³ [Rev.1]		62.43			
	16	Vapour Pressure (Liq.)			Kg/cm ² a	NA				
	17	Cp / Cv (Gas/Steam)			-	NA				
	18	Z (Compressibility) (Gas/Steam)			-	NA				
	19	Shut-off Press. Max. Kg/cm ²	% Solid		NA		NA			
	20	Critical Press. (Liq.) Kg/cm ² a	% Flash		NA		NA			
	21	Mol. Wt. (Gas/Steam)	Outlet Vap. Mol. Wt.		NA		NA			
CALCULATED RESULTS	22	Degree of Superheat	Critical Temperature °F		NA		NA			
	23	Cv @ Flow	Min.	Nor.	Max.	0.338 [Rev.2]	0.507 [Rev.2]	0.676 [Rev.2]		
	24	% Opening @ Flow	Min.	Nor.	Max.	NA	NA	NA		
BODY AND TRIM	25	Noise @ Flow dBA	Min.	Nor.	Max.	<85 dBA	<85 dBA	<85 dBA		
	26	Body Type	Globe			62 Quantity		NA		
	27	Body Size	Body Rating	3/4"	300#	63 Tag No.		NA		
	28	Body/Bonnet Material	A351 Gr. CF8M		64 Manufacturer		NA			
	29	Balanced/Unbalanced	Balanced		65 Model		NA			
	30	Corrosion Allowance	N/A		66 Type	Insulation Class	NA	NA		
	31	Bonnet Type	Standard		67 Body Mtr.	Trim Mtr.	NA	NA		
	32	Trim	Size	Standard	0.631 Inch [Rev.2]	68 Ingress Protection		NA		
	33	Trim (Ball/Plug/Disc) Mtrl	SS316		69 Electrical Connection		NA			
	34	Seat Material	SS316		70 Pneumatic Connection		NA			
	35	Stem/Shaft Material	SS316		71 Manual Reset		NA			
	36	Guiding type	Top Guided		72 Power Supply		NA			
	37	Rated Trim Travel (mm)	N/A		73 Tag No. Open Position		NA			
	38	Packing	Material	Style	Glandless	74 Tag No. Close Position		NA		
	39	Selected Cv	0.98 [Rev.2]		75 Manufacturer	Model	NA	NA		
	40	Characteristics	Linear		76 Type		NA			
	41	Leakage Class	Class IV		77 Ingress Protection		NA			
	42	Flow Tendency to Valve	Close		78 Electrical Connection		NA			
	43	Gasket Material	NA		79					
	44	Conn. In	Size	Rating	3/4"	300#	80 Air Reservoir		NA	
	45	Conn. In	Facing	Finish	RF	125 AARH	81 Air Set	Set Pressure	NA	NA
	46	Conn. Out	Size	Rating	3/4"	300#	82 Air Set Connection		NA	
	47	Conn. Out	Facing	Finish	RF	125 AARH	83 Air Set Material		NA	
	ACTUATOR	48	Manufacturer	Model	NA	NA	84 Surge Protection		NA	
		49	Type	Internal Sensing		85 Air Lock Device		NA		
50		Travel Stop	NA		86 Filter Size in Micron		NA			
51		Air Failure Position	NA		87 AFR make/model		NA			
52		Hand Wheel	NA		88 Fire proofing		NA			
53		Actuator Housing	NA							
POSITIONER	54	Manufacturer	Model	NA	NA	89 Inlet Line No.		NA		
	55	Type	NA		90 Size	Class	Sch	3/4"	300#	80 Sch.
	56	Input	Output	NA	NA	91 Outlet Line No.		NA		
	57	Increase Signal Valve	NA		92 Size	Class	Sch	3/4"	300#	80 Sch.
	58	Ingress Protection	NA		93 Manufacturer	Emerson				
	59	Electrical Connection	NA		94 Model	NPS 3/4 MR95HT [Rev.2]				
PROC. NOTE	60	Pneumatic Connection	NA		95 Requisition No.	NA				
	61	NACE / IBR / SIL	NA		FAB. NOTE	96 PWHT Requirement	NA			




Notes:

- 1) Stainless steel name plate which is engraved with Make, Model No., Tag No., Operating Range, Set Pressure, Size, Rating, MOC shall be permanently affixed on the case or body.
- 2) Single seated valve shall have top guiding.
- 3) Direction of flow must be stamped on valve body
- 5) Set Pressure : 115 Psi.G
- 6) The Valve shall be of downstream control.
- 7) Diaphragm shall be of SS316
- 8) Flanges shall be as per ASME B16.5

Certificates:

1. Certificate of Compliance to Flowserve Sanmar IDS Specification
2. Hydro test report (Body)
3. 3.1 Material Test Certificate.
4. PMI Required.
5. Seat Leakage, Pressure Test, Set Pressure Test Report
6. DP Test Report.
7. RT Test Report.

						INSTRUMENT DATASHEET		 FSPL DOC NO : 2H-169708:PCV	
						Control Valve - Globe			
2	Comments updated	14-08-23	SV	GR	SDP				
1	Comments updated	15-06-23	SV	GR	SDP				
0	For Approval	12-06-23	SV	GR	SDP				
No.	Description	Date	Pred	Chk	App	Code:	Doc. No.:	Rev.: 2	

<div></div>	Golden Triangle Polymers Project			Document Title: INSTRUMENT DATASHEET FOR MEDIA SCRUBBER PUMP (10-P-2401A/B/C)		<div></div>
				Document No.:V-215A-201-A-EIC-544		
	COMMENT RESOLUTION SHEET			Rev. No.: 2		
				Vendor Name: Sparkle Clean Tech Pvt. Ltd.		
S.No.	Ref Doc No./ Title	Ref. Clause	Discipline	JGC Comments	Vendor Response	Status
				Date:	Date: 14.06.2024	Closed/ Open
1	V-215A-201-A-EIC-544	Page No - 7	Mechanical	<div></div>	Updated	Closed
2	V-215A-201-A-EIC-544	Page No - 7	Mechanical	<div><p>3" F BFW flow to</p><p>Noted and updated</p><div><p>No separate model make only updated</p></div></div>	Updated	Closed