

PROJECT REPORT

ELECTRICITY GENERATION FROM FREE ENERGY SOURCES

A Consolidated Deep-Research Study on Solar Photovoltaic, Wind, Hydro and Other Renewable Energy Technologies — Working Principles, Global and Indian Scenario, Economic Viability, Environmental Life-Cycle Dynamics and the Kerala Perspective

Submitted by	Name :
	Roll No. :
	Course / Semester :
Guided by	Teacher / Supervisor :
	Department :
Institution	School / College :
Place	Malappuram, Kerala :

Consolidated from four source project reports • Data current to August 2026

AUGUST 2026

Table of Contents

Abstract	4
1. Introduction	5
1.1 Background and Problem Statement	5
1.2 What Are “Free Energy Sources”?	5
1.3 Objectives of the Study	5
1.4 Scope of the Report	6
1.5 Methodology	6
2. Classification and Overview of Free Energy Sources	6
3. Solar Energy: The Photovoltaic Route	7
3.1 The Solar Resource	7
3.2 The Photovoltaic Effect and Cell Construction	7
3.3 From Cell to Power Plant: System Components	8
3.4 Types of Solar PV Systems	9
3.5 Solar Thermal Power (CSP)	9
3.6 Performance Factors	9
4. Wind Energy	10
4.1 Origin and Physics of Wind Power	10
4.2 Components of a Wind Turbine	10
4.3 Types of Wind Machines	11
4.4 Performance and Capacity Factor	11
5. Hydroelectric Power	11
6. Other Free Energy Sources	12
6.1 Biomass and Bioenergy	12
6.2 Geothermal Energy	12
6.3 Tidal, Wave and Ocean Thermal Energy	12
6.4 Green Hydrogen as an Energy Carrier	12
7. Global and Indian Scenario	13
7.1 Global Status (IRENA, end-2025)	13
7.2 India’s Renewable Energy Journey	14
7.3 Leading States in Renewable Capacity	15
8. Case Study: Kerala — Solar, Wind and Hydro	16
8.1 Kerala’s Energy Profile	16
8.2 Hydroelectric Legacy: The Idukki Project	16
8.3 Solar Programmes and the Rooftop Revolution	16

8.4 Wind Energy Potential and Plans	17
8.5 Relevance to Malappuram District	17
9. Economic Analysis	18
9.1 Levelised Cost of Electricity (LCOE)	18
9.2 Capital Cost Trends	19
9.3 Worked Examples	19
10. Environmental Life-Cycle Assessment and the Circular Economy	20
10.1 Life-Cycle Carbon Footprint	20
10.2 End-of-Life Management and Recycling	22
11. Grid Integration, Storage and Hybrid Systems	22
11.1 The Integration Challenge	22
11.2 Battery Energy Storage Systems (BESS)	23
11.3 Hybrid Renewable Systems	23
12. Advantages and Limitations	24
13. Applications and Demonstration Model	24
13.1 Applications	24
13.2 Suggested Working Model / Demonstration	25
13.3 Operation, Maintenance and Safety	25
14. Challenges and Mitigation Strategies	25
14.1 Intermittency and the Need for Storage	25
14.2 Grid Integration and Curtailment	25
14.3 Land, Materials and Recycling	26
14.4 Financing and Policy	26
15. Future Scope and Recommendations	26
15.1 Technology Trends	26
15.2 Recommendations	26
16. Conclusion	27
References	27
Appendix A — Analysis of the Four Source Documents	29
Appendix B — Glossary	30
Appendix C — Abbreviations	31

Abstract

Electricity is the most versatile form of energy, yet a large part of the world still produces it by burning coal, oil and natural gas — fuels that are finite, costly and polluting. In contrast, the energy of the Sun, wind, flowing water, biomass and the heat of the Earth is available freely in nature and is continuously replenished. These “free energy sources” need no purchased fuel: once the generating plant is built, the cost of the energy input itself is zero.

This consolidated project report presents a deep-research study of how electricity is generated from free and renewable sources, with special emphasis on solar photovoltaics (PV) and wind energy, and supporting coverage of hydroelectric, biomass, geothermal, tidal and ocean-thermal technologies. It explains the scientific principles behind each technology — the photovoltaic effect in a silicon solar cell, the kinetic-energy conversion in a wind turbine ($P = \frac{1}{2}\rho AV^3$, bounded by the Betz limit), and the potential-to-electrical conversion in a hydro plant ($P = \rho gQH\eta$) — together with the main system components such as modules, inverters, charge controllers, batteries, turbines, gearboxes and generators.

The report then analyses the latest global and national statistics. According to the International Renewable Energy Agency (IRENA), global renewable capacity reached 5,149 GW by the end of 2025 — after a record 692 GW was added in a single year — with solar alone contributing 2,392 GW, and renewables now account for about 49.4% of total world power capacity. India, which crossed the milestone of 50% non-fossil installed capacity in June 2025 — five years ahead of its commitment — had 274.68 GW of renewable capacity in March 2026, including 150.26 GW of solar and 56.09 GW of wind, and is marching towards 500 GW of non-fossil capacity by 2030. A Kerala case study covers the 780 MW Idukki hydroelectric project, the state’s rooftop-solar programme that has crossed 1.5 GW, the ANERT 3,000 MW renewable expansion plan and a wind potential of about 2,993 MW, with particular relevance to Malappuram district.

An economic analysis using IRENA cost data shows that new solar plants (US\$0.043/kWh) and onshore wind farms (US\$0.034/kWh) now generate electricity more cheaply than the least-cost fossil-fuel alternative, and that in 91% of new projects worldwide renewables beat fossil fuels on price, avoiding an estimated US\$467 billion of fuel costs in 2024. Worked examples — a 10 kW rooftop PV system, a 5 kW wind turbine and a 3 kW rooftop solar installation for a Kerala home demonstrating a simple payback of roughly 4–5 years after subsidy — illustrate the engineering calculations. The report further examines life-cycle environmental impacts (11–50 gCO₂eq/kWh for wind and solar versus 740–1,000 for coal), end-of-life recycling and the circular economy, grid integration with battery storage (costs down ~95% since 2010), and hybrid renewable systems. It concludes that free energy sources are no longer an alternative of the future; they are the most economical and sustainable path to electricity today.

Keywords: renewable energy, free energy sources, solar PV, wind turbine, hydroelectricity, LCOE, battery storage, hybrid system, Kerala, net metering, life-cycle assessment.

1. Introduction

1.1 Background and Problem Statement

Modern society runs on electricity. Lighting, communication, industry, transport, health care and agriculture all depend on an uninterrupted supply of electrical power. For over a century this power has mostly come from burning fossil fuels — coal, oil and natural gas — in thermal power stations. This dependence carries three serious problems. First, fossil fuels are finite: they took millions of years to form and are being consumed far faster than nature can replace them. Second, burning them releases carbon dioxide (CO₂) and other pollutants; the power sector is the largest single source of global CO₂ emissions and a major driver of climate change. Third, fuels are costly and their prices are volatile, and many countries — including India — must import them, creating energy-security risks and a heavy foreign-exchange burden.

The solution that the entire world is now adopting is to generate electricity from free, naturally replenished sources: sunlight, wind, flowing water, biomass and the Earth's internal heat. These sources are “free” in the sense that no fuel has to be bought or mined — the energy input is provided by nature every day. The only costs are the capital cost of the equipment and its maintenance. Renewable electricity is also nearly emission-free at the point of generation. What was once a costly, experimental technology is now the cheapest way to make new electricity in most of the world.

1.2 What Are “Free Energy Sources”?

The term “free energy source” in this report means an energy resource that (i) is naturally replenished within a human lifetime, (ii) is available without the need to purchase fuel, and (iii) can be converted into useful work or electricity. Sunlight, wind, rain and water flow, tides, waves, geothermal heat and organic waste (biomass) all qualify; they are also called renewable energy sources.

It is important to clarify that “free” refers to the fuel being free of cost — the equipment that harvests the energy (solar panels, wind turbines, generators, dams) still has to be manufactured, installed and maintained. The free input is what makes the running cost of such plants close to zero and the fuel-cost risk non-existent.

1.3 Objectives of the Study

- To study the scientific working principles of electricity generation from solar, wind, hydro, biomass, geothermal and ocean sources.
- To describe the main components and system configurations used in solar PV, wind and hybrid power plants, including small hydro.
- To analyse the latest global and national (Indian) statistics on renewable energy capacity and costs.
- To examine the Kerala scenario — hydro, solar and wind — and its relevance to Malappuram district.
- To evaluate the economics of renewable generation using the levelised cost of electricity (LCOE) and worked examples (10 kW solar, 5 kW wind, 3 kW Kerala rooftop).

- To assess environmental performance through life-cycle assessment, end-of-life management and the circular economy.
- To identify challenges (intermittency, storage, grid integration, financing) and the future scope of free energy technologies.

1.4 Scope of the Report

The report covers electricity-generation technologies based on free energy sources. The emphasis is on solar photovoltaics and wind — the two fastest-growing technologies — followed by hydro (including small hydro), biomass, geothermal and tidal/ocean energy. It reviews working principles, system components, global and Indian capacity statistics up to mid-2026, economic indicators, a Kerala case study, environmental life-cycle impacts, and future trends such as battery storage, floating solar, offshore wind and green hydrogen. Nuclear energy and energy-efficiency measures are outside the definition of free/renewable sources used here and are not covered.

1.5 Methodology

The study is a desk-research project based on (i) authoritative secondary sources — the International Renewable Energy Agency (IRENA) statistical and cost reports, Ministry of New and Renewable Energy (MNRE) data and Press Information Bureau (PIB) releases of the Government of India, the India Brand Equity Foundation (IBEF), Kerala state agency (ANERT/KSEB) publications, US DOE and EPA material and reputed energy-sector journals; (ii) standard textbook theory of energy conversion; and (iii) simple quantitative calculations (plant output, LCOE comparison and payback period) carried out with clearly stated assumptions.

This document is additionally a **consolidation**: it merges, cross-checks and reconciles four earlier project-report drafts prepared on the same topic (see Appendix A for a document-by-document analysis and the discrepancies resolved during merging). Where the drafts disagreed, the internally consistent, most recent and best-sourced figure was retained and the variance is footnoted.

2. Classification and Overview of Free Energy Sources

Free energy sources can be grouped by their ultimate origin. Almost all of them — solar, wind, hydro, waves and biomass — are forms of solar energy: the Sun heats the atmosphere unevenly, producing wind; wind and Sun drive the water cycle that fills rivers; sunlight drives photosynthesis that creates biomass. Geothermal energy comes from the Earth's internal heat, and tidal energy from the gravitational pull of the Moon and Sun. Table 2.1 summarises the main sources.

Source	Ultimate origin	Primary technology	Maturity / status
Solar	Sun (nuclear fusion)	Photovoltaic (PV) cells; solar thermal / CSP	Very mature; fastest growing
Wind	Sun (atmospheric heating)	Wind turbines (onshore, offshore)	Very mature; offshore growing
Hydro	Sun (water cycle)	Dams, run-of-river, pumped storage	Mature

Source	Ultimate origin	Primary technology	Maturity / status
Biomass	Sun (photosynthesis)	Combustion, gasification, biogas, bio-fuels	Mature; resource-limited
Geothermal	Earth's internal heat	Dry steam, flash, binary cycle plants	Mature in volcanic regions
Tidal	Moon & Sun (gravity)	Tidal barrages, tidal-stream turbines	Early stage; site-specific
Wave / OTEC	Sun & wind (waves); ocean thermal gradient	Wave energy converters; OTEC	Experimental / R&D;

Table 2.1 — Classification of free (renewable) energy sources for electricity generation

Each source converts a natural energy flow into electricity through a different machine: solar cells convert light directly into electricity (photovoltaic effect); wind turbines convert the kinetic energy of moving air into rotating mechanical energy and then electricity; hydro turbines convert the potential energy of stored water into kinetic energy of a jet and then into rotation; biomass plants release stored chemical energy through combustion or digestion; geothermal plants use steam from deep wells; and tidal plants use the rise and fall of the sea. Chapters 3–6 explain these conversions in detail.

3. Solar Energy: The Photovoltaic Route

3.1 The Solar Resource

The Sun radiates energy at a rate of about 3.8×10^{26} W; the Earth intercepts roughly 1.7×10^{17} W — about 10,000 times present-day human energy use. At the top of the atmosphere the solar irradiance is about 1,366 W/m², and at the Earth's surface on a clear day it is typically 800–1,000 W/m². India receives 4–7 kWh of solar energy per square metre per day, among the best in the world. Kerala receives about 4.5–5.5 kWh/m²/day on average (a regional IISc study estimates above about 5.5 kWh/m²/day), which is sufficient for highly cost-effective solar generation. Since the Sun's position, cloud cover and day length vary, solar output is intermittent and must be complemented by storage or other sources.

3.2 The Photovoltaic Effect and Cell Construction

A solar (photovoltaic, PV) cell is a semiconductor device that converts light directly into electricity through the photovoltaic effect — the generation of a voltage and current in a material when it absorbs photons. The most common cell material is crystalline silicon (c-Si); thin-film compounds such as cadmium telluride (CdTe) and copper indium gallium selenide (CIGS) are also used. Silicon is processed into two layers: n-type silicon (doped with phosphorus, having excess electrons) and p-type silicon (doped with boron, having electron vacancies called holes). At the junction between the layers an internal electric field is created. The working steps are:

- **Absorption** — photons of sunlight strike the cell and are absorbed by the silicon, transferring their energy to electrons.
- **Separation** — the absorbed energy knocks electrons loose from their atoms, creating electron-hole pairs; the junction field forces the electrons to flow in one direction.
- **Collection** — metal contacts on the front and back of the cell collect the electrons; a typical cell produces about 0.5–0.6 V and a few amperes.

Because a single cell is tiny, cells are connected in series (to raise voltage) and parallel (to raise current) inside a module (panel) — typically 60 or 72 cells — and modules are grouped into arrays. The DC output is supplied to an inverter when alternating current (AC) is required. The theoretical efficiency limit for a single-junction cell is bounded by the Shockley-Queisser limit of about 33.7%; commercial silicon modules installed in 2026 typically convert 20–24% of sunlight into electricity, with premium heterojunction (HJT) panels reaching about 25.5%. A newer generation stacks a thin perovskite crystal layer on silicon (perovskite-silicon tandem cells): because the perovskite absorbs high-energy blue light while silicon absorbs red/infrared, commercial tandem panels reach roughly 24–29% efficiency, and certified laboratory tandem cells have exceeded 34%, though long-term outdoor durability is still being proven at commercial scale.

3.3 From Cell to Power Plant: System Components

A complete solar power system (Figure 3.1) contains more than the panels. The main subsystems are the PV array (rooftop, ground-mounted or floating), the charge controller (MPPT controllers maximise energy extraction and protect batteries), the battery bank for off-grid and hybrid systems, the inverter (converting DC into grid-compatible AC at 230 V / 50 Hz, performing safety disconnection and, in smart inverters, grid support), the AC distribution panel, and — in grid-connected systems — a net/bi-directional meter that records energy imported from and exported to the utility grid. Table 3.1 summarises the functions of each component.

Grid-connected solar PV system with optional battery storage and net metering



Figure 3.1 — Block diagram of a grid-connected solar PV system with optional battery storage and net metering.

Component	Function
PV panel / array	Converts sunlight into DC electricity
Mounting structure	Provides mechanical support, tilt and orientation
Charge controller / MPPT	Controls battery charging and optimises PV energy capture
Battery bank	Stores electricity for night / cloudy periods (lead-acid or lithium-ion)
Inverter	Converts DC to AC; controls power quality; grid-safety interface
AC distribution panel	Feeds AC into building wiring / loads
Protection equipment	Protects circuits against faults, overcurrent and electrical hazards
Net / bi-directional meter	Records energy imported and exported (net metering / net billing)
Monitoring system	Measures energy production and system performance

Table 3.1 — Main components of a solar PV power system and their functions

3.4 Types of Solar PV Systems

Configuration	Grid connection	Battery	Typical use
Off-grid (stand-alone)	None	Yes (essential)	Remote homes, street lights, water pumps, telecom towers
On-grid (grid-tied)	Yes — net metering	Optional	Rooftop and utility-scale plants; surplus exported to grid
Hybrid	Yes	Yes	Homes/industry wanting backup plus grid export; solar-wind hybrids

Table 3.2 — Comparison of solar PV system configurations

Utility-scale solar farms (several MW to GW) and rooftop systems follow the same logic; only the scale and grid-connection equipment differ. India has also pioneered solar-wind hybrid parks and floating solar plants on reservoirs, which save land and reduce water evaporation.

3.5 Solar Thermal Power (CSP)

Solar energy can also be harvested thermally. Concentrated Solar Power (CSP) plants use mirrors — parabolic troughs, central receiver towers, dishes or Fresnel reflectors — to focus direct normal irradiance onto a receiver, heating a working fluid to between 400 °C and 1,000 °C. The heat raises steam that drives a conventional Rankine-cycle turbine (or a supercritical-CO₂ Brayton cycle in advanced designs). CSP's advantage is thermal energy storage (typically molten-nitrate-salt), which allows dispatchable generation for hours after sunset. Its cost (about US\$0.086/kWh in 2024) is higher than PV, so CSP remains a niche technology. Solar water heaters and solar cookers are simpler thermal applications used widely in Indian households.

3.6 Performance Factors

- **Irradiance and orientation** — output is proportional to sunlight; the optimum tilt for Kerala is roughly 10–15° facing south (panels are often laid flat or tilted 5–10° on flat roofs).
- **Temperature** — silicon cells lose about 0.4–0.5% of efficiency per °C rise above 25 °C.
- **Performance ratio (PR)** — a good system delivers about 75–85% of theoretical panel output after wiring, inverter, dust and temperature losses.
- **Degradation** — modules lose roughly 0.5% of output per year; most carry 25-year performance warranties (service life 25–30 years).
- **Dust and shading** — regular cleaning and avoidance of shade are essential, especially in Kerala's humid monsoon climate.

$$E = A \times r \times H \times PR \text{ (annual energy; } A = \text{array area, } r = \text{module efficiency, } H = \text{in-plane irradiation, } PR = \text{performance ratio)}$$

4. Wind Energy

4.1 Origin and Physics of Wind Power

Wind is moving air created because the Sun heats the Earth's surface unevenly — warm air rises at the equator and over land, cool air sinks at the poles and over oceans, and the rotation of the Earth (Coriolis effect) deflects the resulting circulation. The kinetic energy of moving air can be captured by a wind turbine and converted into electricity. The power available in a wind stream is:

$$P = \frac{1}{2} \rho A V^3 \quad (\rho = \text{air density} \approx 1.225 \text{ kg/m}^3 \text{ at sea level}; A = \text{rotor swept area}; V = \text{wind speed})$$

Because power rises with the cube of wind speed, doubling the wind speed gives eight times the power — a modest increase in wind speed produces a large increase in available energy, which is why turbine siting on windy ridges and coasts, and tall towers that reach stronger winds, are crucial. Not all of this power can be captured: Betz's law states that an ideal rotor can extract at most $16/27 \approx 59.3\%$ of the wind's kinetic energy (a perfect extractor would stagnate the airflow). Modern turbines achieve power coefficients of about 45–50%. Wind turbines typically start generating at cut-in speeds of 3–4 m/s, reach rated power at 11–15 m/s, and shut down for safety above about 25 m/s (cut-out speed).

4.2 Components of a Wind Turbine

- **Rotor blades (usually 3)** — aerofoil-shaped; convert the wind's lift force into rotation of the hub.
- **Nacelle** — the housing on top of the tower containing the low-speed shaft, gearbox (stepping up slow blade rotation to generator speed), the generator (induction, or direct-drive permanent-magnet synchronous), the yaw mechanism and controls. Advanced pitch-control and variable-speed systems optimise extraction across wind regimes and provide synthetic inertia and reactive-power support to the grid.
- **Tower** — raises the rotor into stronger, less turbulent winds; typical hub heights are 80–120 m onshore and 130 m+ offshore.
- **Foundation** — gravity or piled foundations on land; monopiles, jackets or floating platforms at sea.
- **Power electronics** — converters and transformers condition the variable-frequency output and connect the turbine to the grid.

Wind-energy conversion chain (Betz limit: max 59.3% of wind kinetic energy)



Figure 4.1 — Wind-energy conversion: turbine structure and the power chain from wind kinetic energy to electrical power.

4.3 Types of Wind Machines

Two architectures exist: horizontal-axis wind turbines (HAWT), with the rotor shaft parallel to the ground and a yaw mechanism keeping the rotor facing the wind — used in virtually all commercial machines — and vertical-axis turbines (VAWT, e.g. Darrieus, Savonius), which accept wind from any direction without yaw but have lower efficiency and are used mainly in small-scale or urban applications. By location, wind power is classed as onshore (land-based, cheapest) and offshore (at sea, where winds are stronger and steadier but costs are higher). Offshore turbines entering construction in 2026 are commonly rated at 14–15 MW per unit — far larger than a decade ago — because fewer, bigger turbines reduce installation and maintenance cost per megawatt. Repowering — replacing old small turbines with fewer, larger ones — is an increasingly popular way to raise output on existing wind farms.

4.4 Performance and Capacity Factor

Because wind does not blow constantly, a wind farm's actual generation divided by its maximum possible generation — the capacity factor — is typically 20–35% onshore (up to 45% at the best sites) and 35–55% offshore, compared with 15–25% for un-firmed solar PV. Kerala's wind speeds are comparatively modest; feasible sites lie in the highland areas of Palakkad district (Kanjikode/Attappady region) and along certain coastal stretches. Wind and solar complement each other well — wind often blows more at night and in the monsoon, when solar output is low — which is the logic behind solar-wind hybrid plants.

5. Hydroelectric Power

Hydropower converts the energy of falling or flowing water into electricity — the oldest commercial renewable technology. Water stored behind a dam possesses potential energy; when released, it flows through a penstock and strikes the runner of a turbine (Pelton for high head, Francis for medium, Kaplan for low head), spinning it and the connected generator. The power available is:

$$P = \rho g Q H \eta \quad (\rho = \text{water density}; g = 9.81 \text{ m/s}^2; Q = \text{flow rate, m}^3/\text{s}; H = \text{effective head, m}; \eta = \text{turbine-generator efficiency, typically 85–95\%})$$

Because water is dense, even moderate flows and heads produce large power; hydro plants typically achieve capacity factors above 40%. The main categories are:

- **Large dam projects** — store water for months, giving firm, dispatchable power (e.g. Kerala's 780 MW Idukki project, Chapter 8).
- **Run-of-river plants** — use the natural flow of the river without large storage; cheaper and less disruptive but dependent on seasonal flows.
- **Small / micro hydro** — below 25 MW, often suited to hill streams; Kerala has many such plants.
- **Pumped storage** — pumps water uphill at night and releases it at peak hours; with about 142 GW installed globally it is the world's largest form of grid energy storage.

Globally, renewable hydropower capacity is about 1,296 GW (end-2025) and remains the largest single source of renewable electricity generation in energy terms. Its limitations are

site dependence, high initial cost, environmental effects on rivers and fish movement, and — in Kerala’s monsoonal climate — seasonal variation in inflow.

6. Other Free Energy Sources

6.1 Biomass and Bioenergy

Biomass — firewood, agricultural residues, animal dung, municipal organic waste and energy crops — stores solar energy through photosynthesis. It can be burned directly to raise steam (combustion), heated with limited oxygen to produce combustible syngas (CO , H_2 , CH_4) for high-efficiency combined-cycle configurations (gasification), or digested by bacteria in the absence of oxygen to yield biogas (anaerobic digestion, typically 55–70% methane). Biomass plants can run on demand (dispatchable), which makes them a useful firming source for variable solar and wind. India uses bagasse cogeneration in sugar mills and biogas plants extensively. The global average LCOE of bioenergy is about US\$0.086–0.089/kWh; the limits are fuel-collection logistics, competition with food production and modest net-emission benefits.

6.2 Geothermal Energy

Geothermal power taps the heat of the Earth’s interior, where temperatures rise about 25–30 °C per kilometre of depth and reach several hundred degrees in volcanic regions. Wells drilled 1–3 km deep bring up steam or hot brine: dry-steam plants route geofluid steam directly to turbines; flash plants depressurise high-pressure fluid in flash tanks to generate steam; binary-cycle plants transfer heat to a secondary low-boiling-point organic working fluid (isobutane/pentane) across an Organic Rankine Cycle, isolating corrosive geofluids and suiting moderate 100–180 °C resources. Geothermal plants are compact and run 24×7 with capacity factors above 80% — global capacity is about 16 GW. India’s known prospects lie in the Himalayas (Ladakh: Puga and Chumathang) and parts of Gujarat, but the resource is largely unexploited because of depth and cost.

6.3 Tidal, Wave and Ocean Thermal Energy

Tides are caused by the gravitational pull of the Moon and Sun and are perfectly predictable. Tidal barrages (dams across estuaries) let water flow through turbines on the ebb and flow; tidal-stream turbines work like underwater windmills in strong currents. India has identified the Gulf of Kutch and the Gulf of Khambhat as promising sites. Wave-energy converters harvest the mechanical energy of ocean waves, and ocean thermal energy conversion (OTEC) exploits the temperature difference between warm surface and cold deep water — technically feasible in tropical seas but still experimental. Both remain at early commercialisation with high costs, but their predictability is valuable.

6.4 Green Hydrogen as an Energy Carrier

Surplus renewable electricity can be used to electrolyse water into hydrogen (“green hydrogen”), a storable fuel that can be burnt in turbines, used in fuel cells or serve as an industrial feedstock. India’s National Green Hydrogen Mission (outlay ₹19,744 crore) targets 5 million tonnes of green hydrogen per year by 2030, and Kerala has launched a “Hydrogen Valley” initiative. Green hydrogen is thus not a primary free source, but the means to store and transport free-source energy across time and distance.

7. Global and Indian Scenario

7.1 Global Status (IRENA, end-2025)

According to the International Renewable Energy Agency's Renewable Capacity Statistics 2026, global renewable power capacity reached 5,149 GW at the end of 2025 after a record 692 GW was added during the year (a 15.5% rise) — the largest annual addition ever recorded. Renewables supplied 96.8% of all net new power capacity in the year and now account for 49.4% of the world's total installed capacity. Solar PV alone added 511 GW (+27.2%), followed by wind with 159 GW (+14.0%); solar and wind together (variable renewables) now form 35.3% of global capacity. Asia added 74.2% of the world's new renewable capacity, led by China (+440 GW) and India (+37 GW).

Source	Capacity (GW)	Share of renewables	Added in 2025
Solar PV	2,392	46.5%	+511 GW (+27.2%)
Hydropower	1,296	25.2%	+18.4 GW (+1.4%)
Wind	1,292	25.1%	+159 GW (+14.0%)
Bioenergy	~150	2.9%	+3.4 GW (+2.3%)
Geothermal	~16	0.3%	+0.3 GW (+1.7%)
Others (CSP, marine)	~3	0.1%	small
Total	5,149	100%	+692 GW (+15.5%)

Table 7.1 — Global renewable power capacity by source at the end of 2025 (IRENA)

Note: an earlier draft report cited wind $\approx 1,081$ GW and hydro $\approx 1,289$ GW for end-2025; the set used here (wind 1,292 GW, hydro 1,296 GW) is the internally consistent IRENA-derived breakdown — the components sum exactly to the 5,149 GW total. Global annual additions grew from 582 GW in 2024 (+19.8% year-on-year) to about 692 GW in 2025.

Global renewable power capacity by source, end-2025 (total 5,149 GW, IRENA)




Figure 7.1 — Global renewable power capacity by source, end-2025 (IRENA).

Despite this record growth, the world remains off the trajectory needed to triple renewables to 11.17 TW by 2030 — the target agreed at COP28 in Dubai: the shortfall is about 6.02 TW. Reaching the target requires the annual growth rate to rise above 16% and, more importantly, sustained investment in grids and storage to absorb the variable output, along with faster permitting and expanded financing, particularly in developing economies.

7.2 India's Renewable Energy Journey

India is now the world's third-largest renewable energy market (after China and the USA). Key milestones from official MNRE/PIB data and industry trackers:

- **50% non-fossil capacity** — in June 2025 India reached 50% of installed electricity capacity from non-fossil sources, five years ahead of its 2030 NDC commitment under the Paris Agreement.
- **Capacity** — non-fossil installed capacity stood at 283.46 GW in March 2026 (renewables 274.68 GW + nuclear 8.78 GW); by June 2026 total renewable capacity had reached about 288.58 GW, with solar at 162.15 GW.
- **Growth** — renewable capacity rose from 76.38 GW (March 2014) to 274.68 GW (March 2026), a 3.59-fold increase, while solar grew 53-fold from 2.82 GW to 150.26 GW. In FY 2025–26 alone India added 55.3 GW of non-fossil capacity, including a record 29 GW of solar and wind in H1 2026.
- **Target** — 500 GW of installed non-fossil electricity capacity by 2030, announced at COP26.
- **Schemes** — PM Surya Ghar (rooftop solar) has supported ~23.90 lakh households (≈7 GW) with ₹13,464 crore of subsidies; PM-KUSUM has solarised 13.94 lakh agricultural pumps (13,112 MW); large solar parks, wind-solar hybrid tenders and green energy corridors are being executed across states.
- **Investment** — over US\$360 billion is expected to be invested in renewable energy and related infrastructure by 2030.

Component	Capacity (GW), Mar 2026	Notes
Solar power	150.26	Utility, rooftop, hybrid and off-grid
Wind power	56.09	Onshore; offshore tenders being launched
Hydro (large + small) + bio-power	~68.3	Residual of renewable total (large hydro ≈ 46.8 GW)
Nuclear	8.78	Non-fossil but not renewable
Total non-fossil	283.46	50%+ of total installed capacity (~542 GW)

Table 7.2 — India's non-fossil installed capacity, March 2026 (PIB / MNRE)




Figure 7.2 — Growth of India's renewable energy capacity, 2014 vs 2026 (MNRE/PIB).

7.3 Leading States in Renewable Capacity

Renewable deployment in India is concentrated in the resource-rich states: Rajasthan and Gujarat lead in solar, Tamil Nadu and Gujarat in wind, and the Himalayan states in hydro. Kerala, a small and densely populated state, ranks lower in raw capacity but is among the leaders in rooftop-solar adoption per capita.

State	Total RE (GW)	Solar (GW)	Wind (GW)	Hydro & biomass (GW)
Rajasthan	37.4	32.0	5.2	0.2
Gujarat	35.5	21.5	13.8	0.2
Tamil Nadu	25.2	10.6	11.8	2.8
Karnataka	24.0	15.0	7.7	1.3
Maharashtra	22.0	12.0	5.3	4.7
Andhra Pradesh	20.0	10.0	4.4	5.6
Madhya Pradesh	18.0	12.0	3.2	2.8
Kerala	3.2	1.8	0.5	0.9

Table 7.3 — Renewable capacity of leading Indian states (October 2025, industry estimates)

Kerala's 3.2 GW estimate predates the rooftop surge; Chapter 8 gives updated state figures.

8. Case Study: Kerala — Solar, Wind and Hydro

8.1 Kerala's Energy Profile

Kerala is a narrow, densely populated coastal state whose electricity demand has grown steadily while local generation has not kept pace: cumulative installed generation capacity is about 6,506 MW, and more than 50% of the state's energy requirement is met through imports, largely coal-based power from other states. Because Kerala has no coal, the strategic answer is to maximise generation from its own free sources — its rivers (hydro), its equatorial sun (solar) and its monsoon-driven winds. The state agency ANERT (Agency for New and Renewable Energy Research and Technology) is implementing a 3,000 MW renewable-energy expansion programme, and a draft regulation by the Kerala State Electricity Regulatory Commission (KSERC, 2025) is modernising the rules for rooftop solar and renewable deployment.

8.2 Hydroelectric Legacy: The Idukki Project

Kerala's power backbone has long been hydro. The Idukki Hydroelectric Project, commissioned in 1976 across the Periyar river, is the state's largest, with 780 MW installed capacity (six 130 MW units) in an underground powerhouse at Moolamattom — the longest underground power station in India. Its arch dam, among the highest in Asia, together with the Cheruthoni and Kulamavu dams, forms a reservoir of about 60 km². In its 50 years of operation the plant has generated over 115,852 million units. Other major schemes (Sabarigiri, Kuttiyadi and numerous small hydel projects) bring Kerala's total hydel capacity to roughly 1,900 MW. Because inflows are seasonal (south-west and north-east monsoons), hydro output varies through the year, which strengthens the case for complementary solar and wind.

8.3 Solar Programmes and the Rooftop Revolution

Kerala is one of the earliest and most successful states for rooftop solar in India. Solar capacity grew from about 188 MW (2020) to 902 MW (2023) and about 1,351 MW by April 2025, with 30–35 MW of on-grid installations added every month; rooftop solar alone crossed 1.5 GW by January 2026. Key initiatives include:

- **Soura / PM Surya Ghar** — the state-level rooftop programme; under the central scheme ANERT has solarised more than 500 public buildings in Thiruvananthapuram corporation alone (18 MW) and installed 2–3 kW systems in about 2,000 underprivileged households under the Green Income Scheme.
- **KSEB rooftop models** — consumer-owned, RESCO (company-owned, with free 10% energy for roof owners) and lease models have been important drivers, allowing zero-investment adoption.
- **Floating solar** — state guidelines cover floating plants on reservoirs, backwaters and non-arable land, tapping Kerala's abundant water surfaces without using farmland.
- **Hybrid solar-wind** — ANERT built Kerala's first solar-wind hybrid mini-grid at Chooralmala (Wayanad), where each of ten tribal-rehabilitation homes received a 1 kW solar + 500 W wind system with a 7.2 kWh battery.

8.4 Wind Energy Potential and Plans

Kerala's wind resource is modest compared with Tamil Nadu or Gujarat, but not negligible: installed wind capacity is about 71.2 MW (January 2025), while the estimated technical potential is about 2,993 MW, mainly in the highland areas of Palakkad district (Kanjikode/Attappady region) and select coastal stretches. The state plans to add 629 MW of wind by FY 2030 and 1,794 MW by FY 2040, and is studying offshore wind and solar-wind hybrid projects to raise capacity factors and evening output.




Figure 8.1 — Renewable energy status of Kerala: (a) solar capacity growth; (b) wind installed vs potential.

8.5 Relevance to Malappuram District

Malappuram, Kerala's most populous district, illustrates both the opportunity and the challenge. The district has good solar irradiation by Kerala standards (about 4.5–5 kWh/m²/day), a large number of residential and commercial rooftops, and KSEB's distribution network connecting almost every household. Rooftop solar under the Soura/PM Surya Ghar schemes is spreading through panchayats, and solar pumps are being installed on farms. Two practical local notes: (i) monsoon clouds reduce generation, so systems should be sized with a battery or net metering to balance seasonal output; and (ii) coastal areas of the district may support small wind and solar-wind hybrids, while inland agricultural areas are suited to solar pumps and solarised warehouses. The economics calculated in Chapter 9 apply directly to a typical Malappuram household.

Item	Status (latest available)	Source / date
Installed generation capacity	~6,506 MW; >50% of demand imported	Feb 2024 (state data)
Hydro capacity (incl. Idukki 780 MW)	~1,900 MW	KSEB / state data
Solar capacity	~1,351 MW (+30–35 MW/month)	Apr 2025 (ANERT)
Rooftop solar alone	>1,500 MW	Jan 2026 (CSE estimate)
Wind capacity / potential	71.2 MW / ~2,993 MW	Jan 2025 / ANERT
Wind targets	629 MW by FY30; 1,794 MW by FY40	State plans
RE expansion programme	3,000 MW target under ANERT	Ongoing

Table 8.1 — Kerala renewable energy snapshot

9. Economic Analysis

9.1 Levelised Cost of Electricity (LCOE)

The levelised cost of electricity is the constant price per unit of electricity (per kWh) needed to recover all costs of a plant — capital, operation, maintenance, fuel and finance — over its lifetime, discounted to present value:

$$LCOE = \frac{\sum (CAPEX_t + OPEX_t + Fuel_t)/(1+r)^t}{\sum E_t/(1+r)^t} \quad (r = \text{discount rate / WACC}; E_t = \text{energy generated in year } t; \text{Fuel} = 0 \text{ for solar, wind, hydro, geothermal})$$

IRENA's cost data show that renewables are now the cheapest source of new electricity: in 91% of newly commissioned capacity worldwide, renewable power cost less than the cheapest new fossil-fuel alternative, avoiding an estimated US\$467 billion of fuel costs in 2024 alone (rising to about US\$480 billion and 8.4 gigatonnes of avoided CO₂ in the 2025 assessment). Table 9.1 consolidates the global 2024 weighted-average LCOE values with capital costs, capacity factors and plant lifetimes.

Technology	LCOE 2024 (US\$/kWh)	vs cheapest fossil	CAPEX (US\$/kW)	Capacity factor	Life (years)
Onshore wind	0.034	53% cheaper	1,200–1,500	20–45%	25–30
Solar PV (utility)	0.043 (India 0.038)	41% cheaper	~691 global avg.	15–25%	25–30
Hydropower	0.057	cheaper	1,500–3,500	35–50%	50–100
Geothermal	0.066	comparable	2,500–5,000	70–90%	30–50
Offshore wind	0.081	comparable	2,800–3,500	40–55%	25–30
CSP	0.086	higher	4,000–7,000	30–50%	25–30
Bioenergy	0.089	higher	2,000–4,000	50–70%	20–30
Gas (CCGT)	0.070–0.110	—	~2,400	50–80%	30
Coal (pulverised)	0.080–0.130	—	3,000–4,000	50–70%	40

Table 9.1 — Techno-economics of power generation technologies (IRENA 2024 global weighted averages; CAPEX ranges from industry assessment)

2025 update (IRENA, Renewable Power Generation Costs in 2025): costs have entered a period of structural stabilisation — onshore wind ≈ US\$33/MWh, solar PV ≈ US\$44/MWh, hydropower ≈ US\$62/MWh, bioenergy ≈ US\$86/MWh, geothermal ≈ US\$89/MWh, offshore wind ≈ US\$78/MWh and CSP ≈ US\$115/MWh; China's record lows are US\$27/MWh (onshore wind) and US\$49/MWh (offshore wind). Dispatchable thermal renewables saw slight cost escalation from site-specific civil-engineering and supply-chain constraints.




Figure 9.1 — Global weighted-average LCOE of new power plants, 2024 (IRENA). Solar PV and onshore wind are 41% and 53% cheaper than the least-cost fossil alternative.

Solar PV LCOE has fallen about 90% since 2010 (from US\$0.417 to US\$0.043/kWh), and IRENA projects further reductions of roughly 30% by 2030 for solar-plus-storage — “firm” power at US\$54–82/MWh in high-irradiance regions, below new coal (US\$70–85/MWh) and well below new gas (over US\$100/MWh). Supply shortages for high-efficiency gas turbines have meanwhile *doubled* CCGT capital costs to roughly US\$2,400/kW, reinforcing the LCOE superiority of variable renewables.

9.2 Capital Cost Trends

Total installed costs have fallen dramatically: utility-scale solar from US\$5,283/kW in 2010 to US\$691/kW in 2024 (–87%), onshore wind to about US\$1,041/kW (–55%), and battery storage by ~93–95% since 2010. IRENA projects solar costs to reach about US\$388/kW and onshore wind US\$861/kW by 2030. In India, the combination of domestic manufacturing (PLI schemes), record-low module prices and competitive bidding has made solar and wind tariffs of ₹2.5–3.0 per unit common in recent auctions; wind-farm capital costs are about ₹6.5–7.5 crore per MW. Hydro projects cost more upfront but last 50–100 years.

9.3 Worked Examples

Example 1 — 10 kW rooftop solar PV system

For an illustrative engineering estimate, assume 5.5 equivalent peak-sun-hours per day (good Kerala site) and a performance ratio of 0.75 to account for system losses:

$$\text{Daily energy} \approx 10 \text{ kW} \times 5.5 \text{ h} \times 0.75 \approx 41.25 \text{ kWh/day} \rightarrow \text{Annual energy} \approx 41.25 \times 365 \approx 15,056 \text{ kWh/year}$$

This is an illustrative estimate, not a guaranteed output; a site-specific simulation should account for monthly radiation, temperature, tilt, shading, soiling and inverter efficiency.

Example 2 — 5 kW wind turbine

Assuming an illustrative capacity factor of 20% (a modest but realistic onshore site):

$$\text{Annual energy} = 5 \text{ kW} \times 8,760 \text{ h} \times 0.20 = 8,760 \text{ kWh/year}$$

The actual result depends strongly on the turbine power curve, hub height and the local wind-speed distribution (remember the cubic relationship).

Example 3 — 3 kW rooftop solar for a Kerala (Malappuram) home

Parameter	Value	Basis
System size	3 kWp	Typical Kerala rooftop
Effective sun hours	4.2 kWh/m ² /day	Kerala annual average, tilted surface
Performance ratio	0.80	Inverter + temperature + dust losses
Annual generation	$3 \times 4.2 \times 365 \times 0.80 \approx 3,679 \text{ kWh}$	$E = \text{capacity} \times \text{sun-hours} \times \text{PR}$
System cost	₹1,70,000 ($\approx$ ₹56,700/kWp)	2025–26 Indian market, incl. installation
PM Surya Ghar subsidy	₹78,000 (for 3 kW)	Central scheme (as applicable)
Net investment	₹92,000	After subsidy
Savings (self-consumption)	₹22,000–24,000/yr	$\sim 3,200 \text{ kWh} \times \text{₹6.5–7.0 avg. tariff}$
Export income (surplus)	₹1,200–2,000/yr	$\sim 600 \text{ kWh} \times \text{₹2.5–3.0 net-billing rate}$
Simple payback	$\approx 4\text{--}5 \text{ years}$	Net investment $\div$ annual benefit
25-year lifetime savings	$\approx$ ₹5.5–6.5 lakh	At constant tariffs
CO ₂ avoided	$\approx 3.0 \text{ t/year}$	Grid factor $\approx 0.82 \text{ kg CO}_2/\text{kWh}$

Table 9.2 — Illustrative economics of a 3 kW rooftop solar system in Kerala (2026 prices)

Even without the subsidy, the system pays for itself in roughly 7 years and then delivers free electricity for the remaining 18+ years of its life — the essence of “free energy” economics: high up-front capital, near-zero running cost. Adding a battery raises cost but gives backup: at 2025–26 prices (₹9,000–12,000 per kWh), a small 3–5 kWh battery adds about ₹30,000–60,000. All cost figures are illustrative and should not be used as quotations for a real installation; actual values depend on location, equipment, tariffs and applicable policies.

10. Environmental Life-Cycle Assessment and the Circular Economy

10.1 Life-Cycle Carbon Footprint

Although renewable generators emit zero greenhouse gases during operation, comprehensive environmental evaluation requires life-cycle assessment (LCA) — quantifying emissions across raw-material extraction, manufacturing, transport, construction, operation and end-of-life management, normalised as grams of CO₂-equivalent per kWh generated. Table 10.1 and Figure 10.1 compare sources on this basis.

Energy source	Life-cycle GHG (gCO ₂ eq/kWh)	Operational share	Dominant upstream drivers
Hydropower	4–24	<5%–50% (variable)	Concrete dams, reservoir land clearing, biogenic methane
Geothermal	6–38	5–20%	Drilling fuel; CO ₂ /H ₂ S release from geofluids
Onshore wind	11–14	<1%	Steel towers, concrete foundations, resin/fiberglass processing
Offshore wind	12–18	<1%	Subsea steel monopiles/jackets, installation-vessel fuel
CSP	8.8–42	0%	Glass mirrors, steel structures, nitrate-salt fluid
Solar photovoltaic	18–49.9	0%	High-temperature polysilicon refining, ingot slicing, aluminium smelting
Dedicated biomass	45–230	>80%	Harvesting diesel, transport, combustion emissions
Natural gas (CCGT)	410–490	>80%	Methane combustion; upstream fugitive leakage
Pulverised coal	740–1,000	>90%	Coal combustion, mining, coal-seam methane

Table 10.1 — Mean life-cycle GHG emissions by electricity source (standardised LCA literature)




Figure 10.1 — Life-cycle GHG emissions by source (log scale). Renewables are 10–50× cleaner than fossil fuels even counting manufacturing.

This reveals a critical systemic insight: renewable power systems *shift* environmental impacts from the operational phase to the manufacturing phase. Over 70% of a wind turbine’s lifetime emissions arise from material extraction and component production; for solar PV the dominant payload is upstream silicon purification (quartz reduction and the energy-intensive Siemens process). As grids decarbonise, the power supplied to polysilicon refineries and steel mills becomes cleaner, establishing a self-reinforcing “green

manufacturing” feedback loop that continuously lowers the footprint of future deployments.

10.2 End-of-Life Management and Recycling

Cumulative solar-panel waste is projected to exceed 25 million tonnes globally by 2050. A crystalline-silicon panel is roughly 70–75% cover glass, 15–18% aluminium frame, 5–8% EVA encapsulant polymer, 3–5% silicon cells and under 1% copper and silver — valuable material that should not be landfilled. Advanced recycling proceeds in three stages:

- **Mechanical disassembly and sorting** — automated removal of frames and junction boxes yields high-purity aluminium and copper streams; shredding and optical sorting separate glass from polymer backsheets.
- **Thermal / chemical delamination** — pyrolysis at about 500 °C burns off the EVA resin, cleanly separating glass from cell wafers; solvent-based dissolution is a lower-temperature alternative.
- **Hydrometallurgical extraction** — acid leaching and electro-refining recover silver, copper, tin and lead; high-purity silicon recovery (99.9999%) can re-enter the ingot supply chain.

For wind turbines, steel towers, copper windings and cast-iron nacelles are already recycled at rates above 90%; the challenge is the thermoset composite blades. Traditional recycling relies on cement co-processing (pulverised blades as kiln fuel and silica input), while emerging routes use chemical solvolysis to recover high-value carbon fibres and recyclable thermoplastic resins (e.g. Elium) that allow low-energy reshaping. Closing the loop economically requires extended-producer-responsibility (EPR) frameworks, design-for-disassembly standards and expanded recycling infrastructure, since landfill fees remain cheaper than advanced recycling in many regions. Solar panels typically serve 25–30 years and must be managed under applicable waste regulations at retirement.

11. Grid Integration, Storage and Hybrid Systems

11.1 The Integration Challenge

The Sun does not shine at night and the wind does not blow on demand. As variable renewables grow beyond a third of global capacity, grid operators must manage the “duck curve” — deep mid-day generation surpluses followed by steep evening ramps as solar output collapses exactly when residential demand peaks. Managing this requires system flexibility: grid-forming inverters, transmission interconnections, demand-side response, accurate AI-based weather forecasting and, above all, energy storage. A useful rule of thumb: because of capacity-factor differences, replacing 1 W of firm dispatchable thermal generation requires about 4 W of nameplate solar PV or 2 W of nameplate wind, supplemented by flexibility or storage.

11.2 Battery Energy Storage Systems (BESS)

Battery storage — dominated by lithium iron-phosphate (LFP) chemistries — provides sub-second frequency response, voltage stabilisation, ramping support and peak shaving. Four-hour utility-scale BESS capital costs have collapsed from about US\$2,700/kWh in 2010 to roughly US\$192/kWh in 2024 and about US\$140/kWh in 2025 (a ~95% decline), with China below US\$70/kWh (Figure 11.1). Pairing utility solar directly with four-hour BESS turns variable mid-day generation into dispatchable evening capacity: firm, high-reliability (95% availability) solar-plus-storage now costs below US\$85/MWh in high-resource regions. Already roughly 25% of newly commissioned utility-scale solar globally is co-located with batteries. India's PLI scheme is building domestic ACC battery factories, and pumped-storage hydro (about 142 GW worldwide) remains the largest storage resource.




Figure 11.1 — Utility-scale battery storage installed cost, 2010–2025 (~95% decline).

11.3 Hybrid Renewable Systems

A hybrid system combines two or more sources — commonly solar PV and wind — with a battery and power-management equipment. When sunlight is weak, wind may contribute more; when wind is weak, solar may contribute more. Because the sources are complementary (wind is often stronger at night and during the monsoon), combining them smooths output, improves reliability and reduces the battery capacity needed for a given availability. Kerala's first such mini-grid, at Chooralmala in Wayanad (Chapter 8), pairs 1 kW of solar with 500 W of wind and a 7.2 kWh battery per home. Figure 11.2 shows the generic power flow.




Figure 11.2 — Solar-wind hybrid system with battery storage: power flow from complementary free sources to AC loads or the grid.

12. Advantages and Limitations

The general advantages shared by all free energy sources are: no fuel cost and low operating cost once installed; minimal greenhouse-gas and air pollution during operation; reduced dependence on imported fuel and improved energy security; scalability from a single rooftop panel to utility-scale farms; steadily falling technology costs (solar electricity is now around 40% cheaper on average than coal-generated electricity in many markets); and local job creation. The common limitations are intermittency, land and material use, high upfront capital cost, grid and storage constraints in many regions, and environmental trade-offs at specific sites.

Technology	Main advantages	Main limitations
Solar PV	Free sunlight; no fuel; modular 1 W-GW; rooftop deployment needs no extra land; near-zero running cost; ~25-yr life; prices –90% since 2010	Intermittent (night, clouds); 20–24% module efficiency; needs land/batteries for firm power; manufacturing and e-waste concerns
Wind	Free wind; lowest LCOE (US\$0.034/kWh); day-and-night generation; 45–50% conversion efficiency; land sharable with farming	Variable output; needs windy sites; visual/noise impact; bird and bat concerns; higher maintenance at remote sites
Hydro	Firm, dispatchable; very long life (50–100 yr); reservoir storage; supports grid frequency; low running cost	Site-specific; high capital cost; displacement and river-ecology impacts; seasonal inflow variation
Small hydro	Continuous power where head and flow exist; high capacity factor; long life	Limited site availability; environmental permissions; seasonal flow
Biomass	Uses waste; dispatchable; rural employment	Fuel logistics; air emissions; land/water competition
Geothermal	24×7 baseload; capacity factor >80%; tiny land footprint	Limited to tectonic regions; high drilling cost
Tidal / wave	Perfectly predictable; huge theoretical resource	High cost; marine-environment effects; early-stage technology

Table 12.1 — Advantages and limitations of major free energy technologies

The common limitation — variability or site dependence — is overcome by combining technologies (hybrid plants), storage and smart grids, as discussed in Chapters 11 and 14.

13. Applications and Demonstration Model

13.1 Applications

- Residential rooftop electricity generation, often paired with battery storage.
- College, school and institutional buildings; commercial and industrial installations.
- Utility-scale solar and wind farms feeding electricity directly into the national grid.
- Off-grid solar and small wind systems for rural electrification and street/outdoor lighting.
- Telecommunication towers and remote monitoring systems.
- Agricultural pumping (PM-KUSUM solar pumps) and solarised warehouses.
- Electric-vehicle charging with suitable power-management systems.

- Microgrids, backup power, and hybrid solar-wind-storage systems for 24-hour supply.
- Green hydrogen production from surplus solar and wind electricity.

13.2 Suggested Working Model / Demonstration

A simple educational demonstration can use a small solar panel, a charge controller, a rechargeable battery, an LED load and a DC motor or small generator to show energy conversion; a separate small fan-driven turbine model demonstrates wind-to-electricity conversion. The measured voltage and current are recorded at different light and airflow conditions. The generic block diagram is: **renewable source → energy converter → controller → storage (optional) → inverter (if AC needed) → load** (Figure 11.2). The experiment should use low-voltage educational equipment under appropriate supervision.

13.3 Operation, Maintenance and Safety

Solar PV maintenance is light: periodic visual inspection, cleaning when necessary, checking electrical connections and monitoring inverter performance; useful indicators include specific yield (kWh/kW), availability and performance ratio. Wind systems require inspection of blades, tower, generator and mechanical/electrical components (capacity factor is the key indicator); hydro systems require inspection of intakes, penstocks, turbines and generators. Safety is critical: installations contain electrical and mechanical hazards and should be built and serviced by trained persons following applicable electrical, structural and local requirements. PV arrays remain energised in sunlight even when the grid supply is disconnected, and wind and hydro equipment requires mechanical isolation before maintenance. Panels and batteries also carry end-of-life responsibilities (Chapter 10).

14. Challenges and Mitigation Strategies

14.1 Intermittency and the Need for Storage

As variable renewables grow, grids need balancing resources: battery energy storage (costs down ~95% since 2010; India's PLI scheme is building ACC factories), pumped-storage hydro, solar-wind hybrids that smooth output, AI-based generation forecasting and demand-response programmes.

14.2 Grid Integration and Curtailment

Renewable-rich states sometimes face curtailment when transmission is congested. India's Green Energy Corridor projects and new HVDC lines are expanding evacuation capacity, while renewable purchase obligations (RPOs) create guaranteed demand; firm-and-dispatchable "round-the-clock" tenders (renewables plus storage) are already delivering power at US\$54–82/MWh in high-resource regions. Globally, permitting delays and grid-connection queues are the largest bottlenecks in advanced economies.

14.3 Land, Materials and Recycling

Utility-scale plants need about 1.5–2.5 hectares per MW of solar; floating solar, canal-top and canal-side plants, and agrivoltaics (crops under panels) reduce land pressure. Supply chains are concentrated (one country dominates module manufacturing), and trade tariffs can raise prices short-term; recycling of modules, batteries and blades must scale to avoid future waste problems (Chapter 10).

14.4 Financing and Policy

High up-front capital means financing cost dominates renewable economics, especially in developing countries where interest rates and perceived risks are higher. Stable policy, single-window clearances, subsidies (PM Surya Ghar, PM-KUSUM), production-linked incentives, green bonds and priority-sector lending are the standard remedies. Accelerating deployment in capital-constrained regions requires concessional finance and de-risking instruments; globally, a financing gap of several terawatts must close to meet the COP28 tripling target.

15. Future Scope and Recommendations

15.1 Technology Trends

- **Floating solar** — on reservoirs, lakes and backwaters; ideal for land-scarce Kerala, guidelines already issued.
- **Offshore wind** — India has announced a 30 GW target by 2030 (zones off Gujarat and Tamil Nadu); Kerala is studying its own offshore prospects; floating platforms open deeper-water sites.
- **Battery storage at scale** — BESS costs expected to fall a further 30–40% by 2030, making firm round-the-clock solar/wind the default new-build option.
- **Green hydrogen** — electrolysis from surplus solar/wind; Kerala's Hydrogen Valley and the National Green Hydrogen Mission are early movers.
- **Next-generation PV and turbines** — perovskite-silicon tandem cells (24–29% commercial efficiency, >34% in the lab) and 14–15 MW offshore turbines.
- **Hybrid parks and agrivoltaics** — solar-wind-storage hybrids and crops-under-panels multi-use land.
- **Digitalisation** — AI forecasting, smart inverters, virtual power plants and peer-to-peer energy trading.

15.2 Recommendations

- **Households (Malappuram/Kerala)** — install rooftop solar under PM Surya Ghar; combine with net metering or a small battery; expect a 4–5-year payback.
- **Institutions** — solarise public buildings, schools, hospitals and warehouses; KSEB's RESCO model allows zero-investment adoption.
- **Farmers** — use PM-KUSUM solar pumps; sell surplus generation to the grid.

- **State (Kerala)** — accelerate floating solar, wind development and hybrid projects; streamline grid connectivity; implement the KSERC renewable regulation with consumer-friendly net billing.
- **Nation (India)** — sustain the 500 GW-by-2030 momentum with storage mandates, green corridors and domestic manufacturing; push global finance to close the ~6 TW gap to the COP28 tripling target.

16. Conclusion

This consolidated report examined how electricity can be generated from free energy sources — sources that nature provides at no cost and replenishes continuously. The physics is well understood: the photovoltaic effect converts sunlight directly into current in silicon cells; wind turbines convert the kinetic energy of moving air ($P = \frac{1}{2}\rho AV^3$, within the Betz limit) into rotation and then electricity; hydro plants convert the potential energy of water ($P = \rho gQH\eta$) into firm power; and biomass, geothermal, tidal and ocean technologies add further diversity. The hardware — modules, inverters, controllers, batteries, turbines, gearboxes and generators — is mature, mass-produced and improving rapidly.

The numbers confirm that the transition is not a future promise but a present fact. Globally, renewable capacity reached 5,149 GW by end-2025 with a record 692 GW added in one year, and renewables now form nearly half of world installed capacity. India — third in the world — reached 50% non-fossil capacity five years early and stands at 274.68 GW of renewables, heading for 500 GW by 2030. On cost, solar (US\$0.043/kWh) and onshore wind (US\$0.034/kWh) beat every new fossil alternative, which is why 91% of new plants worldwide are renewable. Life-cycle analysis shows wind and solar are 10–50 times cleaner than coal even counting manufacturing. In Kerala, the legacy of Idukki's 780 MW of free hydro power is being joined by a rooftop-solar revolution (1.5 GW+), a 3,000 MW state programme, floating-solar plans and 2,993 MW of wind potential — and a typical 3 kW rooftop system in Malappuram pays for itself in about 4–5 years, then delivers electricity for free for two more decades.

The remaining work is not scientific but systemic: storage to smooth the sun and the wind, grids and markets to move the power, finance to pay the up-front capital, recycling systems for the hardware, and policy to keep the pace. For the student, the household and the nation, the conclusion is the same — the cheapest, cleanest and most secure electricity of the coming decades will come from sources that are free, and the only question is how quickly we harvest them.

References

- [1] International Renewable Energy Agency (IRENA), "Renewable Capacity Statistics 2026 — Highlights", March 2026. <https://www.irena.org>
- [2] International Renewable Energy Agency (IRENA), "Renewable Power Generation Costs in 2024", 2025. <https://www.irena.org/Publications/2025/Jun/Renewable-Power-Generation-Costs-in-2024>
- [3] International Renewable Energy Agency (IRENA), "Renewable Power Generation Costs in 2025: Executive Summary", July 2026. <https://www.irena.org/Publications/2026/Jul/Renewable-Power-Generation-Costs-in-2025>

- [4] Press Information Bureau, Government of India, “India Ranks Third Globally in Renewable Energy Installed Capacity”, 8 April 2026. <https://www.pib.gov.in>
- [5] India Brand Equity Foundation (IBEF), “Renewable Energy Industry in India”, May–June 2026. <https://www.ibef.org/industry/renewable-energy>
- [6] Down To Earth, “India Adds Record 29 GW Solar and Wind Capacity in H1 2026”, July 2026. <https://www.downtoearth.org.in>
- [7] Wright Research, “India’s Renewable Capacity in 2025: Progress Toward the 500 GW Goal”, November 2025. <https://www.wrightresearch.in>
- [8] Vajiram & Ravi, “India Ranks Third Globally in Renewable Energy Installed Capacity” and “Idukki Hydroelectric Project”, February–April 2026. <https://vajiramandravi.com>
- [9] Elets Net Zero, “Kerala’s Renewable Energy Push — Scaling Solar, Wind and Green Hydrogen”, April 2025. <https://netzero.eletsonline.com>
- [10] Centre for Science and Environment (CSE), “Kerala’s New Draft Regulation on Renewable Energy”, January 2026. <https://www.cseindia.org>
- [11] Saur Energy, “First Hybrid Solar and Wind Power Project Comes Up in Kerala by ANERT”, 2022. <https://www.saurenergy.com>
- [12] New Kerala, “ANERT Leads Renewable Energy Push in Kerala Through Key PM Schemes”, April 2025. <https://www.newkerala.com>
- [13] Kerala State Electricity Board (KSEB) / PM Surya Ghar portal. <https://solarrooftop.pmsuryaghar.gov.in>
- [14] Kerala Tourism, “Idukki Dam” (project profile). <https://www.keralatourism.org/munnar/idukki-dam.php>
- [15] U.S. Department of Energy, “Small Wind Guidebook” (WindExchange) and “Solar Photovoltaic System Cost Benchmarks”. <https://www.energy.gov>
- [16] U.S. Environmental Protection Agency, “Site Considerations for Renewable Energy Projects” and “End-of-Life Solar Panels: Regulations and Management”. <https://www.epa.gov>
- [17] Indian Institute of Science (IISc), “Scope for Solar Energy in Kerala and Karnataka”. <https://www.iisc.ac.in>
- [18] Climate Central, “Wind and Solar Power 101”, January 2025. <https://www.climatecentral.org>
- [19] EnergySage, “How Do Solar Cells Work? Photovoltaic Cells Explained”. <https://www.energysage.com>
- [20] pv magazine, “Firm Solar and Storage Costs Fall to \$54/MWh, Says IRENA”, May 2026. <https://www.pv-magazine.com>
- [21] TaiyangNews, “IRENA: Solar Power Averaged \$0.043/kWh Globally in 2024”, July 2025. <https://taiyangnews.info>
- [22] Wikipedia, “Life-cycle Greenhouse Gas Emissions of Energy Sources” and “Betz’s Law” (compilation of LCA and aerodynamic sources). <https://en.wikipedia.org>
- [23] MDPI Energies, “Renewable Energy and CO₂ Emissions: Analysis of the Life Cycle”, Energies 18(13), 3332. <https://www.mdpi.com/1996-1073/18/13/3332>
- [24] Lazard, “Levelized Cost of Energy+ (LCOE+)”. <https://www.lazard.com/research-insights/levelized-cost-of-energyplus-lcoeplus/>
- [25] U.S. Energy Information Administration (EIA), “Capacity Factor for Electric Utility Generation”. <https://www.eia.gov>
- [26] Alternative Energy Tutorials, “Betz Limit and the Power Coefficient of Wind Turbines”. <https://www.alternative-energy-tutorials.com>

- [27] IRENA, “End-of-Life Management for a Circular Economy: Solar PV Panels”, 2026, and “Circular Economy” policy pages. <https://www.irena.org/Energy-Transition/Policy/Circular-economy>
- [28] IJRASET, “Renewable Energy Sources: Comparative Analysis of Solar, Wind, Hydropower and Biomass in India”. <https://www.ijraset.com>
- [29] ABI Research, “Renewable Energy Statistics 2026” (Smart Energy Research Service). <https://www.abiresearch.com>
- [30] Note: web addresses are provided at source-domain level; full citation details should be completed by the student in the referencing style (APA/MLA/IEEE) required by the institution.

Appendix A — Analysis of the Four Source Documents

This consolidated report was produced by analysing and merging four project-report drafts on the same subject. Table A.1 summarises each document, its distinctive strengths, and the issues found during analysis.

Source document (file)	Pages	Focus and distinctive content	Issues found during analysis
Electricity_from_Free_Energy_Sources_Report.pdf	9	General academic report: working principles, global 2025–26 status, source comparison, applications; strong on next-generation PV (HJT, perovskite tandems) and 14–15 MW offshore turbines	Title page has unfilled placeholders; global wind capacity ($\approx 1,081$ GW) inconsistent with the IRENA end-2025 dataset; Table of Contents page empty
Renewable Energy Project Report.pdf (name with spaces)	7	Technical-economic deep dive: LCOE formula and capacity-factor analysis, life-cycle CO ₂ assessment table, circular economy and recycling, BESS cost decline, firm solar+storage	Text contains copy-paste artefacts from an online AI document editor (stray “Make tweaks, leave comments...”, “NO THANKS / USE THE APP” and garbled header watermarks) — removed here; cites both IRENA 2024 and 2025 cost reports
Renewable_Energy_Electricity_Project_Report.pdf	7	Engineering-student report: small hydro and hybrid systems, component-function tables, sample calculations (10 kW PV, 5 kW wind), safety, O&M; demonstration model, EPA/DOE references	Kerala insolation figure (>5.5 kWh/m ² /day) is at the optimistic end of the 4.5–5.5 range used elsewhere; otherwise internally consistent
Renewable_Energy_Project_Report.pdf	29	Deep-research study: fullest structure (13 chapters + glossary + abbreviations), India scenario with schemes, Kerala case study incl. Idukki and Malappuram, 3 kW rooftop economics, 19 references	Cover placeholders unfilled; figure captions present but no actual chart images embedded in the text layer

Table A.1 — Document-by-document analysis of the four source reports

Reconciliation decisions taken while merging:

- **Global wind/hydro capacity** — adopted wind 1,292 GW and hydro 1,296 GW (the internally consistent IRENA set summing exactly to 5,149 GW); the $\approx 1,081$ GW figure in one draft appears to be an older estimate and is footnoted in §7.1.
- **LCOE vintage** — the 2024 IRENA weighted averages are used in the main table (cited by most drafts); the 2025 update is quoted separately as a note in §9.1.

- **Kerala insolation** — the range 4.5–5.5 kWh/m²/day is used, with the IISc >5.5 figure retained for the optimistic worked example (Example 1) and the conservative 4.2 used in the 3 kW economic example, so the sensitivity is visible.
- **Capacity factors** — ranges merged across drafts (onshore wind 20–45%, offshore 35–55%) since site quality varies.
- **Editorial artefacts** — all editor watermarks/UI text found in one PDF were stripped; duplicate boilerplate across drafts was de-duplicated.

Appendix B — Glossary

Photovoltaic (PV) effect	Generation of voltage/current in a semiconductor when it absorbs light.
Module / panel	Assembly of PV cells (typically 60–72) producing DC power.
Inverter	Device converting DC to AC; also the grid-safety interface.
Charge controller / MPPT	Regulator between array, battery and load that maximises energy capture.
Net metering / net billing	Billing arrangement in which exported solar units offset imported units / are paid at a set rate.
Betz limit	Maximum 59.3% of wind kinetic energy convertible by any rotor (16/27).
Capacity factor	Actual generation ÷ maximum possible generation over a period.
LCOE	Levelised cost of electricity — lifetime cost per kWh, discounted to present value.
Performance ratio (PR)	Ratio of actual to theoretical PV system output after all losses.
Dispatchable	Capable of being turned up/down on demand (e.g. hydro, gas, biomass).
Variable renewable energy (VRE)	Sources whose output varies with weather/time (solar, wind).
BESS	Battery energy storage system.
RESCO model	A renewable energy service company owns the plant; the consumer pays for energy or roof space.
Duck curve	Net-load shape caused by high solar penetration: mid-day trough and steep evening ramp.
Life-cycle assessment (LCA)	Evaluation of environmental impacts across manufacture, operation and end-of-life.
Extended producer responsibility (EPR)	Policy making producers responsible for end-of-life management of their products.
Green hydrogen	Hydrogen produced by electrolysis of water using renewable electricity.

Appendix C — Abbreviations

ANERT	Agency for New and Renewable Energy Research and Technology (Kerala)
BESS / ACC	Battery Energy Storage System / Advanced Chemistry Cell
COP / NDC	Conference of the Parties / Nationally Determined Contribution
CSP / OTEC	Concentrated Solar Power / Ocean Thermal Energy Conversion
DC / AC	Direct Current / Alternating Current
GW / MW / kWh	Gigawatt / Megawatt / kilowatt-hour
HAWT / VAWT	Horizontal-Axis / Vertical-Axis Wind Turbine
HJT	Heterojunction (solar cell technology)
IRENA / IEA	International Renewable Energy Agency / International Energy Agency
KSEB / KSERC	Kerala State Electricity Board / Kerala State Electricity Regulatory Commission
LCOE / CAPEX / OPEX	Levelised Cost of Electricity / Capital Expenditure / Operating Expenditure
MNRE / PIB	Ministry of New and Renewable Energy / Press Information Bureau (Government of India)
PM-KUSUM	Pradhan Mantri Kisan Urja Suraksha evam Utthaan Mahabhiyan
PM Surya Ghar	National rooftop-solar scheme (“Muft Bijli”)
PR / CF	Performance Ratio / Capacity Factor
PV	Photovoltaic
RE / VRE / RPO	Renewable Energy / Variable Renewable Energy / Renewable Purchase Obligation

This consolidated report was prepared in August 2026 by merging and reconciling the four source documents listed in Appendix A. Placeholder fields (name, roll number, course, guide, institution) should be completed by the student before submission.